### WELCOME TO HAWKE INTERNATIONAL – INTERACTIVE CATALOGUE

This interactive catalogue has been designed with ease of use in mind. The pages are interactive and contain links or 'hotspots' that can be clicked to take the user to the relevant information or page.

### INSTRUCTIONS FOR USE

It is recommended that you print out these instructions for reference.

### LINKS

A link is signalled when the mouse pointer changes from a hand to a pointing finger. For example where a page number is referenced.

### FIT TO SCREEN

The default for each page is fit to screen, which allows a full view of the page without the need to scroll.

### TO ENLARGE THE PAGE

- I. Select the magnifying glass icon from the toolbar and click on the page until the required size is reached.
- 2. To enlarge a particular section of the page, click and hold down the left mouse button, drag the bounding box over the section you wish to enlarge and release the mouse button.

### STEP THROUGH EACH PAGE IN SEQUENCE

Use the  $\checkmark$  and  $\triangleright$  buttons, usually found on the toolbar at the top of the screen, to move backwards and forwards through the pages. There is a page counter at the bottom left of the screen that indicates where you are in the sequence. You can also move to other pages by highlighting the page numbers and typing in a number.

### **RETURN TO PREVIOUS VIEW**

Clicking the 4 button found in the toolbar at the top of the screen will return you to the previous view i.e. whatever was displayed previously on the screen. This would shrink the page if you had enlarged it, or return you to a previous page if you had just left it.

**CLICK HERE** 

TO CONTINUE

Hawke International is committed to providing you, the end user, with software products that are easy to use, that provide you with the information you are seeking in a quick and efficient manner and are of benefit to you. If you have any comments/suggestions about our software products please do not hesitate to contact Hawke International





Featuring the New ATEX range





## Introduction



### FOR CUSTOMERS WHO DEMAND THE BEST

For those who demand quality, reliability and above all, safety, Hawke International is the obvious choice.

### **Smarter Products**

Hawke International has provided peace of mind to contractors, installers and end users for over 50 years. Our innovative range of cable connection and termination products, specifically designed with the customer in mind, have gained worldwide approval and credability for the testing conditions of hazardous (classified) locations and hostile environments.

The customers requirements for sustained safety and reliability under extreme conditions are therefore Hawke's primary objectives. Furthermore our superior designs allow ease of installation, use long life materials and are manufactured to rigorous quality standards. All this provides the customer with unparalleled benefits of the lowest lifetime cost of purchase.

### Worldwide

Located in Manchester, UK, Hawke International has subsidiary locations in Houston, USA and Singapore, along with direct representation in Brazil, the Middle East, Canada and China. Hawke International is supported worldwide by the Hubbell Group along with a global network of agents and distributors.

### **Product Development**

Hawke International recognises that the demands of the customer base never stand still and we are therefore committed to the ongoing development of our products and features to provide improved safety, versatility, reliability and ease of use.

### **First Choice**

Predominantly used on Offshore and Onshore oil and gas exploration, production and processing facilities. Hawke's products are the 'First Choice' for the world's major oil, gas and petrochemical companies.

### A Quality Company

Hawke International's products are designed and manufactured under a quality system not only complying with ISO 9001 but also with the latest international standards. Rigorous and regular in-house testing ensures that every product manufactured meets the highest quality standards expected by the market.











Hawke International "Leading the way in the design of worldwide connection solutions"



Hawke Cable Glands Contents

Flameproof/Increased Safety and Industrial

	Page No.	
Cable Gland Selection Chart	4 - 8	ntents
Hazardous Area Cable Glands	9 - 23	ls Co
<ul> <li>Cable Gland Features</li> <li>501/421 Technical Data</li> <li>501/423 Technical Data</li> <li>501/453/Universal Technical Data</li> <li>501/453/RAC Technical Data</li> <li>501/453/RAC/L Technical Data</li> <li>PSG 553/RAC Technical Data</li> <li>ICG 623 Technical Data</li> <li>ICG 653/Universal Technical Data</li> <li>ICG 653/Universal/L Technical Data</li> <li>501/414 Technical Data</li> <li>SB 474 Technical Data</li> </ul>	9 -10 11 12 13 14 15 16 17 18 19 20 21	Hawke Cable Glanc
<ul> <li>CSB 656 Technical Data</li> <li>Oversize Cable Glands and Increased Safety Cable Glands</li> </ul>	22	
<ul> <li>Plastic Cable Glands and Accessories</li> <li>HPG-Ex Metric Thread Technical Data</li> <li>HPG-Ex NPT Thread Technical Data</li> <li>HPG-Ex PG Thread Technical Data</li> <li>Plastic Cable Gland Accessories</li> </ul>	24 - 27 24 25 26 27	
Mining Glands and Accessories • Mining Gland Features • 653/Universal Group I Technical Data • 653/T Group I Technical Data • 623 Group I • Stopping Plug and Flanges Group I • Adaptors and Reducers Group I	28 - 33 28 29 30 31 32 33	



### Hawke Cable Glands Contents

Flameproof/Increased Safety and Industrial

	Page No.	
Industrial Cable Glands	34 - 43	
Cable Gland Features	34 - 35	
I2I Technical Data	36	
123 Technical Data	37	
153/Universal Technical Data	38	
• 153/RAC Technical Data	39	
• 153/RAC/L Technical Data	40	
• 150/RAC Technical Data	41	
151/RAC Technical Data	42	
II4 Technical Data	43	
North American Series Cable Glands/Connectors	44 - 51	
Cable Gland Features	44 - 43	
• 710 Technical Data	46	
711 and 713 Technical Data	47	
• 753 Technical Data	48	
• 755 Technical Data	49	
I53/X Technical Data	50	
• 701 Technical Data	51	
Accessories	52 - 57	
Nylon, Red Fibre and Serrated Washers	53	
Earth Tags and Locknuts	54	
Shrouds and Insulated Adaptors	55	
Stopping Plugs	56	
Adaptors and Reducers	57	
Technical Data	58 - 87	
• 1.0 Potentially Explosive Atmospheres	59	
• 2.0 Area Classification (Classification of Locations)	59	
• 3.0 CENELEC and IEC	59 - 63	
• 4.0 ATEX 94/9/EC Directive	63 - 64	
• 5.0 Wiring Systems and Extract from	65 - 68	
BS EN 60079-14 : 1997/IEC 60079-14 : 1996		
Installation in Hazardous Areas	(0 <del>7</del> 0	
• 6.0 Apparatus Marking - IEC and CENELEC (Group II)	69 - 70	
• 7.0 CE Marking	/1	
• 8.0 Certification/Listing	/1	
• 9.0 CENELEC and IEC Degree of Protection, IP Code	12 - 15	
• IU.U IECEX Scheme	/ 5	
• 11.0 North American Hazardous (Classified) Locations	/5 - /8 70 04	
• 12.0 vviring Systems	/ð - ð4	
I 3.0 Abbreviations, Acronyms and Definitions	84 - 87	

Cable Gland Type	Colour Code/ Page	Application/Cable Type	Sealing/Ingress Protection	Material	Certification	Protection Concept
501/421	П	Indoor/outdoor Non-armoured cable	Outer cable sheath seal IP66/67/68 Deluge	Brass Stainless Steel	EC IEC	Flameproof and Increased Safety roval.
501/423	12	Indoor/outdoor Non-armoured cable	Two outer cable sheath seals IP66/67/68 Deluge	Brass	EC IEC C IEC C IEC AUS C IEC Marine Appr	Flameproof and Increased Safety oval.
501/453/Universal	13	Indoor/outdoor Armoured/braided cable with inner and outer sheath	Inner (diaphragm) and outer cable sheath seals IP66/67/68 Deluge	Brass Stainless Steel	EC IEC C C C Marine Appr	Flameproof and Increased Safety oval.
501/453/RAC	14	Indoor/outdoor Armoured/braided cable with inner and outer sheath	Inner and outer cable sheath seals IP66/67/68 (Deluge option)	Brass Stainless Steel	EC IEC C C C Marine Appl	Flameproof and Increased Safety roval.
501/453/RAC/L	15	Indoor/outdoor Armoured/braided cable with inner lead sheath and outer sheath	Inner lead sheath seal/electrical bond and outer cable sheath seal IP66/67/68 (Deluge option)	Brass	EC IEC	Flameproof and roval. Increased Safety
PSG 553/RAC	16	Indoor/outdoor Armoured/braided cable with inner (optional) and outer sheath	Individual conductor seal and outer cable sheath seal IP66/67/68 (Deluge option)	Brass		Flameproof and Increased Safety
ICG 623	17	Indoor/outdoor Non-armoured cable	Inner (compound) and outer cable sheath seals IP66/67/68 Deluge	Brass	EC IEC	Flameproof and roval. Increased Safety
ICG 653/Universal	18	Indoor/outdoor Armoured/braided cable with inner (optional) and outer sheath	Inner (compound) and outer cable sheath seals IP66/67/68 Deluge	Brass Stainless Steel	EC IEC C IEC AUS Marine Appr	Flameproof and Increased Safety roval.

HAVK69 June '07

Cable Gland Type	Colour Code/ Page	Application/Cable Type	Sealing/Ingress Protection	Material	Certification	Protection Concept		
ICG 653/UNIV/L	19	Indoor/outdoor Armoured/braided cable with inner lead sheath and outer sheath	Inner lead sheath seal/electrical bond and outer cable sheath seal IP66/67/68 Deluge	Brass	EC IEC G C Marine Approval.	Flameproof and Increased Safety		
501/414	20	Indoor/outdoor Non-armoured cable, conduit system	Outer cable sheath seal IP66/67/68 Deluge	Brass	EC IEC 🔛 Marine Approval.	Flameproof and Increased Safety		
SB 474	21	Indoor/outdoor Individual conductors, conduit system	Individual conductor seal IP66/67/68 Deluge	Brass	EC IEC 🔛 Marine Approval.	Flameproof and Increased Safety		
CSB 656	22	Indoor/outdoor Individual conductors, conduit system	Individual conductor (compound) seal IP66/67/68 Deluge	Brass	EC IEC ES AUS	Flameproof and Increased Safety		
Oversize G, H & J and Increased Safety Cable Glands	23							
HPG-Ex Plastic Cable Glands	24-26	Indoor/outdoor Non-armoured elastomer and plastic insulated cable	Outer cable sheath seal IP66/67/68	Polyamide		Increased Safety		
Plastic Cable Gland Accessories	27		PLEASE REFER T	O INDIVIDUAL DA	data sheets for details			
653/Universal Group 1 Mining	29	Indoor/outdoor Armoured/braided cable with inner (optional) and outer sheath	Inner (compound) and outer cable sheath seals IP66/67/68 Deluge	Brass Stainless Steel		Group I Mining		

**Cable Gland Selection Chart** 

# Connection Solutions

Cable Gland Type	Colour Code/ Page	Application/Cable Type	Sealing/Ingress Protection	Material	Certification	Protection Concept					
653/T Group I Mining	30	Indoor/outdoor Pliable wire armoured, elastomer and plastic insulated cable	Inner (compound) and outer cable sheath seals IP66/67/68 Deluge	Brass		Group I Mining					
623 Group I Mining	31	Indoor/outdoor Non-armoured elastomer and plastic insulated cable.	Inner (compound) and outer cable sheath seals IP66/67/68 Deluge	Brass		Group I Mining					
Accessories Group I Mining	32		PLEASE REFER	TO INDIVIDUAL DA	TA SHEETS FOR DETAILS						
Adaptors/Reducers Group I	33		PLEASE REFER TO INDIVIDUAL DATA SHEETS FOR DETAILS								
121	36	Indoor/outdoor Non-armoured cable	Outer cable sheath seal IP66/67/68 Deluge	Brass		Industrial					
123	37	Indoor/outdoor Non-armoured cable	Two outer cable sheath seals IP66/67/68 Deluge	Brass		Industrial					
I 53/Universal	38	Indoor/outdoor Armoured/braided cable with inner and outer sheath	Inner (diaphragm) and outer cable sheath seals IP66/67/68 Deluge	Brass Stainless Steel		Industrial					
I53/RAC	39	Indoor/outdoor Armour/braided cable with inner and outer cable sheath	Inner and outer cable sheath seals IP66/67/68 (Deluge option)		Industrial						

**Cable Gland Selection Chart** 

Cable Gland Type	Colour Code/ Page	Application/Cable Type	Sealing/Ingress Protection	Material	Certification	Protection Concept
I53/RAC/L	40	Indoor/outdoor Armoured/braided cable with inner lead sheath and outer sheath	Inner lead sheath seal/electrical bond and outer cable sheath seal IP66/67/68 (Deluge option)	Brass		Industrial
ISO/RAC	41	Dry Indoor/outdoor Armoured/braided cable with inner (optional) and outer sheath		Brass		Industrial
ISI/RAC	42	Indoor/outdoor Armoured/braided cable with inner (optional) and outer sheath	Outer cable sheath seal IP66 (Deluge option)	Brass		Industrial
	43	Indoor/outdoor Non-armoured cable, conduit system	Outer cable sheath seal IP66/67/68 Deluge	Brass		Industrial
710	46	Indoor/outdoor Non-armoured cable	Inner (compound) and outer cable jacket seals IP66/67/68 NEMA 4X & Deluge	Brass with Nickel Plated Entry	Marine Approval.	Explosion Proof
711 and 713	47	Indoor/outdoor Type MCHL and Teck cables	Inner (compound) and outer cable jacket seals IP66/67/68 NEMA 4X & Deluge	Brass with Nickel Plated Entry	Image: Weight of the second	Explosion Proof
753	48	Indoor/outdoor Armoured Marine Shipboard cable	Inner (compound) and outer cable jacket seals IP66/67/68 NEMA 4X & Deluge	Brass with Nickel Plated Entry and Stainless Steel	Marine Approval.	Explosion Proof
755	49	Indoor/outdoor Steel Wire Armoured cable with inner (option) and outer jacket	Inner (compound) and outer cable jacket seals IP66/67/68 NEMA 4X & Deluge	Brass with Nickel Plated Entry	Image: Constraint of the second se	Explosion Proof

HAVK69 June '07

Cable Gland Type	Colour Code/ Page	Application/Cable Type	Sealing/Ingres Protection	Material	Certification	Protection Concept					
153/X	50	Indoor/outdoor Armoured marine shipboard jacketed or non-jacketed cable	Inner and outer cable jacket seals IP66/67/68 NEMA 4X & (Deluge option)	Brass with Nickel Plated Entry	Image: Constraint of the second se	General Purpose					
701	51	Indoor/outdoor Type MC and Teck cables	Outer cable jacket seal IP66/67/68 NEMA 4X & Deluge	Brass with Nickel Plated Entry	Image: Constraint of the second se	General Purpose					
	53-56		PLEASE REFER TO INDIVIDUAL DATA SHEETS FOR DETAILS								
Accessories	53-56		PLEASE REFER TO INDIVIDUAL DATA SHEETS FOR DETAILS								
Accessories	53-56		PLEASE REF	ER TO INDIVIDUAL	DATA SHEETS FOR DETAILS						
Accessories	53-56		PLEASE REF	er to individual	DATA SHEETS FOR DETAILS						
Adaptors and Reducers	57		PLEASE REFER TO INDIVIDUAL DATA SHEETS FOR DETAILS								
Technical Data Hawke Cable Glands and Enclosures	58-87		PLEASE REFER TO INDIVIDUAL DATA SHEETS FOR DETAILS								

**Cable Gland Selection Chart** 

# Cable Gland Selection Chart

# Hazardous Area Cable Glands



Connection Solutions www.ehawke.com





Flameproof and Increased Safety



### Features

### Unique Rear Sealing System

This arrangement offers IP66, IP67, IP68 (30 metres for 7 days), NEMA 4X and Deluge (DTS01) Ingress Protection. The seal is manufactured from a silicone material, has LSFZH properties, is ozone and oil resistant and is suitable for use at both high and low temperatures. The Rear Sealing System covers the entire range of cable diameters without the need for special seals and the cable acceptance range is stamped on the backnut for ease of inspection. The backnut can be hand tightened, with only one further spanner turn required to ensure IP66, IP67, IP68 and NEMA 4X.

### Unique Inspectable Compound Chamber

The revolutionary Hawke compound chamber has been designed with inspectability in mind. The pre-lubricated compound chamber can be removed once the compound has fully cured, allowing full inspection of the flameproof seal. If required minor surface voids can be repaired in situ. This unique patented compound chamber now forms the compound as well as providing a flameproof seal, resulting in reduced piece parts, as there is no longer a requirement to separate the seal from the compound chamber.

### • Zero Cable Damage

The unique Hawke diaphragm sealing system does not damage cable with 'Cold Flow' characteristics. The diaphragm type seal is the only elastomeric seal to comply fully with EN 60079-14 and IEC 60079-14 and is therefore suitable on cables which would otherwise require barrier style cable glands. The Hawke diaphragm seal is also unique in that it is the only flameproof elastomeric seal that can be visually inspected in operation - A real benefit to ATEX inspectors.

### • The Original Reversible Armour Clamp

The original RAC clamping system was invented by Hawke over 10 years ago and is a well established proven performer in all conditions. Simply by reversing the clamping ring, the cable gland can adjust to accomodate all types of cable armour or braid. Unlike many of our competitors the correct clamping orientation is marked clearly with a 'W', 'Z' or 'X' and backed up by the presence of a groove in the component. Hawke's RAC clamping system is also fully inspectable when positioned on the cable.

### • Inspectable Deluge Seal

Hawke's inspectable deluge seal offers IP66 and IP67 sealing and is certified as 'deluge proof' by ITS in accordance with DTS01. Indeed Hawke's deluge seal is so good that it exceeds the expectations of the offshore industry by not only preventing ingress into the equipment, but also into the cable gland, which could potentially corrode the cable armour.















	С	ABLE	GLA	ND SEL	ECT	ION.	TAB	LE	
	Entry	Thread	(	Cable Acceptan		Но	Yagon		
S:		Size		Outer She		Dimensions			
Ref			S	tandard	Alter	native	'G'		
	Motric	NPI↑ Std/		Seal	Sea	I (S)		Across	Across
		Option	Min.	Max.	Min.	Max.		Flats	Corners
2K	MI6	-	3.0	8.0	-	-	27	19.0	21.2
Os	M20 <sup>2</sup>	<sup>1</sup> /2"	3.0	8.0	-	-	32.8	24.0	27.7
0	M20 <sup>2</sup>	1/2"	7.5	11.9	-	-	32.8	24.0	27.7
Α	M20	3/4"/1/2"	11.0	14.3	8.5	13.4	32.8	30.0	34.6
В	M25	"/³⁄4"	13.0	20.2	9.5	15.4	33.8	36.0	41.6
С	M32	11/4"/1"	19.0	26.5	15.5	21.2	35.2	46.0	53.I
C2	M40	1⁄2"/   1⁄4"	25.0	32.5	22.0	28.0	36.5	55.0	63.5
D	M50	2"/1½"	31.5	44.4/42.3 <sup>1</sup>	27.5	34.8	47.9	65.0	75.I
Е	M63	21⁄2"/2"	42.5	56.3/54.3 <sup>1</sup>	39.0	46.5	46.2	80.0	92.4
F	M75	3"/2½"	54.5	68.2/65.3 <sup>1</sup>	48.5	58.3	48	95.0	109.6
G	M80	31⁄2"	67.0	73.0	-	-	41	106.4	123.0
н	M90	31⁄2"	67.0	77.6	-	-	41	115.0	132.8
J	MI00	4"	75.0	91.6	-	-	41	127.0	146.7

<sup>1</sup> Smaller value is applicable when selecting reduced NPT entry option.
 <sup>2</sup> Sizes Os and O are available with an M16 thread size. For O size with M16 thread, the maximum cable outer sheath diameter is 10.9mm.

### **General Information**

2K - F size metric entry threads are 1.5mm pitch as standard. For G size glands and above, a 2mm pitch is supplied as standard. (1.5mm pitch with 15mm length of thread can be supplied) please specify when ordering.

Thread length is 15mm for sizes 2K to F and 20mm for sizes G to J. All dimensions in millimetres (except\* where dimensions are in inches). Assembly instruction data sheet No. A.I. 307.

Accessories including locknuts, sealing washers, serrated washers, earth tags, shrouds, adaptors and reducers available. See pages 53 - 57.

### Materials & Finishes

The 501/421 cable gland is manufactured in brass (standard), nickel plated brass, 316 stainless steel or aluminium. Brass NPT entries are nickel plated as standard.

### Cable Gland Ordering Examples

Cable Gland Type/Size/Thread

e.g. 501/421/C/M32 501/421/C/1<sup>1</sup>/4" NPT

### Cable Gland with Alternative Seal (S)

e.g. 501/421/C/M32/S 501/421/C/1½" NPT/S

# Flameproof and Increased Safety

Cable Gland Type

🎬 ATEX 🐼 🤆

501/421



2K Size Cable Gland Design

### Application

- Outdoor or Indoor use.
- For use with non-armoured elastomer and plastic insulated cables.
- See technical section of the catalogue for installation rules and regulations.

### Features

- Provides a cable retention seal onto the cables outer sheath.
- When used in increased safety applications, this cable gland may be used with braided cable where the braid and the cables outer sheath pass into the enclosure.

The braid must be suitably terminated inside the enclosure.

- Flameproof Exd and Increased Safety Exe. ( II 2 GD
- Baseefa 06ATEX0056X.
- IECEx BAS06.0013X.
- Suitable for use in Zone 1, Zone 2, Zone 21 and Zone 22.
- Suitable for use in Gas Groups IIA, IIB and IIC.
- Construction and test standards EN 50014, EN 50018, EN 50019 and EN 50281-1-1. IEC 60079-0, IEC 60079-1 and IEC 60079-7.
- IP66, IP67 and IP68 (30 metres for 7 days) ingress protection to IEC 60529, EN 60529 and NEMA 4X.
- DTS01 deluge protection certified by ITS. Additional deluge protection seal also available.
- Operating temperature range -60°C to +100°C as standard.
- Alternative Certification Options Available.
  - 🚺 🚯 Exd IIC/Exe II.
  - 🚫 CV C E P E L BR-Exd IIC/Exe II.
  - 🔤 📴 GOST R-Exd IICU/Exe IIU.
  - Approved for use in Kazakhstan.
  - AUS-Exd IIC/Exe II.
  - Marine Approval.





	С	ABLE	GLA	ND SEL	ECT	ION	ГАВ	LE	
	Entry	Thread	C	Cable Acceptan		Но	(agon		
Sizo		Size		Outer She		Dime	ensions		
Ref			S	tandard	Alter	native	'G'		
	Motric	NP1*		Seal	Sea	l (S)		Across	Across
		Option	Min.	Max.	Min.	Max.		Flats	Corners
Os	M20 <sup>2</sup>	<sup>1</sup> /2"	3.0	8.0	-	-	52.3	24.0	27.7
0	M20 <sup>2</sup>	1⁄2"	7.5	11.9	-	-	52.3	24.0	27.7
А	M20	<sup>3</sup> /4"/1/2"	11.0	14.3	8.5	13.4	51.5	30.0	34.6
В	M25	"/3⁄4"	13.0 20.2		9.5	15.4	54.7	36.0	41.6
С	M32	1/4"/ "	19.0	26.5	15.5	21.2	55.9	46.0	53.I
C2	M40	1⁄2"/   1⁄4"	25.0	32.5	22.0	28.0	58. I	55.0	63.5
D	M50	2"/1½"	31.5	44.4/42.3 <sup>1</sup>	27.5	34.8	74.3	65.0	75.I
Е	M63	21⁄2"/2"	42.5	56.3/54.3 <sup>1</sup>	39.0	46.5	73.2	80.0	92.4
F	M75	3"/2½"	54.5	68.2/65.3 <sup>1</sup>	48.5	58.3	75	95.0	109.6
G	M80	31/2"	67.0	73.0	-	-	68	106.4	123.0
н	M90	31⁄2"	67.0	77.6	-	-	68	115.0	132.8
J	M100	4"	75.0	91.6	-	-	68	127.0	146.7

<sup>1</sup> Smaller value is applicable when selecting reduced NPT entry option.

<sup>2</sup> Sizes Os and O are available with an M16 thread size. For O size with M16 thread, the maximum cable outer sheath diameter is 10.9mm.

### **General Information**

Os - F size metric entry threads are 1.5mm pitch as standard. For G size glands and above, a 2mm pitch is supplied as standard. (1.5mm pitch with 15mm length of thread can be supplied) please specify when ordering.

Thread length is 15mm for sizes Os to F and 20mm for sizes G to J. All dimensions in millimetres (except\* where dimensions are in inches). Assembly instruction data sheet No. A.I. 306.

Accessories including locknuts, sealing washers, serrated washers, earth tags, shrouds, adaptors and reducers available. See pages 53 - 57.

### **Materials & Finishes**

The 501/423 cable gland is manufactured in brass (standard), nickel plated brass, 316 stainless steel or aluminium. Brass NPT entries are nickel plated as standard.

### brass INFT entries are nicker plated as standard

### Cable Gland Ordering Examples Cable Gland Type/Size/Thread

e.g. 501/423/C/M32 501/423/C/1½" NPT

### Cable Gland with Alternative Seal (S)

e.g. 501/423/C/M32/S 501/423/C/11/4" NPT/S

# Cable Gland Type 501/423 MATEX (Ex) (E Flameproof and Increased Safety

### Application

- Outdoor or Indoor use.
- For use with non-armoured elastomer and plastic insulated cables.
- May be used on cables incorporating inner and outer cable sheaths.
- See technical section of catalogue for installation rules and regulations.

### **Features**

- Provides a cable retention seal onto the cables outer sheath at two independent sealing points.
- When used in increased safety applications, this cable gland may be used with braided cable where the braid and the cables outer sheath pass into the enclosure.

The braid must be suitably terminated inside the enclosure.

- Flameproof Exd and Increased Safety Exe. 🐼 II 2 GD
- Baseefa 06ATEX0056X.
- IECEx BAS06.0013X.
- Suitable for use in Zone 1, Zone 2, Zone 21 and Zone 22.
- Suitable for use in Gas Groups IIA, IIB and IIC.
- Construction and test standards EN 50014, EN 50018, EN 50019 and EN 50281-1-1. IEC 60079-0, IEC 60079-1 and IEC 60079-7.
- IP66, IP67 and IP68 (30 metres for 7 days) ingress protection to IEC 60529, EN 60529 and NEMA 4X.
- DTS01 deluge protection certified by ITS. Additional deluge protection seal also available.
- Operating temperature range -60°C to +100°C as standard.
- Alternative Certification Options Available.
- 🚺 🚯 Exd IIC/Exe II.
- 🚫 CVCEPEL BR-Exd IIC/Exe II.
- AUS-Exd IIC/Exe II.
- 🚨 Marine Approval.





# Cable Gland Type 501/453/Universal

501/453/Universal Cable Gland

Flameproof and Increased Safety

		C	ABL	E GLA	ND S	SELEC	<b>IOIT</b>	<b>NTAB</b>	LE		
	Entry Thread Size Size			Cable Acceptance Details							agon
Size			Inne	Inner Sheath		Outer Sheath		C' r/Braid	'G'	Dime	Dimensions
Ref.	Martin	NPT*		A		D				Across	Across
	Metric	Std./ Option	Min.	Max.	Max. Min.		Orientation I	Orientation 2		Flats	Corner
Os	M20 <sup>2</sup>	1/2"	3.0	8.1	5.5	12.0	0.9/1.25	0/0.7	64.4	24.0	27.7
0	M20 <sup>2</sup>	1/2"	6.5	11.9	9.5	16.0	0.9/1.25	0/0.7	64.4	24.0	27.7
Α	M20	3/4"/1/2"	8.4	14.3	12.5	20.5	0.9/1.25	0/0.7	65.4	30.0	34.6
В	M25	"/3/4"	11.1	20.2	16.9	26.0	1.25/1.6	0/0.7	71	36.0	41.6
С	M32	1/4"/ "	17.6	26.5	22.0	33.0	1.6/2.0	0/0.7	76	46.0	53.I
C2	M40	1⁄2"/   1⁄4"	23.I	32.5	28.0	41.0	1.6/2.0	0/0.7	78.I	55.0	63.5
D	M50	2"/1½"	28.9	44.4/42.3 <sup>1</sup>	36.0	52.6	1.8/2.5	0/1.0	93.I	65.0	75.I
Е	M63	21⁄2"/2"	39.9 56.3/54.3 <sup>1</sup>		46.0	65.3	1.8/2.5	0/1.0	99	80.0	92.4
F	M75	3"/21/2"	50.5	68.2/65.3 <sup>1</sup>	57.0	78.0	1.8/2.5	0/1.0	101.9	95.0	109.6

Large	arger cable glands available in 501/453 design with a compression type inner seal.										
G	M80	31⁄2"	67.0	73.0	75.0	89.5	#	#	90.6	106.4	123.0
Н	M90	31/2"	67.0	77.6	75.0	89.5	#	#	90.6	115.0	132.8
J	M100	4"	75.0	91.6	88.0	104.5	#	#	90.6	127.0	146.7

<sup>1</sup>Smaller value is applicable when selecting reduced NPT entry option.

<sup>2</sup>Sizes Os and O are available with an M16 thread size. For O size with M16 thread, the maximum cable inner sheath diameter is 10.9mm.

# Dedicated armour clamping rings are fitted. Please specify armour type and size when ordering.

### **General Information**

Os - F size metric entry threads are 1.5mm pitch as standard.

For G size glands and above, a 2mm pitch is supplied as standard.

(1.5mm pitch with 15mm length of thread can be supplied) please specify when ordering. Thread length is 15mm for sizes Os to F and

20mm for sizes G to J.

All dimensions in millimetres

(except\* where dimensions are in inches).

Assembly instruction data sheet No. A.I. 300 for sizes Os to F.

Assembly instruction data sheet No. A.I. 303 for sizes G to J.

Accessories including locknuts, sealing washers, serrated washers, earth tags, shrouds, adaptors and reducers available. See pages 53 - 57.

### Materials & Finishes

The 501/453/Universal cable gland is manufactured in brass (standard), nickel plated brass, 316 stainless steel or aluminium. Brass NPT entries are nickel plated as standard.

### Cable Gland Ordering Examples Cable Gland Type/Size/Thread

Cable Gland Type/Size/Threa

e.g. 501/453/UNIV/C/M32 501/453/UNIV/C/11/4" NPT Cable Gland with Alternative Clamping Ring (AR)

Alternative Reversible Armour

Orientation I

0.8 - 1.0

0.8 - 1.0

0.9 - 1.25

1.2 - 1.6

12-16

1.45 - 1.8

1.45 - 1.8

1.45 - 1.8

**SELECTION TABLE** 

Steel Wire Armour/Braid/Tape

Orientation 2

0.4 - 0.8

0.4 - 0.8

0.5 - 0.9

0.6 - 1.2

06 - 12

1.0 - 1.45

1.0 - 1.45

1.0 - 1.45

Clamping Rings (RAC)

Size

Ref.

O/Os

А

В

C C2

D

Е

F

e.g. 501/453/UNIV/C/M32/AR 501/453/UNIV/C/1<sup>1</sup>/4" NPT/AR

### Application

- Outdoor or Indoor use.
- For use with single wire armoured 'W', wire braided 'X' and steel tape armoured 'Z', elastomer and plastic insulated cables.
- For particular use with :-Cables that exhibit
- "Cold Flow" characteristics.See technical section of catalogue for installation rules and regulations.

### Features

• Provides armour clamping using one clamping arrangement for all armour/braid types.

 Provides a diaphragm seal on the cables inner sheath which will not damage cable that has "Cold Flow" characteristics.

- Provides an outer deluge seal to prevent moisture ingress to the cable armour/braid.
- Provides a cable retention and low smoke and fume, zero halogen seal onto the cables outer sheath.

- Baseefa 06ATEX0057X for sizes Os to F.
- IECEx BAS06.0014X for sizes Os to F.
- Baseefa 06ATEX0056X for sizes G to J.
- IECEx BAS06.0013X for sizes G to J.
- Suitable for use in Zone 1, Zone 2, Zone 21 and Zone 22.
- Suitable for use in Gas Groups IIA, IIBand IIC.
- Construction and test standards EN 50014, EN 50018, EN 50019 and EN 50281-1-1. IEC 60079-0, IEC 60079-1 and IEC 60079-7.
- IP66, IP67 and IP68 (30 metres for 7 days) ingress protection to IEC 60529, EN 60529 and NEMA 4X.
- DTS01 deluge protection certified by ITS.
- Operating temperature range -60°C to +80°C as standard.
- Alternative Certification Options Available.
  - 🚺 🚯 Exd IIC/Exe II.
  - 🚫 Cv cepel
  - GOST R-Exd IICU/Exe IIU.
  - Approved for use in Kazakhstan.
  - AUS-Exd IIC/Exe II.
  - Marine Approval.





# Cable Gland Type 501/453/RAC 🎬 ATEX 🐼 🤆

Flameproof and Increased Safety

		CA	BL	E GLA	NC	) SE	LE	СТ	IONT	ABLE			
	Entry	Throad		Cable Acceptance Details								Hoveren	
5:	Size Size	Size		Inner Shea	th 'A		Ou	ter	'C'			Dimensions	
Ref		NIDTY	S	tandard	Alter	native	She	ath	Armou	r/Braid	'G'		
	Motric	NP1*		Seal	Sea	I (S)	'	B'				Across	Across
	i leule	Option	Min.	Max.	Min.	Max.	Min.	Max.	Orientation I	1 Orientation		Flats	Corner
Os	M20 <sup>2</sup>	1/2"	3.0	8.0	-	-	5.5	12.0	0.9/1.25	0/0.7	65.I	24.0	27.7
0	M20 <sup>2</sup>	1/2"	6.5	11.9	-	-	9.5	16.0	0.9/1.25	0/0.7	65.I	24.0	27.7
Α	M20	3/4"/1/2"	10.0	14.3	8.5	13.4	12.5	20.5	0.9/1.25	0/0.7	66. I	30.0	34.6
В	M25	"/³⁄4"	12.5	20.2	9.5	15.4	16.9	26.0	1.25/1.6	0/0.7	71.4	36.0	41.6
С	M32	1/4"/ "	19.0	26.5	14.5	21.2	22.0	33.0	1.6/2.0	0/0.7	75.2	46.0	53.I
C2	M40	1⁄2"/   1⁄4"	25.0	32.5	22.0	28.0	28.0	41.0	1.6/2.0	0/0.7	77.I	55.0	63.5
D	M50	2"/1½"	31.5	44.4/42.3 <sup>1</sup>	27.5	34.8	36.0	52.6	1.8/2.5	0/1.0	90.3	65.0	75.I
E	M63	21⁄2"/2"	42.5	56.3/54.3 <sup>ı</sup>	39.0	46.5	46.0	65.3	1.8/2.5	0/1.0	96.7	80.0	92.4
F	M75	3"/21/2"	54.5	68.2/65.3 <sup>1</sup>	48.5	58.3	57.0	78.0	1.8/2.5	0/1.0	96	95.0	109.6
L		1 .				I	I	1	1	1			1

Larger cable glands available in 501/453 design.

		0											
G	M80	31⁄2"	67.0	73.0	-	-	75.0	89.5	#	#	95.6	106.4	123.0
Н	M90	31/2"	67.0	77.6	-	-	75.0	89.5	#	#	95.6	115.0	132.8
J	MI00	4"	75.0	91.6	-	-	88.0	104.5	#	#	95.6	127.0	146.7

<sup>1</sup>Smaller value is applicable when selecting reduced NPT entry option.

<sup>2</sup>Sizes Os and O are available with an M16 thread size. For O size with M16 thread,

the maximum cable inner sheath diameter is 10.9mm.

<sup>3</sup> This cable gland type is also available for use with lead sheath cables - 501/453/RAC/L. Contact Hawke sales for more information.

<sup>4</sup>Deluge protection option available.

# Dedicated armour clamping rings are fitted. Please specify armour type and size when ordering.

### **General Information**

Os - F size metric entry threads are 1.5mm pitch as standard.

For G size glands and above, a 2mm pitch is supplied as standard.

(1.5mm pitch with 15mm length of thread can

- be supplied) please specify when ordering.
- Thread length is 15mm for sizes Os to F and
- 20mm for sizes G to J.

All dimensions in millimetres

(except\* where dimensions are in inches).

Assembly instruction data sheet No. A.I. 302.

Accessories including locknuts, sealing washers, serrated washers, earth tags, shrouds, adaptors and reducers available. See pages 53 - 57.

### **Materials & Finishes**

The 501/453/RAC cable gland is manufactured in brass (standard), nickel plated brass, 316 stainless steel or aluminium. Brass NPT entries are nickel plated as standard.

### **Cable Gland Ordering Examples** Cable Gland Type/Size/Thread

e.g. 501/453/RAC/C/M32 501/453/RAC/C/11/4" NPT

### Cable Gland with Alternative Seal (S)

e.g. 501/453/RAC/C/M32/S 501/453/RAC/C/11/4" NPT/S

### Alternative Reversible Armour

Clamping Rings (RAC)

SELECTION TABLE										
Size	Steel Wire Armour/Braid/Tape									
Ref.	Orientation I	Orientation 2								
O/Os	0.8 - 1.0	0.4 - 0.8								
Α	0.8 - 1.0	0.4 - 0.8								
В	0.9 - 1.25	0.5 - 0.9								
С	1.2 - 1.6	0.6 - 1.2								
C2	1.2 - 1.6	0.6 - 1.2								
D	1.45 - 1.8	1.0 - 1.45								
E	1.45 - 1.8	1.0 - 1.45								
F	1.45 - 1.8	1.0 - 1.45								

### Application

- Outdoor or Indoor use.
- For use with single wire armoured 'W', wire braided 'X' and steel tape armoured 'Z', elastomer and plastic insulated cables.
- See technical section of catalogue for installation rules and regulations.

### **Features**

- Provides armour clamping using one clamping arrangement for all armour/ braid types.
- Provides a seal on the cables inner sheath.
- Provides a cable retention and low smoke and fume, zero halogen seal onto the cables outer sheath.

### **Technical Data**

- Flameproof Exd and Increased Safety Exe. 🐼 II 2 GD
- Baseefa 06ATEX0056X.
- IECEx BAS06.0013X.
- Suitable for use in Zone I, Zone 2, Zone 21 and Zone 22.
- Suitable for use in Gas Groups IIA. IIB and IIC.
- Construction and test standards EN 50014, EN 50018, EN 50019 and EN 50281-1-1. IEC 60079-0, IEC 60079-1 and IEC 60079-7.
- IP66, IP67 and IP68 (30 metres for 7 days) ingress protection to IEC 60529, EN 60529 and NEMA 4X.
- DTS01 deluge protection certified by ITS.
- Operating temperature range -60°C to +80°C as standard.
- Alternative Certification Options Available.
- 🚺 🚯 Exd IIC/Exe II.
- CVCEPEL
- **P**GOST R-Exd IICU/Exe IIU.
- Approved for use in Kazakhstan.
- AUS-Exd IIC/Exe II.
- Marine Approval.

**Cable Gland with Alternative** 

501/453/RAC/C/11/4" NPT/AR

e.g. 501/453/RAC/C/M32/AR

Clamping Ring (AR)





### Cable Gland Type 501/453/RAC/L For Lead Sheath Cables

Flameproof and Increased Safety

		(	CA	BLE GI		ID S	ELI	ECT	ΓΙΟΝ	TABL	E.		
	Entry	Throad		C	Cable A	Accept	ance D	Details	S				
<u>c</u> .	Size Size		Inr	ner Lead Sl	heath	ieath 'A' Oute			יכ			Hexagon	
Size	`		Sta	ndard (L)	Alter	native	She	ath	Armou	r/Braid	'G'	Dimensions	
Kei.	Motric	NPT*	Se	al+Bond	Seal+	Bond	''	B'				Across	Across
	rieuric	Option	Min.	Max.	Min.	Max.	Min.	Max.	Orientation I	Orientation 2		Flats	Corner
0	M20 <sup>2</sup>	1/2"	6.5	10.5	4.0	8.0	9.5	16.0	0.9/1.25	0/0.7	65.I	24.0	27.7
Α	M20	3/4"/1/2"	-	-	8.5	13.0	12.5	20.5	0.9/1.25	0/0.7	66. I	30.0	34.6
В	M25	"/³/4"	12.5	19.0	9.5	15.4	16.9	26.0	1.25/1.6	0/0.7	71.4	36.0	41.6
С	M32	11⁄4"/1"	19.0	25.0	14.5	21.2	22.0	33.0	1.6/2.0	0/0.7	75.2	46.0	53.I
C2	M40	1⁄2"/   1⁄4"	25.0	31.2	22.0	28.0	28.0	41.0	1.6/2.0	0/0.7	77.1	55.0	63.5
D	M50	2"/1½"	31.5	42.3/42.8 <sup>1</sup>	27.5	34.8	36.0	52.6	1.8/2.5	0/1.0	90.3	65.0	75.1
E	M63	21⁄2"/2"	42.5	53.3/54.5 <sup>1</sup>	39.0	46.5	46.0	65.3	1.8/2.5	0/1.0	96.7	80.0	92.4
F	M75	3"/21/2"	54.5	66.0/64.3 <sup>1</sup>	48.5	58.3	57.0	78.0	1.8/2.5	0/1.0	96	95.0	109.6
-													

### Larger cable glands available in 501/453/L design. G | M80 31/2" 67.0 70.0 75.0 89.5 # # 95.6 106.4 123.0 H M90 # # 95.6 115.0 132.8 31/2" 67.0 75.0 75.0 89.5 --75.0 89.5 J M100 4" \_ \_ 88.0 104.5 # # 95.6 127.0 146.7

<sup>2</sup>Sizes Os and O are available with an M16 thread size. For O size with M16 thread,

, the maximum cable inner sheath diameter is 10.9mm.

<sup>4</sup>Deluge protection option available.

# Dedicated armour clamping rings are fitted. Please specify armour type and size when ordering.

### **General Information**

Os - F size metric entry threads are 1.5mm pitch as standard.

For G size glands and above, a 2mm pitch is supplied as standard.

(1.5mm pitch with 15mm length of thread can be supplied) please specify when ordering.

Thread length is 15mm for sizes O to F and 20mm for sizes G to J.

All dimensions in millimetres

(except\* where dimensions are in inches). Assembly instruction data sheet No. A.I. 302 + 336

for sizes Os to F. Assembly instruction data sheet No. A.I. 303 + 336

for sizes G to J.

Accessories including locknuts, sealing washers, serrated washers, earth tags, shrouds, adaptors and reducers available. See pages 53 - 57.

### Materials & Finishes

The 501/453/RAC/L cable gland is manufactured in brass(standard), nickel plated brass, 316 stainless steel or aluminium.

Brass NPT entries are nickel plated as standard.

### Cable Gland Ordering Examples

Cable Gland Type/Size/Thread/ Standard Inner Seal + Bond

e.g. 501/453/RAC/C/M32/L 501/453/RAC/C/11/4" NPT/L

### Cable Gland with Alternative Inner Seal + Bond

e.g. 501/453/RAC/C/M32/K 501/453/RAC/C/1½" NPT/K Cable Gland with Alternative Clamping Ring (AR)

Alternative Reversible Armour

Orientation I

0.8 - 1.0

0.8 - 1.0

0.9 - 1.25

1.2 - 1.6

1.2 - 1.6

1.45 - 1.8

1.45 - 1.8

1.45 - 1.8

**SELECTION TABLE** 

Steel Wire Armour/Braid/Tape

Orientation 2

04-08

0.4 - 0.8

0.5 - 0.9

0.6 - 1.2

0.6 - 1.2

1.0 - 1.45

1.0 - 1.45

1.0 - 1.45

Clamping Rings (RAC)

Size

Ref

O/Os

А

В

С

C2

D

e.g. 501/453/RAC/C/M32/L/AR 501/453/RAC/C/1<sup>1</sup>/4" NPT/L/AR

### Application

- Outdoor or Indoor use.
- For use with single wire armoured 'W' wire braided 'X' and steel tape armoured 'Z', elastomer and plastic insulated cables with a lead inner sheath.
- See technical section of catalogue for installation rules and regulations.

### Features

• Provides armour clamping using one clamping arrangement for all armour /braid types. 501/453/RAC/L Cable Gland

- Provides a seal and an electrical bond on the cables lead inner sheath.
- Provides a cable retention and low smoke and fume, zero halogen seal onto the cables outer sheath.

- Flameproof Exd and Increased Safety Exe. 🐼 II 2 GD
- Baseefa 06ATEX0056X.
- IECEx BAS06.0013X.
- Suitable for use in Zone 1, Zone 2, Zone 21 and Zone 22.
- Suitable for use in Gas Groups IIA, IIB and IIC.
- Construction and test standards EN 50014, EN 50018, EN 50019 and EN 50281-1-1.
   IEC 60079-0, IEC 60079-1 and IEC 60079-7.
- IP66, IP67 and IP68 (30 metres for 7 days) ingress protection to IEC 60529, EN 60529 and NEMA 4X.
- DTS01 deluge protection certified by ITS.
- Operating temperature range -60°C to +80°C as standard.
- Alternative Certification Options Available.
  - 🚺 🚯 Exd IIC/Exe II.
  - CV C E P E L BR-Exd IIC/Exe II.
  - GOST R-Exd IICU/Exe IIU.
  - Approved for use in Kazakhstan.
  - Marine Approval.





	C	ABLE	GLA	ND S	SELEC	TION	ΤΑΙ	BLE	
	Entry	Throad	Ca	ible Acce		Havagan			
Size	S	Size		Sheath	'C Armoui	; r/Braid	'G'	Dimensions	
Ref.	M	NPT*		.B.				Across	Across
	Metric	Std./ Option	Min.	Max.	Orientation I	Orientation 2		Flats	Corners
Α	M20	3/4"/1/2"	12.5	20.5	0.9/1.25	0/0.7	61.1	30.0	34.6
В	M25	"/3/4"	16.9	26.0	1.25/1.6	0/0.7	66.4	36.0	41.6
С	M32	1/4"/ "	22.0	33.0	1.6/2.0	0/0.7	70.2	46.0	53.I

CABLE	GLAND	SIZE FOR	CORE SIZ	E & NUMBER
CADLL	OLAI V		CONE DIL	

Maximum No	Cores Cross Sectional Area mm <sup>2</sup>										
of Cores	1.5	2.5	4.0	6.0	10.0						
7	A & B	A & B	B & C	С	С						
4	-	-	-	В	-						
3	-	-	-	-	В						

	PUN	СН	FOOL	SIZE D	ETA	ILS	
Punch Ref.		No. I			No.3		
Core C.S.A. mm <sup>2</sup>	1.5	-	2.5	4.0	-	6.0	10.0

<sup>4</sup>Deluge protection option available.

### **General Information**

A - C size metric entry threads are 1.5mm pitch as standard. (1.5mm pitch with 15mm length of thread can be supplied) please specify when ordering.

Thread length is 15mm for sizes A to C.

All dimensions in millimetres (except\* where dimensions are in inches). Assembly instruction data sheet No. A.I. 312.

Accessories including locknuts, sealing washers, serrated washers, earth tags, shrouds, adaptors and reducers available. See pages 53 - 57.

### **Materials & Finishes**

The PSG 553/RAC cable gland is manufactured in brass (standard), nickel plated brass, 316 stainless steel or aluminium. Brass NPT entries are nickel plated as standard.

### Cable Gland Ordering Examples Cable Gland Type/Size/Thread

e.g. PSG 553/RAC/C/M32 PSG 553/RAC/C/I<sup>1</sup>/4" NPT

### Punch Tool Ordering Example

e.g. Punch Tool Number 1.

### Application

- Outdoor or Indoor use.
- For use with single wire armoured 'W', wire braided 'X' and steel tape armoured 'Z', elastomer and plastic insulated cables.

Flameproof and Increased Safety

Cable Gland Type

**PSG 553/RAC** 

🎬 ATEX 🐼 🤆

### For particular use with :-

- a) Cables that are not effectively filled, compact and/or circular, have tape bedding or have hygroscopic fillers.
- b) Cables that exhibit "Cold Flow" characteristics.
- c) Enclosures for gas group IIC, under 2 litres in volume and containing an ignition source.
- d) Enclosures for gas groups IIA or IIB, which are greater than 2 litres in volume and contain an ignition source.
   See technical section of the catalogue
- for installation rules and regulations.

### Features

- Provides a barrier seal to the individual insulated cores within the cable and prevents entry of the products of an explosion into the cable.
- The required number of holes for the cores are punched in the seal by means of a special tool to suit the core size.
- Provides armour clamping using one clamping arrangement for all armour/ braid types.
- Provides a cable retention and low smoke and fume, zero halogen seal onto the cables outer sheath.

- Baseefa 06ATEX0056X.
- IECEx BAS06.0013X.
- Suitable for use in Zone 1, Zone 2, Zone 21 and Zone 22.
- Suitable for use in Gas Groups IIA, IIB and IIC.
- Construction and test standards EN 50014, EN 50018, EN 50019 and EN 50281-1-1. IEC 60079-0, IEC 60079-1 and IEC 60079-7.
- IP66, IP67 and IP68 (30 metres for 7 days) ingress protection to IEC 60529 and EN 60529.
- Operating temperature range -60°C to +80°C as standard.





# Cable Gland Type ICG 623

Flameproof and Increased Safety

		CA	BLE	GLAN	<b>ND</b>	SEL	ECT	101	<b>I TA</b>	BLE		
	Entry	Throad		Cabl	e Acc	eptanc	e Deta	ils			Hovagon	
C:	Size Size		lr	ner Sheat	Outer Sheath 'B'							
Size				Cores		Stan	dard	Alteri	native	'G'		
Ref.	Martin	NPT*	Max.	'E' Max.	Max. No.	Se	eal	Seal	(S)		Across	Across
	Metric	Std./ Option	Over Cores	Inner Sheath	Of Cores	Min.	Max.	Min.	Max.		Flats	Corners
Os	M20	1/2"	8.0	8.0	6	3.0	8.0	-	-	57.5	24.0	27.7
0	M20	1/2"	8.9	10.0	6	7.5	11.9	-	-	57.5	24.0	27.7
Α	M20	3/4"/1/2"	11.0	12.5	10	11.0	14.3	8.5	13.4	56.3	30.0	34.6
В	M25	"/ <sup>3</sup> /4"	16.2	18.4	21	13.0	20.2	9.5	15.4	58.9	36.0	41.6
С	M32	1/4"/ "	21.9	24.7	42	19.0	26.5	15.5	21.2	61.7	46.0	53.I
C2	M40	1⁄2"/   1⁄4"	26.3	29.7	60	25.0	32.5	22.0	28.0	62.6	55.0	63.5
D	M50	2"/1½"	37.I	41.7	80	31.5	44.4	27.5	34.8	72.8	65.0	75.I
E	M63	21⁄2"/2"	47.8	53.5	100	42.5	56.3	39.0	46.5	75.7	80.0	92.4
F	M75	3"/21/2"	59.0	66.2/65.3 <sup>I</sup>	120	54.5	68.2	48.5	58.3	77.7	95.0	109.6

<sup>1</sup>Smaller value is applicable when selecting reduced NPT entry option.

### **General Information**

Os - F size metric entry threads are 1.5mm pitch as standard. (1.5mm pitch with 15mm length of thread can be supplied) please specify when ordering.

Thread length is 15mm for sizes Os to F.

All dimensions in millimetres (except\* where dimensions are in inches). Two part sealing compound and assembly instructions are supplied with the cable gland.

Assembly instruction data sheet No. A.I. 305.

Accessories including locknuts, sealing washers, serrated washers, earth tags, shrouds, adaptors and reducers available. See pages 53 - 57.

### **Materials & Finishes**

The ICG 623 cable gland is manufactured in brass(standard), nickel plated brass, 316 stainless steel or aluminium. Brass NPT entries are nickel plated as standard.

### Cable Gland Ordering Examples

Cable Gland Type/Size/Thread

e.g. ICG 623/C/M32 ICG 623/C/11/4" NPT

### Cable Gland with Alternative Seal (S)

e.g. ICG 623/C/M32/S ICG 623/C/11/4" NPT/S

### Application

- Outdoor or Indoor use.
- For use with non-armoured elastomer and plastic insulated cables.

### For particular use with :-

- a) Cables that are not effectively filled, compact and/or circular, have tape bedding or have hygroscopic fillers.
- b) Cables that exhibit "Cold Flow" characteristics.
- c) Enclosures containing an ignition source in gas group II C areas or containing an ignition source in a Zone I area and exceeding 2 litres in volume.
- See technical section of the catalogue for installation rules and regulations.

### **Features**

- Provides a barrier seal between the individual insulated cores within the cable and prevents entry of the products of an explosion into the cable.
- Assembly of the cable gland compresses and distributes the compound evenly to create a barrier seal at the point of entry into the enclosure.
- The compound chamber may be seperated from the cured compound to ensure that the chamber has been effectively filled. If required, external voids can be repaired.
- Provides a cable retention seal onto the cables outer sheath.

- Flameproof Exd and Increased Safety Exe.
   II 2 GD
- Baseefa 06ATEX0058X. IECEx BAS06.0015X.
- Suitable for use in Zone 1, Zone 2, Zone 21 and Zone 22.
- Suitable for use in Gas Groups IIA, IIB and IIC.
- Construction and test standards EN 50014, EN 50018, EN 50019 and EN 50281-1-1. IEC 60079-0, IEC 60079-1 and IEC 60079-7.
- IP66, IP67 and IP68 (30 metres for 7 days) ingress protection to IEC 60529, EN 60529 and NEMA 4X.
- DTS01 deluge protection certified by ITS.
- Operating temperature range -60°C to +80°C as standard.
- Alternative Certification Options Available.
  - 🚺 🚯 Exd IIC/Exe II.
  - 💽 🗘 C E P E L BR-Exd IIC/Exe II.
  - AUS-Exd IIC/Exe II.
  - Marine Approval.





# Cable Gland Type ICG 653/Universal

Flameproof and Increased Safety

		CA	BL	E GLA	N	) SE	ELEC	стю	N TAB	LE		
	Entro	Thread			Cabl	e Acce	ptance	Details				
Size		Size	Inner Sheath/ Cores			Oi She	uter eath	'C' Armour/Braid		'G'	Dimensions	
INCEI.		NPT*	'D' Max.	'E' Max	Max.	· ·	В'				Across	Across
	Metric	Std./ Option	Over Cores	Inner Sheath	Of Cores	Min.	Max.	Orientation I	Orientation 2		Flats	Corners
Os	M20	1/2"	8.9	10.0	6	5.5	12.0	0.9/1.25	0/0.7	72.8	24.0	27.7
0	M20	1/2"	8.9	10.0	6	9.5	16.0	0.9/1.25	0/0.7	72.8	24.0	27.7
А	M20	3/4"/1/2"	11.0	12.5	10	12.5	20.5	0.9/1.25	0/0.7	73.8	30.0	34.6
В	M25	"/3/4"	16.2	18.4	21	16.9	26.0	1.25/1.6	0/0.7	78.I	36.0	41.6
С	M32	1⁄4"/ "	21.9	24.7	42	22.0	33.0	1.6/2.0	0/0.7	83.0	46.0	53.I
C2	M40	1⁄2"/   1⁄4"	26.3	29.7	60	28.0	41.0	1.6/2.0	0/0.7	84. I	55.0	63.5
D	M50	2"/1½"	37.I	41.7	80	36.0	52.6	1.8/2.5	0/1.0	91.3	65.0	75.I
E	M63	21/2"/2"	47.8	53.3	100	46.0	65.3	1.8/2.5	0/1.0	101.8	80.0	92.4
F	M75	3"/21/2"	59.0	66.2/65.3 <sup>1</sup>	120	57.0	78.0	1.8/2.5	0/1.0	101.2	95.0	109.6

<sup>1</sup>Smaller value is applicable when selecting reduced NPT entry option.

### **General Information**

Os - F size metric entry threads are 1.5mm pitch as standard.

(1.5mm pitch with 15mm length of thread can be supplied) please specify when ordering. Thread length is 15mm for sizes Os to F. All dimensions in millimetres (except\* where dimensions are in inches).

Two part sealing compound and assembly instructions are supplied with the cable gland. Assembly instruction data sheet No. A.I. 301.

Accessories including locknuts, sealing washers, serrated washers, earth tags, shrouds, adaptors and reducers available. See pages 53 - 57.

### **Materials & Finishes**

The ICG 653/Universal cable gland is manufactured in brass (standard), nickel plated brass, 316 stainless steel or aluminium. Brass NPT entries are nickel plated as standard.

### Cable Gland Ordering Examples Cable Gland Type/Size/Thread

e.g. ICG 653/UNIV/C/M32 ICG 653/UNIV/C/1½" NPT

### Cable Gland with Alternative Clamping Ring (AR)

e.g. ICG 653/UNIV/C/M32/AR ICG 653/UNIV/C/11/4" NPT/AR

### Alternative Reversible Armour Clamping Rings (RAC)

	SELECTION TABLE											
Size	Steel Wire Armour/Braid/Tape											
Ref.	Orientation I	Orientation 2										
O/Os	0.8 - 1.0	0.4 - 0.8										
Α	0.8 - 1.0	0.4 - 0.8										
В	0.9 - 1.25	0.5 - 0.9										
С	1.2 - 1.6	0.6 - 1.2										
C2	1.2 - 1.6	0.6 - 1.2										
D	1.45 - 1.8	1.0 - 1.45										
E	1.45 - 1.8	1.0 - 1.45										
F	145-18	10-145										

18

### Application

- Outdoor or Indoor use.
- For use with single wire armoured 'W', wire braided 'X' and steel tape armoured 'Z', elastomer and plastic insulated cables.

### For particular use with :-

- a) Cables that are not effectively filled, compact and/or circular, have tape bedding or have hygroscopic fillers.
- b) Cables that exhibit "Cold Flow" characteristics.
- c) Enclosures containing an ignition source in gas group II C areas or containing an ignition source in a Zone I area.
- See technical section of the catalogue for installation rules and regulations.

### Features

- Provides a barrier seal between the individual insulated cores within the cable and prevents entry of the products of an explosion into the cable.
- Assembly of the cable gland compresses and distributes the compound evenly to create a barrier seal at the point of entry into the enclosure.
- The compound chamber may be seperated from the cured compound to ensure that the chamber has been effectively filled. If required, external voids can be repaired.
- Provides armour clamping, using one clamping arrangement for all armour/braid types.
- Provides an outer deluge seal to prevent moisture ingress to the cable armour/braid.
- Provides a cable retention and low smoke and fume, zero halogen seal onto the cables outer sheath.

### **Technical Data**

- Flameproof Exd and Increased Safety Exe. 🐼 II 2 GD
- Baseefa 06ATEX0058X. IECEx BAS06.0015X.
- Suitable for use in Zone 1, Zone 2, Zone 21 and Zone 22.
- Suitable for use in Gas Groups IIA, IIB and IIC.
   Construction and test standards EN 50014, EN 50019 EN 50019 and EN 50014.
- EN 50018, EN 50019 and EN 50281-1-1. IEC 60079-0, IEC 60079-1 and IEC 60079-7.
- IP66, IP67 and IP68 (30 metres for 7 days) ingress protection to IEC 60529, EN 60529 and NEMA 4X.
- DTS01 deluge protection certified by ITS.
  - Operating temperature range -60°C to +80°C as standard.
  - Alternative Certification Options Available.
  - 🚺 🚯 Exd IIC/Exe II.
  - 🚫 CKCEPEL BR-Exd IIC/Exe II.
  - 🔤 📴 GOST R-Exd IICU/Exe IIU.

HAWKE

HWK69 June '07

- AUS-Exd IIC/Exe II.
- 🌆 Marine Approval.

ICG 653/Universal Cable Gland



		CAE	BLE	GL		ID	SE	LEC	<b>IOIT</b>	N TAB	BLE		
	Entro	Thread			Ca	ble A	ccept	ance	Details			Llas	
Size	Size		Inner Sheath/			n/	Outer		'C	2		Dimensions	
Ref.	Matric	NPT*	'D' Max.	 	E' Max.	Max. No.	- SHE	B'	Armou	r/Braid	'G'	Across	Across
	rieuric	Option	Over Cores	Inner Sheath	Inner Sheath	Of Cores	Min.	Max.	Orientation I	Orientation 2		Flats	Corners
Os	M20	1/2"	8.5	4.0	10.0	6	5.5	12.0	0.9/1.25	0/0.7	72.8	24.0	27.7
0	M20	1/2"	8.5	4.0	10.0	6	9.5	16.0	0.9/1.25	0/0.7	72.8	24.0	27.7
Α	M20	3/4"/1/2"	10.8	7.4	12.5	10	12.5	20.5	0.9/1.25	0/0.7	73.8	30.0	34.6
В	M25	"/3/4"	16.2	11.0	18.4	21	16.9	26.0	1.25/1.6	0/0.7	78.I	36.0	41.6
С	M32	1⁄4"/   "	21.9	14.0	24.7	42	22.0	33.0	1.6/2.0	0/0.7	83.0	46.0	53.I
C2	M40	1⁄2"/   1⁄4"	26.3	21.0	29.7	60	28.0	41.0	1.6/2.0	0/0.7	84. I	55.0	63.5
D	M50	2"/1½"	37.I	27.0	41.7	80	36.0	52.6	1.8/2.5	0/1.0	91.3	65.0	75.I
E	M63	21⁄2"/2"	47.8	39.0	53.3	100	46.0	65.3	1.8/2.5	0/1.0	101.8	80.0	92.4
F	M75	3"/21/2"	59.0	51.0	64.0	120	57.0	78.0	1.8/2.5	0/1.0	101.2	95.0	109.6

### **General Information**

Os - F size metric entry threads are 1.5mm pitch as standard.

(1.5mm pitch with 15mm length of thread can be supplied) please specify when ordering. Thread length is 15mm for sizes Os to F. All dimensions in millimetres (except\* where dimensions are in inches). Two part sealing compound and assembly instructions are supplied with the cable gland. Assembly instruction data sheet

Accessories including locknuts, sealing washers, serrated washers, earth tags, shrouds, adaptors and reducers available. See pages 53 - 57.

### **Materials & Finishes**

No. A.I. 301 + 336.

The ICG 653/Universal/L cable gland is manufactured in brass (standard), nickel plated brass, 316 stainless steel or aluminium. Brass NPT entries are nickel plated as standard.

### Cable Gland Ordering Examples Cable Gland Type/Size/Thread/Bond

e.g. ICG 653/UNIV/C/M32/L ICG 653/UNIV/C/1<sup>1</sup>/4" NPT/L

### Cable Gland with Alternative Clamping Ring (AR)

e.g. ICG 653/UNIV/C/M32/L/AR ICG 653/UNIV/C/1½" NPT/L/AR

### Alternative Reversible Armour Clamping Rings (RAC)

	SELECTION	TABLE							
Size	Steel Wire Armour/Braid/Tape								
Ref. Orientation I		Orientation 2							
O/Os	0.8 - 1.0	0.4 - 0.8							
Α	0.8 - 1.0	0.4 - 0.8							
В	0.9 - 1.25	0.5 - 0.9							
С	1.2 - 1.6	0.6 - 1.2							
C2	1.2 - 1.6	0.6 - 1.2							
D	1.45 - 1.8	1.0 - 1.45							
E	1.45 - 1.8	1.0 - 1.45							
F	1.45 - 1.8	1.0 - 1.45							

### Application

- Outdoor or Indoor use.
- For use with single wire armoured 'W', wire braided 'X' and steel tape armoured 'Z', elastomer and plastic

**Cable Gland Type** 

For Lead Sheath Cables  $ATEX \langle \mathcal{E}x \rangle \langle \mathcal{E} \rangle$ 

ICG 653/Universal/L

Flameproof and Increased Safety

insulated cables with a lead inner sheath. For particular use with :-

- a) Cables that are not effectively filled, compact and/or circular, have tape bedding or have hygroscopic fillers.
   b) Cables that exhibit "Cold Flow"
- characteristics.
- c) Enclosures containing an ignition source in gas group II C areas or containing an ignition source in a Zone I area.
- See technical section of the catalogue for installation rules and regulations.

### Features

- Provides a barrier seal between the individual insulated cores within the cable and prevents entry of the products of an explosion into the cable.
- Assembly of the cable gland compresses and distributes the compound evenly to create a barrier seal at the point of entry into the enclosure.
- The compound chamber may be seperated from the cured compound to ensure that the chamber has been effectively filled. If required, external voids can be repaired.
- Provides armour clamping, using one clamping arrangement for all armour/braid types.
- Provides a seal and an electrical bond on the cables lead inner sheath.
- Provides an outer deluge seal to prevent moisture ingress to the cable armour/braid.
- Provides a cable retention and low smoke and fume, zero halogen seal onto the cables outer sheath.

- Flameproof Exd and Increased Safety Exe. 🐼 II 2 GD
- Baseefa 06ATEX0058X.
   IECEx BAS06.0015X.
- Suitable for use in Zone 1, Zone 2, Zone 21 and Zone 22.
- Suitable for use in Gas Groups IIA, IIB and IIC.
   Construction and test standards EN 50014, EN 50018, EN 50019 and EN 50281-1-1. IEC 60079-0, IEC 60079-1 and IEC 60079-7.
- IP66, IP67 and IP68 (30 metres for 7 days) ingress protection to IEC 60529, EN 60529 and NEMA 4X.
- DTS01 deluge protection certified by ITS.
- Operating temperature range -60°C to +80°C as standard.
- Alternative Certification Options Available.
  - 🚺 🚯 Exd IIC/Exe II.
  - CACEPEL BR-Exd IIC/Exe II.
  - GOST R-Exd IICU/Exe IIU.
  - Marine Approval.





# Cable Gland Type 501/414 Materia ATEX (Ex) (Ce

Flameproof and Increased Safety

		CABL	E GI	LAN	D S	ELECT			BL	Ξ	
	Male	Entry	Fomale	Entry	Cab	le Acceptai	nce De	etails		Llauran	
<b>.</b>	Thread Size		Thread Size		(	Outer Shea		ath 'B'			
Size					St	Standard		native	'G'		
Rei.	Magnia	NPT*	Motric	NPT		Seal	Sea	l (S)		Across	Across
	Metric	Std./ Option	Metric	#	Min.	Max.	Min.	Max.		Flats	Corners
Os	M20 <sup>2</sup>	1/2"	M20	-	3.0	8.0	-	-	69.0	24.0	27.7
0	M20 <sup>2</sup>	1/2"	M20	-	7.5	11.9	-	-	69.0	24.0	27.7
Α	M20	3/4"/1/2"	M20	-	11.0	14.3	8.5	13.4	69.0	30.0	34.6
В	M25	"/3/4"	M25	-	13.0	20.2	9.5	15.4	61.0	36.0	41.6
С	M32	11/4"/1"	M32	-	19.0	26.5	15.5	21.2	77.0	46.0	53.I

<sup>1</sup>Smaller value is applicable when selecting reduced NPT entry option. <sup>2</sup>Sizes Os and O are available with an M16 thread size. For O size with M16 thread, the maximum cable inner sheath diameter is 10.9mm.

# NPT female thread sizes equivalent to those shown in the table for the male thread size are available. Hexagon dimensions as shown may alter.

### **General Information**

Os - C size metric entry threads are 1.5mm pitch as standard. (1.5mm pitch with 15mm length of thread can be supplied) please specify when ordering. Thread length is 15mm for sizes Os to C.

All dimensions in millimetres (except\* where dimensions are in inches). Assembly instruction data sheet No. A.I. 310.

Accessories including locknuts, sealing washers, serrated washers, earth tags, shrouds, adaptors and reducers available. See pages 53 - 57.

### **Materials & Finishes**

The 501/414 cable gland is manufactured in brass (standard), nickel plated brass, 316 stainless steel or aluminium. Brass NPT entries are nickel plated as standard.

### Cable Gland Ordering Examples

Cable Gland Type/Size/MaleThread/ Female Thread

e.g. 501/414/C/M32/M32 501/414/C/1<sup>1</sup>/4" NPT/M32

### Cable Gland with Alternative Seal (S)

e.g. 501/414/C/M32/M32/S 501/414/C/11/4" NPT/M32/S

### Application

- Outdoor or Indoor use.
- For use with non-armoured elastomer and plastic insulated cables installed in conduit.
- See technical section of the catalogue for installation rules and regulations.

### **Features**

- Provides a cable retention seal onto the cables outer sheath.
- When used in increased safety applications, this cable gland may be used with braided cable where the braid and the cables outer sheath pass into the enclosure. The braid must be suitably terminated into the enclosure.
- Provides female running coupler for cable gland or conduit entry.

- Flameproof Exd and Increased Safety Exe. ( ↓ II 2 GD
- Baseefa 06ATEX0056X.
- IECEx BAS06.0013X.
- Suitable for use in Zone 1, Zone 2, Zone 21 and Zone 22.
- Suitable for use in Gas Groups IIA, IIB and IIC.
- Construction and test standards EN 50014, EN 50018, EN 50019 and EN 50281-1-1. IEC 60079-0, IEC 60079-1 and IEC 60079-7.
- IP66, IP67 and IP68 (30 metres for 7 days) ingress protection to IEC 60529 and EN 60529.
- DTS01 deluge protection certified by ITS.
- Operating temperature range -60°C to +100°C as standard.
- Alternative Certification Options Available.
  - 🚺 🚯 Exd IIC/Exe II.
  - 🌆 Marine Approval.





	CAB	LE GLA	ND SI	ELECT		ABLE		
Size	Male Threa	Entry ad Size	Female Threa	e Entry d Size	'G'	Hexagon Dimensions		
Ret.	Metric	NPT* Std./ Option	Metric	NPT #		Across Flats	Across Corners	
А	M20	3/4"/1/2"	M20	-	63.9	30.0	34.6	
В	M25	"/3/4"	M25	-	52.8	36.0	41.6	
C	M32	1/4"/ "	M32	-	69.5	46.0	53.I	

### CABLE GLAND SIZE FOR CORE SIZE & NUMBER

Maximum No	Cores Cross Sectional Area mm <sup>2</sup>										
of Cores	1.5	2.5	4.0	6.0	10.0						
7	A & B	A & B	B & C	С	С						
4	-	-	-	В	-						
3	-	-	-	-	В						

	PUNCH TOOL SIZE DETAILS												
Punch Ref.		No.I			No.2								
Core C.S.A. mm <sup>2</sup>	١.5	-	2.5	4.0	-	6.0	10.0						

# NPT female thread sizes equivalent to those shown in the table for the male thread size are available. Hexagon dimensions as shown may alter.

### **General Information**

A - C size metric entry threads are 1.5mm pitch as standard. (1.5mm pitch with 15mm length of thread can be supplied) please specify when ordering.

Thread length is 15mm for sizes A to C.

All dimensions in millimetres (except\* where dimensions are in inches). Assembly instruction data sheet No. A.I. 309.

Accessories including locknuts, sealing washers, serrated washers, earth tags, shrouds, adaptors and reducers available. See pages 53 - 57.

### Materials & Finishes

The SB 474 cable gland is manufactured in brass (standard), nickel plated brass, 316 stainless steel or aluminium. Brass NPT entries are nickel plated as standard.

Cable Gland Ordering Examples Cable Gland Type/Size/Male Thread/Female Thread

e.g. SB 474/C/M32/M32 SB 474/C/I<sup>1</sup>/4" NPT/M32

Punch Tool Ordering Example

e.g. Punch Tool Number 1.

**Connection Solutions** 

www.ehawke.com

### Application

- Outdoor or Indoor use.
- For particular use with :-
- a) Cables that are not effectively filled, compact and/or circular, have tape bedding or have hygroscopic fillers.
- b) Cables that exhibit "Cold Flow" characteristics.
- c) Enclosures for gas group IIC, under
   2 litres in volume and containing an ignition
- d) Enclosures for gas groups IIA or IIB, which are greater than 2 litres in volume and contain an ignition source.
- See technical section of the catalogue for installation rules and regulations.

### **Features**

- Provides a barrier seal to the individual insulated cores within the cable and prevents entry of the products of an explosion into the cable.
- The required number of holes for the cores are punched in the seal by means of a special tool to suit the core size.
- DTS01 deluge protection certified by ITS.
- Provides female running coupler for cable gland or conduit entry.

- Baseefa 06ATEX0056X.
- IECEx BAS06.0013X.
- Suitable for use in Zone 1, Zone 2, Zone 21 and Zone 22.
- Suitable for use in Gas Groups IIA, IIB and IIC.
- Construction and test standards EN 50014, EN 50018, EN 50019 and EN 50281-1-1. IEC 60079-0, IEC 60079-1 and IEC 60079-7.
- IP66, IP67 and IP68 (30 metres for 7 days) ingress protection to IEC 60529 and EN 60529.
- Operating temperature range -60°C to +80°C as standard.
- Alternative Certification Options Available.
  - Marine Approval.





	(	CABL	E GL	AND S	ELE	СТІ	ON	TAE	BLE	
Size Ref.	Male Thre	e Entry ead Size	Female Entry Thread Size		Inn	Inner Sheath/ Cores			Hexagon Dimensions	
	Metric	NPT* Std./ Option	Metric	NPT #	<b>'D'</b> Max. Over Cores	<b>'E'</b> Max. Inner Sheath	Max. No. Of Cores		Across Flats	Across Corners
Α	M20	3/4"/1/2"	M20	-	11.0	12.5	10	53.5	30.0	34.6
В	M25	"/³⁄4"	M25	-	16.2	18.4	21	53.5	36.0	41.6
С	M32	11/4"/1"	M32	-	21.9	24.7	42	56.0	46.0	53.I
C2	M40	1⁄2"/   1⁄4"	M40	-	26.3	29.7	60	56.0	55.0	63.5
D	M50	2"/1½"	M50	-	37.1	41.7	80	61.4	65.0	75.1
E	M63	21/2"/2"	M63	-	47.8	53.5	100	63.7	80.0	92.4
F	M75	3"/21/2"	M75	-	59.0	66.2	120	65.7	95.0	109.6

# NPT female thread sizes equivalent to those shown in the table for the male thread size are available. Hexagon dimensions as shown may alter.

### **General Information**

A - F size metric entry threads are 1.5mm pitch as standard. Thread length is 15mm for sizes Os to F.

All dimensions in millimetres (except\* where dimensions are in inches). Two part sealing compound and assembly instructions are supplied with the cable gland.

Assembly instruction data sheet No. A.I. 311.

Accessories including locknuts, sealing washers, serrated washers, earth tags, shrouds, adaptors and reducers available. See pages 53 - 57.

### **Materials & Finishes**

The CSB 656 cable gland is manufactured in brass(standard), nickel plated brass, 316 stainless steel or aluminium. Brass NPT entries are nickel plated as standard.

### **Cable Gland Ordering Examples**

Cable Gland Type/Size/Male Thread/Female Thread

e.g. CSB 656/C/M32/M32 CSB 656/C/11/4" NPT/M32

- Alternative Certification Options Available.
  - 🚺 🚯 Exd IIC/Exe II.
  - AUS-Exd IIC/Exe II.
  - 🏭 Marine Approval.

### Application

- Outdoor or Indoor use.
- For use with conduit incorporating individual insulated conductors or For particular use with :-
- For particular use with :-
- a) Cables that are not effectively filled, compact and/or circular, have tape bedding or have hygroscopic fillers.
- b) Cables that exhibit "Cold Flow" characteristics.
- c) Enclosures containing an ignition source in gas group II C areas or containing an ignition source in a Zone I area and exceeding 2 litres in volume.
- See technical section of the catalogue for installation rules and regulations.

### Features

- Provides a barrier seal between the individual insulated cores within the cable and prevents entry of the products of an explosion into the cable or conduit.
- Seals conductors at entry to enclosure via conduit or enables an existing cable gland to be converted to a barrier type cable gland.
- The device is fitted with a simple compound filled chamber which permits packing around individual insulated conductors.
- Assembly of the cable gland compresses and distributes the compound evenly to create a barrier seal at the point of entry into the enclosure.
- The compound chamber may be seperated from the cured compound to ensure that the chamber has been effectively filled.
- If required, external voids can be repaired. Provides female running coupler for cable gland or conduit entry.

### **Technical Data**

- Flameproof Exd and Increased Safety Exe. 🐼 II 2 GD
- Baseefa 06ATEX0058X.
   IECEx BAS06.0015X.
- Suitable for use in Zone 1, Zone 2, Zone 21 and Zone 22.
- Suitable for use in Gas Groups IIA, IIB and IIC.
- Construction and test standards EN 50014, EN 50018, EN 50019 and EN 50281-1-1. IEC 60079-0. IEC 60079-1 and IEC 60079-7.
- IP66, IP67 and IP68 (30 metres for 7 days) ingress protection to IEC 60529, EN 60529 and NEMA 4X.
- DTS01 deluge protection certified by ITS.
- Operating temperature range -60°C to +80°C as standard.



# Cable Gland Type CSB 656 Material CSB 656

Flameproof and Increased Safety

# Oversize, G, H & J **Cable Glands** ATEX ( ) ( ) US

Flameproof/Increased Safety and Industrial

### 501/453 Flameproof / Increased Safety



### **151** Industrial



### 153 Industrial



### 321 Increased Safety



The 321 cable gland is manufactured in brass (standard), nickel plated brass, 316 stainless steel or aluminium.

Brass NPT entries are nickel plated as standard.

### 501/453

Assembly instruction data sheet No. A.I. 303.

For application, features, technical data, general information, materials/finishes and cable gland ordering examples, please refer to :-Page 13 (501/453/Universal). Page 14 (501/453/RAC). Page 15 (501/453/RAC/L).

### 151

Assembly instruction data sheet No. A.I. 314.

For application, features, technical data, general information, materials/finishes and cable gland ordering examples, please refer to :-

Page 42 (I51/RAC).

### 153

Assembly instruction data sheet No. A.I. 303.

For application, features, technical data, general information, materials/finishes and cable gland ordering examples, please refer to :-Page 39 (I53/RAC). Page 40 (153/RAC/L).

### **American Series Cable Glands**

'H' Size (M90) cable glands are available with the exception of the 755. Please contact Hawke International for details.

All of Hawke's Hazardous Area cable glands are dual certified (i.e. Flameproof and Increased Safety). The following cable glands are also available to Increased Safety certification only.

### 321

Assembly instruction data sheet No. A.I. 307. For sizes O s to J. Baseefa Certificate No. BAS 01 ATEX 2266X.

For application, features, technical data, general information, materials/finishes and cable gland ordering examples, please refer to :-Page 11 (501/421).

ncreased Safety

**Cable Glands** 



# Cable Gland Type HPG-Ex Metric Thread ATEX (Ex) (E

**Increased Safety** 

	CABLE GLAND SELECTION TABLE												
Entry Thread	Thread	Cable Accep	tance Details			Product Part Codes							
Size	Lengtn	Outer S	heath 'B'	G									
Metric		Min.	Max.		Black	Blue	Grey						
MI2	8.0	3.0	6.5	21.0	P3/M12/1/S/S/A	P3/M12/1/S/B/A	P3/M12/1/S/G/A						
MI2	8.0	2.0	5.0	21.0	P3/M12/2/S/S/A	P3/M12/2/S/B/A	P3/M12/2/S/G/A						
MI6	8.0	4.0	8.0	22.0	P3/M16/1/S/S/A	P3/M16/1/S/B/A	P3/M16/1/S/G/A						
MI6	8.0	3.0	6.0	22.0	P3/M16/2/S/S/A	P3/M16/2/S/B/A	P3/M16/2/S/G/A						
MI6	8.0	5.0	10.0	25.0	P3/M16/3/S/S/A	P3/M16/3/S/B/A	P3/M16/3/S/G/A						
MI6	8.0	3.0	7.0	25.0	P3/M16/4/S/S/A	P3/M16/4/S/B/A	P3/M16/4/S/G/A						
M20	9.0	6.5 12.0		27.0	P3/M20/1/S/S/A	P3/M20/1/S/B/A	P3/M20/1/S/G/A						
M20	9.0	5.0 9.0		27.0	P3/M20/2/S/S/A	P3/M20/2/S/B/A	P3/M20/2/S/G/A						
M20	9.0	10.0	14.0	28.0	P3/M20/3/S/S/A	P3/M20/3/S/B/A	P3/M20/3/S/G/A						
M20	9.0	7.0	12.0	28.0	P3/M20/4/S/S/A	P3/M20/4/S/B/A	P3/M20/4/S/G/A						
M25	11.0	13.0	18.0	31.0	P3/M25/1/S/S/A	P3/M25/1/S/B/A	P3/M25/1/S/G/A						
M25	11.0	9.0	16.0	31.0	P3/M25/2/S/S/A	P3/M25/2/S/B/A	P3/M25/2/S/G/A						
M32	11.0	18.0	25.0	39.0	P3/M32/1/S/S/A	P3/M32/1/S/B/A	P3/M32/1/S/G/A						
M32	11.0	13.0	20.0	39.0	P3/M32/2/S/S/A	P3/M32/2/S/B/A	P3/M32/2/S/G/A						
M40	13.0	22.0	32.0	48.0	P3/M40/1/S/S/A	P3/M40/1/S/B/A	P3/M40/1/S/G/A						
M40	13.0	20.0	26.0	48.0	P3/M40/2/S/S/A	P3/M40/2/S/B/A	P3/M40/2/S/G/A						
M50	13.0	32.0	38.0	49.0	P3/M50/1/S/S/A	P3/M50/1/S/B/A	P3/M50/1/S/G/A						
M50	13.0	25.0	31.0	49.0	P3/M50/2/S/S/A	P3/M50/2/S/B/A	P3/M50/2/S/G/A						
M63	14.0	37.0	44.0	49.0	P3/M63/1/S/S/A	P3/M63/1/S/B/A	P3/M63/1/S/G/A						
M63	14.0	29.0	35.0	49.0	P3/M63/2/S/S/A	P3/M63/2/S/B/A	P3/M63/2/S/G/A						

### **General Information**

All Metric entry threads are 1.5mm pitch as standard. All dimensions in millimetres. Also available in NPT and PG threads. Assembly instruction data sheet No. A.I. 369.

Accessories including locknuts, sealing washers, serrated washers, earth tags, shrouds, adaptors and reducers available. See pages 53 - 57.

### **Materials & Finishes**

The body of the gland is manufactured in polyamide. The gasket and 'O' ring are manufactured in NBR (Nitrile-Butadiene Rubber).

### Cable Gland Ordering Examples

For ordering examples please see product part codes section in the selection table above.

### Application

- Outdoor or Indoor use.
- For use with non-armoured elastomer and plastic insulated cables.
- See technical section of the catalogue for installation rules and regulations.

### **Features**

- Provides a cable seal onto the cables outer sheath.
- Two piece gland.
- Captive cable seal.
- Vibration resistant back nut/clamp.
- UL94-VO rated.

### **Technical Data**

- Increased Safety Exe.
   II 2G ID Ex ell tD A20.
- BVS 06 ATEX E 154X.
- Suitable for use in Zone 1, Zone 2, Zone 20, Zone 21 and Zone 22.
- Suitable for use in Gas Groups IIA, IIB and IIC.
  IP66, IP67 and IP68 (up to 10 bar with 'O' ring)
- ingress protection.Operating temperature range
  - -20°C to +90°C as standard.

Connection Solutions www.ehawke.com







	CABLE GLAND SELECTION TABLE												
Entry Thread	Thread	Cable Accep	tance Details		Product Part Codes								
Size	Length	Outer S	heath 'B'	'G'		froduct fait codes							
NPT *	'H'	Min.	Max.		Black	Blue	Grey						
3/8"	15.0	4.0	8.0	22.0	P3/M3/8"NPT/1/S/A	P3/M3/8"NPT/1/B/A	P3/M3/8"NPT/1/G/A						
3/8"	15.0	2.0	6.0	22.0	P3/M3/8"NPT/2/S/A	P3/M3/8"NPT/2/B/A	P3/M3/8"NPT/2/G/A						
1/2"	13.0	6.5	12.0	27.0	P3/M1/2"NPT/1/S/A	P3/M1/2"NPT/1/B/A	P3/M1/2"NPT/1/G/A						
1/2"	13.0	5.0	9.0	27.0	P3/M1/2"NPT/2/S/A	P3/M1/2"NPT/2/B/A	P3/M1/2"NPT/2/G/A						
1/2"/16	13.0	10.0	14.0	28.0	P3/M1/2"NPT(16)/1/S/A	P3/M1/2"NPT(16)/1/B/A	P3/M1/2"NPT(16)/1/G/A						
1/2"/16	13.0	7.0	12.0	28.0	P3/M1/2"NPT(16)/2/S/A	P3/M1/2"NPT(16)/2/B/A	P3/M1/2"NPT(16)/2/G/A						
3/4"	14.0	13.0	18.0	31.0	P3/M3/4"NPT/1/S/A	P3/M3/4"NPT/1/B/A	P3/M3/4"NPT/I/G/A						
3/4"	14.0	9.0	16.0	31.0	P3/M3/4"NPT/2/S/A	P3/M3/4"NPT/2/B/A	P3/M3/4"NPT/2/G/A						
"	19.0	18.0	25.0	39.0	P3/M1"NPT/1/S/A	P3/M1"NPT/1/B/A	P3/M1"NPT/1/G/A						
۱"	19.0	13.0	20.0	39.0	P3/M1"NPT/2/S/A	P3/M1"NPT/2/B/A	P3/M1"NPT/2/G/A						
/4"	16.0	18.0	25.0	39.0	P3/M1 1/4"NPT/1/S/A	P3/MI I/4"NPT/I/B/A	P3/M1 1/4"NPT/1/G/A						
/4"	16.0	13.0	20.0	39.0	P3/M1 1/4"NPT/2/S/A	P3/M1 1/4"NPT/2/B/A	P3/M1 1/4"NPT/2/G/A						
/2"	20.0	22.0	32.0	48.0	P3/M1 1/2"NPT/1/S/A	P3/M1 1/2"NPT/1/B/A	P3/M1 1/2"NPT/1/G/A						
/2"	20.0	20.0	26.0	48.0	P3/M1 1/2"NPT/2/S/A	P3/M1 1/2"NPT/2/B/A	P3/M1 1/2"NPT/2/G/A						

# HPG-Ex Cable Gland NPT

### **General Information**

All dimensions in millimetres (except\* where dimensions are in inches). Also available in Metric and PG threads. Assembly instruction data sheet No. A.I. 369.

Accessories including locknuts, sealing washers, serrated washers, earth tags, shrouds, adaptors and reducers available. See pages 53 - 57.

### **Materials & Finishes**

The body of the gland is manufactured in polyamide. The gasket and 'O' ring are manufactured in NBR (Nitrile-Butadiene Rubber).

### **Cable Gland Ordering Examples**

For ordering examples please see product part codes section in the selection table above.

### Application

- Outdoor or Indoor use.
- For use with non-armoured elastomer and plastic insulated cables.
- See technical section of the catalogue for installation rules and regulations.

### **Features**

- Provides a cable seal onto the cables outer sheath.
- Two piece gland.
- Captive cable seal.
- Vibration resistant back nut/clamp.
- UL94-VO rated.

- Increased Safety Exe.
   Il 2G ID Ex ell tD A20.
- BVS 06 ATEX E 154X.
- Suitable for use in Zone 1, Zone 2, Zone 20, Zone 21 and Zone 22.
- Suitable for use in Gas Groups IIA, IIB and IIC.
- IP66, IP67 and IP68 (up to 10 bar with 'O' ring) ingress protection.
- Operating temperature range -20°C to +90°C as standard.





# Cable Gland Type HPG-Ex PG Thread ATEX (Ex) (E Increased Safety

	CABLE GLAND SELECTION TABLE												
Entry Thread	Thread	Cable Accep	otance Details			Product Part Codes							
Size	Length	Outer S	Sheath 'B'	'G'									
PG	'H'	Min.	Max.		Black	Blue	Grey						
7	8.0	3.0	6.5	21.0	P3/PG7/1/S/S/A	P3/PG7/1/S/B/A	P3/M12/1/S/G/A						
7	8.0	2.0	5.0	21.0	P3/PG7/2/S/S/A	P3/PG7/2/S/B/A	P3/M12/2/S/G/A						
9	8.0	4.0	8.0	22.0	P3/PG9/1/S/S/A	P3/PG9/1/S/B/A	P3/M16/1/S/G/A						
9	8.0	3.0	6.0	22.0	P3/PG9/2/S/S/A	P3/PG9/2/S/B/A	P3/M16/2/S/G/A						
11	8.0	5.0	10.0	25.0	P3/PG11/3/S/S/A	P3/PG11/3/S/B/A	P3/M16/3/S/G/A						
11	8.0	3.0	7.0	25.0	P3/PG11/4/S/S/A	P3/PG11/4/S/B/A	P3/M16/4/S/G/A						
13.5	9.0	6.5	12.0	27.0	P3/PG13.5/1/S/S/A	P3/PG13.5/1/S/B/A	P3/M20/1/S/G/A						
13.5	9.0	5.0	9.0	27.0	P3/PG13.5/2/S/S/A	P3/PG13.5/2/S/B/A	P3/M20/2/S/G/A						
16	9.0	10.0	14.0	28.0	P3/PG16/3/S/S/A	P3/PG16/3/S/B/A	P3/M20/3/S/G/A						
16	9.0	7.0	12.0	28.0	P3/PG16/4/S/S/A	P3/PG16/4/S/B/A	P3/M20/4/S/G/A						
21	11.0	13.0	18.0	31.0	P3/PG21/1/S/S/A	P3/PG21/1/S/B/A	P3/M25/1/S/G/A						
21	11.0	9.0	16.0	31.0	P3/PG21/2/S/S/A	P3/PG21/2/S/B/A	P3/M25/2/S/G/A						
29	11.0	18.0	25.0	39.0	P3/PG29/1/S/S/A	P3/PG29/1/S/B/A	P3/M32/1/S/G/A						
29	11.0	13.0	20.0	39.0	P3/PG29/2/S/S/A	P3/PG29/2/S/B/A	P3/M32/2/S/G/A						
36	13.0	22.0	32.0	48.0	P3/PG36/1/S/S/A	P3/PG36/1/S/B/A	P3/M40/1/S/G/A						
36	13.0	20.0	26.0	48.0	P3/PG36/2/S/S/A	P3/PG36/2/S/B/A	P3/M40/2/S/G/A						
42	13.0	32.0	38.0	49.0	P3/PG42/1/S/S/A	P3/PG42/1/S/B/A	P3/M50/1/S/G/A						
42	13.0	25.0	31.0	49.0	P3/PG42/2/S/S/A	P3/PG42/2/S/B/A	P3/M50/2/S/G/A						
48	14.0	37.0	44.0	49.0	P3/PG48/1/S/S/A	P3/PG48/1/S/B/A	P3/M63/1/S/G/A						
48	14.0	29.0	35.0	49.0	P3/PG48/2/S/S/A	P3/PG48/2/S/B/A	P3/M63/2/S/G/A						

### **General Information**

All dimensions in millimetres. Also available in Metric and NPT threads. Assembly instruction data sheet No. A.I. 369.

Accessories including locknuts, sealing washers, serrated washers, earth tags, shrouds, adaptors and reducers available. See pages 53 - 57.

### **Materials & Finishes**

The body of the gland is manufactured in polyamide. The gasket and 'O' ring are manufactured in NBR (Nitrile-Butadiene Rubber).

### **Cable Gland Ordering Examples**

For ordering examples please see product part codes section in the selection table above.

### Application

- Outdoor or Indoor use.
- For use with non-armoured elastomer and plastic insulated cables.
- See technical section of the catalogue for installation rules and regulations.

### Features

- Provides a cable seal onto the cables outer sheath.
- Two piece gland.
- Captive cable seal.
- Vibration resistant back nut/clamp.
- UL94-VO rated.

- Increased Safety Exe.
- BVS 06 ATEX E 154X.
- Suitable for use in Zone 1, Zone 2, Zone 20, Zone 21 and Zone 22.
- Suitable for use in Gas Groups IIA, IIB and IIC.
  IP66, IP67 and IP68 (up to 10 bar with 'O' ring)
- ingress protection.Operating temperature range
  - -20°C to +90°C as standard.







### **Metric Nylon Locknuts**



### LOCKNUT SELECTION TABLE

Metric	Across	ידי	Product Part Codes				
Gland	'X'	2	Black	Grey			
MI2	17.0	5.0	P3/LN/M12/S	P3/LN/M12/G			
MI6	22.0	5.0	P3/LN/M16/S	P3/LN/M16/G			
M20	27.0	6.0	P3/LN/M20/S	P3/LN/M20/G			
M25	36.0	7.0	P3/LN/M25/S	P3/LN/M25/G			
M32	41.0	7.0	P3/LN/M32/S	P3/LN/M32/G			
M40	50.0	7.0	P3/LN/M40/S	P3/LN/M40/G			
M50	60.0	8.0	P3/LN/M50/S	P3/LN/M50/G			
M63	75.0	8.0	P3/LN/M63/S	P3/LN/M63/G			

### **NPT Nylon Locknuts**



	LOCKNUT SELECTION TABLE												
NPT *	Across Flats	'7'	Product Part Codes										
	Gland	'X'	-	Black	Grey								
	3/8"	24.0	7.0	P3/LN/3/8"NPT/S	P3/LN/3/8"NPT/G								
	1/2"	27.0	6.0	P3/LN1/2"NPT/S	P3/LN/1/2"NPT/G								
	3/4"	32.0	7.0	P3/LN/3/4"NPT/S	P3/LN/3/4"NPT/G								
	l"	40.0	7.0	P3/LN/I"NPT/S	P3/LN/I"NPT/G								

**PG Nylon Locknuts** 



L	OCKNU	T SE	LECTION	ABLE
PG Cabla	Across	'7'	Product	Part Codes
Gland	'X'	L	Black	Grey
PG7	19.0	5.0	P3/LN/PG7/S	P3/LN/PG7/G
PG9	22.0	5.0	P3/LN/PG9/S	P3/LN/PG9/G
PGII	24.0	5.0	P3/LN/PG11/S	P3/LN/PG11/G
PG13.5	27.0	6.0	P3/LN/PG13.5/S	P3/LN/PG13.5/G
PG16	30.0	6.0	P3/LN/PG16/S	P3/LN/PG16/G
PG21	36.0	7.0	P3/LN/PG21/S	P3/LN/PG21/G
PG29	46.0	7.0	P3/LN/PG29/S	P3/LN/PG29/G
PG36	60.0	8.0	P3/LN/PG36/S	P3/LN/PG36/G
PG42	65.0	8.0	P3/LN/PG42/S	P3/LN/PG42/G
PG48	70.0	8.0	P3/LN/PG48/S	P3/LN/PG48/G

### Features

• Secures a cable gland in position at the equipment.

### **Technical Data**

• Operating temperature range -20°C to +90°C as standard.

### **Materials & Finishes**

The locknut is manufactured in polyamide.

### **General Information**

All dimensions in millimetres (except\* where dimensions are in inches). Hawke does not recommend the use of tapered entry threads in enclosures with plain clearance holes. Parallel threaded entries are recommended for this purpose.

### **Ordering Example**

For ordering examples please see product part codes section in the selection tables above.



Plastic Cable Gland Accessories

Cable Glands Group I ATEX (Ex) (C Mining Flameproof and Increased Safety

### SAFETY THROUGH INSPECTABILITY

### Features of Hawke's Mining Gland Range Include:-

### Unique Rear Sealing System - Wide Cable Acceptance Range



This arrangement offers IP66, IP67, IP68, NEMA 4X and Deluge (DTS01) Ingress Protection.

The seal is manufactured from a silicone material, has LSFZH properties, is ozone and oil resistant and is suitable for use at both high and low temperatures. The Rear Sealing System covers the entire range of cable diameters without the need for special seals and the cable acceptance range is stamped on the backnut for ease of inspection. The backnut can be hand tightened, with only one further spanner turn required to ensure IP66, IP67 and NEMA 4X.





Group I Cable Glands

### Unique Inspectable Compound Chamber - Designed for Safety



The revolutionary Hawke compound chamber has been designed with inspectability in mind.

The pre-lubricated compound chamber can be removed once the compound has fully cured, allowing full inspection of the flameproof seal.

If required minor surface voids can be repaired in situ. This unique patented compound chamber now forms the compound as well as providing a flameproof seal, resulting in reduced piece parts, as there is no longer a requirement for a separate seal and compound chamber.





Hawke International "Leading the way in the design of worldwide connection solutions"





# 653/Universal ATEX (Ex) (E Mining Flameproof and Increased Safety

		CA	BL	E GLA	NC	) SE	ELEC	СТІОІ	N TAB	SLE		
	Entro	Thread			Cabl	e Acce	ptance	Details			Llavagan	
Size Ref.	entry S	Size	Inner Sheath/ Cores			Ou She	uter eath	'C Armou	C' r/Braid	'G'	Dimensions	
itter.		NPT*	'D' 'E' Max Max		Max.	·	В'				Across	Across
	Metric	Std./ Option	Over Cores	Inner Sheath	Of Cores	Min.	Max.	Orientation I	Orientation 2		Flats	Corner
Os	M20	1/2"	8.9	10.0	6	5.5	12.0	0.9/1.25	0/0.7	72.8	24.0	27.7
0	M20	1/2"	8.9	10.0	6	9.5	16.0	0.9/1.25	0/0.7	72.8	24.0	27.7
Α	M20	3/4"/1/2"	11.0	12.5	10	12.5	20.5	0.9/1.25	0/0.7	73.8	30.0	34.6
В	M25	"/3/4"	16.2	18.4	21	16.9	26.0	1.25/1.6	0/0.7	78.I	36.0	41.6
С	M32	1⁄4"/ "	21.9	24.7	42	22.0	33.0	1.6/2.0	0/0.7	83.0	46.0	53.I
C2	M40	1⁄2"/   1⁄4"	26.3	29.7	60	28.0	41.0	1.6/2.0	0/0.7	84.I	55.0	63.5
D	M50	2"/1½"	37.1	41.7	80	36.0	52.6	1.8/2.5	0/1.0	91.3	65.0	75.I
E	M63	21/2"/2"	47.8	53.3	100	46.0	65.3	1.8/2.5	0/1.0	101.8	80.0	92.4
F	M75	3"/21/2"	59.0	66.2/65.3 <sup>1</sup>	120	57.0	78.0	1.8/2.5	0/1.0	101.2	95.0	109.6
1												

<sup>1</sup>Smaller value is applicable when selecting reduced NPT entry option.

### **General Information**

Os - F size metric entry threads are 1.5mm pitch as standard.

(1.5mm pitch with 15mm length of thread can be supplied) please specify when ordering. Thread length is 15mm for sizes Os to F. All dimensions in millimetres (except\* where dimensions are in inches).

Two part sealing compound and assembly instructions are supplied with the cable gland. Assembly instruction data sheet No. A.I. 301.

Accessories including locknuts, sealing washers, serrated washers, earth tags, shrouds, adaptors and reducers available. See pages 53 - 57.

### **Materials & Finishes**

The ICG 653/Universal is manufactured in brass (standard), nickel plated brass, 316 stainless steel or aluminium. Brass NPT entries are nickel plated as standard.

### Cable Gland Ordering Examples Cable Gland Type/Size/Thread

e.g. 653/UNIV/C/M32 653/UNIV/C/I 1/4" NPT

### Cable Gland with Alternative Clamping Ring (AR)

e.g. 653/UNIV/C/M32/AR 653/UNIV/C/I ¼" NPT/AR

### Alternative Reversible Armour Clamping Rings (RAC)

	SELECTION TABLE												
Size	Steel Wire Armour/Braid/Tape												
Ref.	Orientation I	Orientation 2											
O/Os	0.8 - 1.0	0.4 - 0.8											
Α	0.8 - 1.0	0.4 - 0.8											
В	0.9 - 1.25	0.5 - 0.9											
С	1.2 - 1.6	0.6 - 1.2											
C2	1.2 - 1.6	0.6 - 1.2											
D	1.45 - 1.8	1.0 - 1.45											
E	1.45 - 1.8	1.0 - 1.45											
F	1.45 - 1.8	1.0 - 1.45											

### Application

- Outdoor or Indoor use.
- For use with single wire armoured 'W', wire braided 'X' and steel tape armoured 'Z', elastomer and plastic insulated cables.

Group I Cable Gland

### For particular in all mining applications particularly those with:-

- a) Cables that are not effectively filled, compact and/or circular, have tape
- bedding or have hygroscopic fillers. b) Cables that exhibit "Cold Flow"
- characteristics.
- c) Enclosures containing an ignition source.
- See technical section of the catalogue for installation rules and regulations.

### **Features**

- Provides a barrier seal between the individual insulated cores within the cable and prevents entry of the products of an explosion into the cable
- Assembly of the cable gland compresses and distributes the compound evenly to create a barrier seal at the point of entry into the enclosure.
- The compound chamber may be seperated from the cured compound to ensure that the chamber has been effectively filled. If required, external voids can be repaired.
- Provides armour clamping, using one clamping arrangement for all armour/braid types.
- Provides a cable retention and low smoke and fume, zero halogen seal onto the cables outer sheath.

- Flameproof Exd and Increased Safety Exe. 🐼 IM 2
- Baseefa 02ATEX0175X.
- Suitable for use in Mines.
- Construction and test standards EN 50014, EN 50018 and EN 50019
- IP66, IP67 and IP68 ingress protection to IEC 60529 and EN 60529.
- Operating temperature range -60°C to +80°C as standard.





	CABLE GLAND SELECTION TABLE														
	Entro	Thread													
Size	entry S	Size	lı	nner Sheath Cores	n/	Ou She	uter eath	'C' Pliable Wire	'G'	Dimensions					
Inter.		NPT*	'D' Max.	'E' Max.	Max. No.		В'	Armour		Across	Across				
	Metric	Std./ Option	Over Cores	Inner Sheath	Of Cores	Min.	Max.	Orientation		Flats	Corners				
0	M20	1/2"	8.9	10.0	6	9.5	16.0	7 x 0.45	72.8	24.0	27.7				
A	M20	3/4"/1/2"	11.0	12.5	10	12.5	20.5	7 x 0.45	73.8	30.0	34.6				
В	M25	"/3/4"	16.2	18.4	21	16.9	26.0	7 x 0.45	78.1	36.0	41.6				
С	M32	11/4"/1"	21.9	24.7	42	22.0	33.0	7 x 0.45	83.0	46.0	53.1				
C2	M40	½"/  ¼"	26.3	29.7	60	28.0	41.0	7 x 0.7 l	84.I	55.0	63.5				
D	M50	2"/1½"	37.1	41.7	80	36.0	52.6	7 x 0.7 l	91.3	65.0	75.I				
E	M63	21/2"/2"	47.8	53.3	100	46.0	65.3	7 x 0.9	101.8	80.0	92.4				
F	M75	3"/21/2"	59.0	66.2/65.3 <sup>1</sup>	120	57.0	78.0	7 x 1.25	101.2	95.0	109.6				

<sup>1</sup>Smaller value is applicable when selecting reduced NPT entry option.

### **General Information**

O - F size metric entry threads are 1.5mm pitch as standard.

(1.5mm pitch with 15mm length of thread can be supplied) please specify when ordering.

Thread length is 15mm for sizes Os to F.

All dimensions in millimetres (except\* where dimensions are in inches).

Two part sealing compound and assembly instructions are supplied with the cable gland. Assembly instruction data sheet No. A.I. 346.

Accessories including locknuts, sealing washers, serrated washers, earth tags, shrouds, adaptors and reducers available. See pages 53 - 57.

### **Materials & Finishes**

The 653/T is manufactured in brass (standard), nickel plated brass, 316 stainless steel or aluminium. Brass NPT entries are nickel plated as standard.

### Cable Gland Ordering Examples Cable Gland Type/Size/Thread

e.g. 653/T/C/M32 653/T/C/1 <sup>1</sup>/4" NPT

# Group I Cable Gland 653/T ATEX ( Mining

Flameproof and Increased Safety

### Application

- Outdoor or Indoor use.
- For use with pliable wire armoured, elastomer and plastic insulated cables

### For particular in all mining

### applications particularly those with:-

- a) Cables that are not effectively filled, compact and/or circular, have tape bedding or have hygroscopic fillers.
- b) Cables that exhibit "Cold Flow" characteristics.
- c) Enclosures containing an ignition source.
- See technical section of the catalogue for installation rules and regulations.

### **Features**

- Provides a barrier seal between the individual insulated cores within the cable and prevents entry of the products of an explosion into the cable.
- Assembly of the cable gland compresses and distributes the compound evenly to create a barrier seal at the point of entry into the enclosure.
- The compound chamber may be seperated from the cured compound to ensure that the chamber has been effectively filled. If required, external voids can be repaired.
- Provides armour clamping, for pliable wire armour
- Provides a cable retention and low smoke and fume, zero halogen seal onto the cables outer sheath.

- Flameproof Exd and Increased Safety Exe. 🐼 IM 2
- Baseefa 02ATEX0179X.
- Suitable for use in Mines.
- Construction and test standards EN 50014, EN 50018 and EN 50019
- IP66, IP67 and IP68 ingress protection to IEC 60529 and EN 60529.
- Operating temperature range -60°C to +80°C as standard.





# Group I Cable Gland 623 ATEX ( Mining

Flameproof and Increased Safety

	CABLE GLAND SELECTION TABLE													
Size	Entry	Throad		Cabl		Hovagon								
		Size	lr	ner Sheat	h/	0	uter S	heath '	В'		Dimensions			
Bof				Cores		Stan	dard	Alteri	native	'G'				
Rei.	Matria	NPT*	Max.	Max.	Max. No.	Se	eal	Seal	(S)		Across	Across		
	Metric	Option	Over Cores	Inner Sheath	Of Cores	Min.	Max.	Min.	Max.		Flats	Corners		
Os	M20	1/2"	8.0	8.0	6	3.0	8.0			57.5	24.0	27.7		
0	M20	1/2"	8.9 10.0		6	7.5	11.9	-	-	57.5	24.0	27.7		
Α	M20	3/4"/1/2"	11.0	12.5	10	11.0	14.3	8.5	13.4	56.3	30.0	34.6		
В	M25	"/³⁄4"	16.2	18.4	21	13.0	20.2	9.5	15.4	58.9	36.0	41.6		
С	M32	1⁄4"/ "	21.9	24.7	42	19.0	26.5	15.5	21.2	61.7	46.0	53.I		
C2	M40	1⁄2"/   1⁄4"	26.3	29.7	60	25.0	32.5	22.0	28.0	62.6	55.0	63.5		
D	M50	2"/1½"	37.I	41.7	80	31.5	44.4	27.5	34.8	72.8	65.0	75.I		
E	M63	21/2"/2"	47.8	53.5	100	42.5	56.3	39.0	46.5	75.7	80.0	92.4		
F	M75	3"/21/2"	59.0	66.2/65.3 <sup>I</sup>	120	54.5	68.2	48.5	58.3	77.7	95.0	109.6		

<sup>1</sup>Smaller value is applicable when selecting reduced NPT entry option.

### **General Information**

Os - F size metric entry threads are 1.5mm pitch as standard. (1.5mm pitch with 15mm length of thread can be supplied) please specify when ordering.

Thread length is 15mm for sizes Os to F.

All dimensions in millimetres (except\* where dimensions are in inches). Two part sealing compound and assembly instructions are supplied with the cable gland.

Assembly instruction data sheet No. A.I. 305.

Accessories including locknuts, sealing washers, serrated washers, earth tags, shrouds, adaptors and reducers available. See pages 53 - 57.

### **Materials & Finishes**

The 623 is manufactured in brass (standard), nickel plated brass, 316 stainless steel or aluminium. Brass NPT entries are nickel plated as standard.

### Cable Gland Ordering Examples Cable Gland Type/Size/Thread

e.g. 623/C/M32 623/C/1 <sup>1</sup>/<sub>4</sub>" NPT

Cable Gland with Alternative Seal (S)

e.g. 623/C/M32/S 623/C/1 <sup>1</sup>/4" NPT/S

### **Application**

- Outdoor or Indoor use.
- For use with non-armoured elastomer and plastic insulated cables.
- For particular use with :-
- a) Cables that are not effectively filled, compact and/or circular, have tape bedding or have hygroscopic fillers.
- b) Cables that exhibit "Cold Flow" characteristics.
- c) Enclosures containing an ignition source.
- See technical section of the catalogue for installation rules and regulations.

### Features

- Provides a barrier seal between the individual insulated cores within the cable and prevents entry of the products of an explosion into the cable.
- Assembly of the cable gland compresses and distributes the compound evenly to create a barrier seal at the point of entry into the enclosure.
- The compound chamber may be seperated from the cured compound to ensure that the chamber has been effectively filled. If required, external voids can be repaired.
- Provides a cable retention seal onto the cables outer sheath.

- Flameproof Exd and Increased Safety Exe.
   I M2.
- Baseefa 06ATEX0177X.
- Suitable for use in Mines.
- Construction and test standards EN 50014, EN50018 and EN 50019.
- IP66, IP67 and IP68 ingress protection to IEC 60529 and EN 60529.
- Operating temperature range -60°C to +80°C as standard.





# Group I Stopping Plugs and Flanges ATEX (Ex) Mining

Flameproof

### M475 and M477 Flameproof



M475 AND M477 STOPPING PLUGS										
Threa	ıd Size	Hex. Key								
Metric		Across Flats								
x 1.5p	NPT *	Size 'V'								
M20	1/2"	10.0								
M25	3/4"	10.0								
M32	Ι"	14.0								
M40	1/4"	14.0								
M50	1/2"	17.0								
M63	21/2"or2"	17.0								
M75	3"	19.0								

### **General Information**

All dimensions in millimetres (except\* where dimensions are in inches). The M475 is tightened from outside of the enclosure. The M477 is tightened from the inside of the enclosure.

### **Materials & Finishes**

M475 and M477 Stopping plugs are manufactured in brass (standard).

### Features

• To close unused cable gland entries and maintain the flameproof integrity of the equipment.

### **Technical Data**

- Flameproof EExd I. 🐼 I M2 IP66.
- Baseefa Certificate No. Baseefa 02 ATEX 0086.
- Suitable for use in Mines.

### Stopping Plugs Ordering Example

Stopping Plug Type/Size/Thread

e.g. M477/M32

**Mining Accessories** 

### **Blanking Flange Type 470**



### **General Information** All dimensions in millimetres.

### **Materials & Finishes**

The 470 Blanking Flange is manufactured in brass (standard).

### 470 BLANKING FLANGE SELECTION TABLE

Size	Flange Dimensions														
Ref.	K	L	Μ	N	Р	R	S	Т	U						
0	44.4	12.7	19.05	26.1	6.7	11.1	7	30	70.0						
А	44.4	12.7	19.05	26.I	6.7	11.1	7	30	70.0						
В	57.I	12.7	25.40	26.I	6.7	11.1	7	36	82.5						
С	69.8	14.3	31.75	27.7	9.1	15.1	8.7	46	98.4						
C2	82.5	14.3	38.10	27.7	9.1	15.1	8.7	55	111.1						
D	95.2	17.5	50.80	29.3	11.1	18.1	10.5	65	130.2						
Е	114.3	17.5	63.50	29.3	11.1	18.1	10.5	80	149.3						
F	127.0	17.5	76.20	32.5	11.1	20.5	13.5	95	162.0						

### Features

• To close unused cable gland entries and maintain the flameproof integrity of the equipment.

### Ordering Example

Blanking FlangeType/Size e.g. 470/A

47	470 BLANKING FLANGE												
Size	Equipment Entry Hole Size												
Ref.	Max	Min											
O/A	19.35	19.10											
В	25.70	25.45											
С	32.05	31.80											
C2	38.40	38.15											
D	51.10	50.85											
E	63.80	63.55											
F	76.50	76.25											

### **Technical Data**

- Flameproof EExd I. 🖾 I M2
- Baseefa Certificate No.
- Baseefa 02 ATEX 0174U.
- Suitable for use in Mines.

### Adaptor Flange Type 483



**General Information** All dimensions in millimetres.

### **Materials & Finishes**

The 483 Adaptor Flange is manufactured in brass (standard).

	483 ADAPTOR FLANGE SELECTION TABLE													
Size	Flange Dimensions													
Ref.	К	L	M	N	Р	R	S	Т	U	V	W	Size		
0	57.1	12.7	25.40	26.1	6.7	11.1	7	36	82.5	M20	20	В		
А	57.I	12.7	25.40	26.I	6.7	11.1	7	36	82.5	M20	20	В		
В	69.8	14.3	31.75	27.7	9.1	15.1	8.7	46	98.4	M25	25.4	С		
С	82.5	14.3	38.10	27.7	9.1	15.1	8.7	55	111.1	M32	32	C2		
C2	95.2	17.5	50.80	29.3	11.1	18.1	10.5	65	130.2	M40	40	D		
D	114.3	17.5	63.50	29.3	11.1	18.1	10.5	80	149.3	M50	50.7	E		
Е	127.0	17.5	76.20	32.5	11.1	20.5	13.5	95	162.0	M63	63.4	F		
F	127.0	17.5	76.20	48.0	11.1	20.5	13.5	95	162.0	M75	66.0	F		
Fea	tures	5										Tech		

To allow metric threaded Group I cable gland types, 653/Universal, 653/T and 623 to be used in size up spigot entries.

### **Ordering Example**

Adaptor FlangeType/Size e.g. 483/A

Size	Equipment E	ntry Hole Size				
Ref.	Max	Min				
0	25.70	25.45				
Α	25.70	25.45				
В	32.05	31.80				
С	38.40	38.15				
C2	51.10	50.85				
D	63.80	63.55				
Е	76.50	76.25				
F	76.50	76.25				

492 ADARTOR ELANCE

- 🔹 Flameproof EExd I. 🐼 I M2
  - Baseefa Certificate No.
  - Baseefa 02 ATEX 0173U.
  - Suitable for use in Mines.



# Adaptor Reducer

# Group I Adaptors and Reducers M476

ATEX (Ex) Mining

Flameproof and Increased Safety

	Adaptor		ADAPTOR AND REDUCER SELECTION TABLE																	
	R	مطبية	or								Mal	e Th	read							
	Reducer		.01	Metric								NPT								
				M16	M20	M25	M32	M40	M50	M63	M75		1⁄2"	3⁄4"	١"	11/4"	½"	2"	21⁄2"	3"
			MI6																	
			M20																	
			M25																	
		tric	M32																	
		Me	M40																	
			M50																	
.	J		M63																	
	rea		M75																	
li	F																			
	nale		1⁄2"																	
	٦e		3⁄4"																	
			١"																	
		РТ	11⁄4"																	
		Z	½"																	
			2"																	
			21⁄2"																	
			3"																	

### **General Information**

All Metric entry threads are 1.5mm pitch as standard.

### **Materials & Finishes**

Hawke adaptors/reducers are manufactured in brass (standard), nickel plated brass, 316 stainless steel or aluminium. Brass NPT entries are nickel plated as standard.

### Adaptor Ordering Example 476/Male Thread Size/Female Thread Size.

e.g. 476//M25/M20.

### **Reducer Ordering Example** M476/1/Male Thread Size/Female Thread Size.

e.g. 476/1/M25/3/4" NPT.

### **Application/Features**

 Provides a means of connection between the equipment and cable glands with dissimilar thread sizes or types.

- Flameproof and Increased Safety Exde I.
- Certificate No. SIRA 06 ATEX 1240U.
- Suitable for use in Mines.
- Construction and test standards EN 50014, EN 50018 and EN 50019.







# Industrial Cable Glands










# **Features**

### Unique Rear Sealing System

This arrangement offers IP66, IP67, IP68 (30 metres for 7 days), NEMA 4X and Deluge (DTS01) Ingress Protection. The seal is manufactured from a silicone material, has LSFZH properties, is ozone and oil resistant and is suitable for use at both high and low temperatures.

The Rear Sealing System covers the entire range of cable diameters without the need for special seals and the cable acceptance range is stamped on the backnut for ease of inspection. The backnut can be hand tightened, with only one further spanner turn required to ensure IP66, IP67, IP68 and NEMA 4X.

### • The Original Reversible Armour Clamp

The original RAC clamping system was invented by Hawke over 10 years ago and is a well established proven performer in all conditions. Simply by reversing the clamping ring, the cable gland can adjust to accomodate all types of cable armour or braid. Unlike many of our competitors the correct clamping orientation is marked clearly with a 'W', 'Z' or 'X' and backed up by the presence of a groove in the component. Hawke's RAC clamping system is also fully inspectable when positioned on the cable.

### • Inspectable Deluge Seal

Hawke's inspectable deluge seal offers IP66 and IP67 sealing and is certified as 'deluge proof' by ITS in accordance with DTS01. Indeed Hawke's deluge seal is so good that it exceeds the expectations of the offshore industry by not only preventing ingress into the equipment, but also into the cable gland, which could potentially corrode the cable armour.













	CABLE GLAND SELECTION TABLE												
	Entry	Thread	C	Cable Acceptan	ce Deta	ils		Цах	(2000				
C:		Size		Outer She	ath 'B'			Dime	ensions				
Rof			St	andard	Alter	native	'G'						
	Motric	NP1*		Seal	Sea	I (S)		Across	Across				
	i ieu ic	Option	Min. Max. Min. Max.			Flats	Corners						
2K	MI6	-	3.0	8.0	-	-	27	19.0	21.2				
Os	M20 <sup>2</sup>	1/2"	3.0	8.0	-	-	32.8	24.0	27.7				
0	M20 <sup>2</sup>	1/2"	7.5	11.9	-	-	32.8	24.0	27.7				
Α	M20	3/4"/1/2"	11.0	14.3	8.5	13.4	32.8	30.0	34.6				
В	M25	"/3/4"	13.0	20.2	9.5	15.4	33.8	36.0	41.6				
С	M32	11⁄4"/1"	19.0	26.5	15.5	21.2	35.2	46.0	53.I				
C2	M40	1⁄2"/   1⁄4"	25.0	32.5	22.0	28.0	36.5	55.0	63.5				
D	M50	2"/1½"	31.5	44.4/42.3	27.5	34.8	47.9	65.0	75.I				
E	M63	21/2"/2"	42.5	56.3/54.3 <sup>1</sup>	39.0	46.5	46.2	80.0	92.4				
F	M75	3"/21/2"	54.5	68.2/65.3 <sup>1</sup>	48.5	58.3	48	95.0	109.6				
G	M80	31/2"	67.0	73.0	-	-	41	106.4	123.0				
н	M90	31/2"	67.0	77.6	-	-	41	115.0	132.8				
J	M100	4"	75.0	91.6	-	-	41	127.0	146.7				

 $^1$  Smaller value is applicable when selecting reduced NPT entry option.  $^2$  Sizes Os and O are available with an M16 thread size. For O size with M16

thread, the maximum cable outer sheath diameter is 10.9mm.

### **General Information**

2K - F size metric entry threads are 1.5mm pitch as standard. For G size glands and above, a 2mm pitch is supplied as standard. (1.5mm pitch with 15mm length of thread can be supplied) please specify when ordering.

Thread length is 15mm for sizes 2K to F and 20mm for sizes G to J. All dimensions in millimetres (except\* where dimensions are in inches). Assembly instruction data sheet No. A.I. 307.

Accessories including locknuts, sealing washers, serrated washers, earth tags, shrouds, adaptors and reducers available. See pages 53 - 57.

### **Materials & Finishes**

The 121cable gland is manufactured in brass (standard), nickel plated brass, 316 stainless steel or aluminium. Brass NPT entries are nickel plated as standard.

### **Cable Gland Ordering Examples**

Cable Gland Type/Size/Thread

e.g. 121/C/M32 121/C/1½" NPT

Cable Gland with Alternative Seal (S)

e.g. 121/C/M32/S 121/C/1<sup>1</sup>/4" NPT/S



2K Size Cable Gland Design

### Application

- Outdoor or Indoor use.
- For use with non-armoured elastomer and plastic insulated cables.
- See technical section of the catalogue for installation rules and regulations.

### Features

• Provides a cable retention seal onto the cables outer sheath.

### **Technical Data**

- Construction and test standards EN 50262. BS 6121 Part 1. Type A2.
- IP66, IP67 and IP68 (30 metres for 7 days) ingress protection to IEC 60529 and EN 60529.
- DTS01 deluge protection certified by ITS.
- Operating temperature range -60°C to +100°C as standard.

121



Cable Gland Type

Industrial



	CABLE GLAND SELECTION TABLE													
	Entry	Thread	C	Cable Acceptan	ce Deta	ils		Не	(agon					
Sizo		Size		Outer Shea	ath 'B'			Dime	ensions					
Ref			St	tandard	Alter	native	'G'							
	Motric	NP1* Std /		Seal	Sea	I (S)		Across	Across					
	i ieu ic	Option	Min.	Max.	Min.	Max.		Flats	Corners					
Os	M20 <sup>2</sup>	1/2"	3.0	8.0	-	-	52.3	24.0	27.7					
0	M20 <sup>2</sup>	1⁄2"	7.5	11.9	-	-	52.3	24.0	27.7					
A	M20	3/4"/1/2"	11.0	14.3	8.5	13.4	51.5	30.0	34.6					
В	M25	"/3/4"	13.0	20.2	9.5	15.4	54.7	36.0	41.6					
С	M32	1/4"/  "	19.0	26.5	15.5	21.2	55.9	46.0	53.I					
C2	M40	1⁄2"/   1⁄4"	25.0	32.5	22.0	28.0	58.I	55.0	63.5					
D	M50	2"/1½"	31.5	44.4/42.3	27.5	34.8	74.3	65.0	75.I					
E	M63	21/2"/2"	42.5	56.3/54.3	39.0	46.5	73.2	80.0	92.4					
F	M75	3"/21/2"	54.5	68.2/65.3 <sup>1</sup>	48.5	58.3	75	95.0	109.6					
G	M80	31/2"	67.0	73.0	-	-	68	106.4	123.0					
н	M90	31⁄2"	67.0	77.6	-	-	68	115.0	132.8					
J	M100	4"	75.0	91.6	-	-	68	127.0	146.7					

<sup>1</sup> Smaller value is applicable when selecting reduced NPT entry option.
 <sup>2</sup>Sizes Os and O are available with an M16 thread size. For O size with M16 thread, the maximum cable outer sheath diameter is 10.9mm.

### **General Information**

Os - F size metric entry threads are 1.5mm pitch as standard. For G size glands and above, a 2mm pitch is supplied as standard. (1.5mm pitch with 15mm length of thread can be supplied) please specify when ordering.

Thread length is 15mm for sizes Os to F and 20mm for sizes G to J. All dimensions in millimetres (except\* where dimensions are in inches). Assembly instruction data sheet No. A.I. 306.

Accessories including locknuts, sealing washers, ser rated washers, earth tags, shrouds, adaptors and reducers available. See pages 53 - 57.

### **Materials & Finishes**

The 123 cable gland is manufactured in brass (standard), nickel plated brass, 316 stainless steel or aluminium. Brass NPT entries are nickel plated as standard.

### Cable Gland Ordering Examples Cable Gland Type/Size/Thread

e.g. 123/C/M32 123/C/1<sup>1</sup>/4" NPT

### Cable Gland with Alternative Seal (S)

e.g. 123/C/M32/S 123/C/1<sup>1</sup>/4" NPT/S

### Application

- Outdoor or Indoor use.
  For use with non-armoured elastomer and plastic insulated
- cables.
  May be used on cables incorporating inner and outer cable sheaths.
- See technical section of catalogue for installation rules and regulations.

### **Features**

• Provides a cable retention seal onto the cables outer sheath at two independent sealing points.

### **Technical Data**

- Construction and test standards EN 50262. BS 6121 Part 1. Type A2.
- IP66, IP67 and IP68 (30 metres for 7 days) ingress protection to IEC 60529 and EN 60529.
- DTS01 deluge protection certified by ITS.
- Operating temperature range -60°C to +100°C as standard.

# l

Connection Solutions www.ehawke.com

# Cable Gland Type I 23 (E Industrial



# Cable Gland Type I 53/Universal

Industrial

 $( \epsilon$ 

		LE									
	Entry	Thread		С	able Ac	ceptance	Details				(2000
Size	S	Size	Inne	r Sheath	Outer	Sheath	'C Armou	C' r/Braid	'G'	Dime	ensions
Ref.	Metric Std./			~		Ь				Across	Across
	Metric	Std./ Option	Min.	Max.	Min.	Max.	Orientation I	Orientation 2		Flats	Corner
Os	M20 <sup>2</sup>	1/2"	3.0	8.I	5.5	12.0	0.9/1.25	0/0.7	64.4	24.0	27.7
0	M20 <sup>2</sup>	<sup>1</sup> /2"	6.5	11.9	9.5	16.0	0.9/1.25	0/0.7	64.4	24.0	27.7
Α	M20	3/4"/1/2"	8.4	14.3	12.5	20.5	0.9/1.25	0/0.7	65.4	30.0	34.6
В	M25	"/3/4"	11.1	20.2	16.9	26.0	1.25/1.6	0/0.7	71	36.0	41.6
С	M32	1/4"/ "	17.6	26.5	22.0	33.0	1.6/2.0	0/0.7	76	46.0	53.I
C2	M40	1⁄2"/   1⁄4"	23.I	32.5	28.0	41.0	1.6/2.0	0/0.7	78.1	55.0	63.5
D	M50	2"/1½"	28.9	44.4/42.3 <sup>1</sup>	36.0	52.6	1.8/2.5	0/1.0	93.1	65.0	75.I
E	M63	21⁄2"/2"	39.9	56.3/54.3 <sup>1</sup>	46.0	65.3	1.8/2.5	0/1.0	99	80.0	92.4
F	M75	3"/21/2"	50.5	68.2/65.3 <sup>1</sup>	57.0	78.0	1.8/2.5	0/1.0	101.9	95.0	109.6

### Larger cable glands available in 501/453 design style.

		,			<u> </u>						
G	M80	31⁄2"	67.0	73.0	75.0	89.5	#	#	90.6	106.4	123.0
Н	M90	31/2"	67.0	77.6	75.0	89.5	#	#	90.6	115.0	132.8
J	M100	4"	75.0	91.6	88.0	104.5	#	#	90.6	127.0	146.7

<sup>1</sup>Smaller value is applicable when selecting reduced NPT entry option.

<sup>2</sup> Sizes Os and O are available with an M16 thread size. For O size with M16 thread, the maximum cable inner sheath diameter is 10.9mm.

# Dedicated armour clamping rings are fitted. Please specify armour type and size when ordering.

### **General Information**

Os - F size metric entry threads are 1.5mm pitch as standard.

For G size glands and above, a 2mm pitch is supplied as standard.

(1.5mm pitch with 15mm length of thread can be supplied) please specify when ordering. Thread length is 15mm for sizes Os to F and

20mm for sizes G to J.

All dimensions in millimetres (except\* where dimensions are in inches).

Assembly instruction data sheet No. A.I. 372 for sizes Os to F.

Assembly instruction data sheet No. A.I. 303 for sizes G to J.

Accessories including locknuts, sealing washers, serrated washers, earth tags, shrouds, adaptors and reducers available. See pages 53 - 57.

### **Materials & Finishes**

The 153/Universal cable gland is manufactured in brass (standard), nickel plated brass, 316 stainless steel or aluminium. Brass NPT entries are nickel plated as standard.

### Cable Gland Ordering Examples Cable Gland Type/Size/Thread

e.g. 153/UNIV/C/M32 153/UNIV/C/11/4" NPT Alternative Reversible Armour Clamping Rings (RAC)

SELECTION TABLE									
Size	Steel Wire Arm	our/Braid/Tape							
Ref.	Orientation I	Orientation 2							
O/Os	0.8 - 1.0	0.4 - 0.8							
Α	0.8 - 1.0	0.4 - 0.8							
В	0.9 - 1.25	0.5 - 0.9							
С	1.2 - 1.6	0.6 - 1.2							
C2	1.2 - 1.6	0.6 - 1.2							
D	1.45 - 1.8	1.0 - 1.45							
E	1.45 - 1.8	1.0 - 1.45							
F	145-18	1.0 - 1.45							

### Application

- Outdoor or Indoor use.
- For use with single wire armoured 'W', wire braided 'X' and steel tape armoured 'Z', elastomer and plastic insulated cables.
- For particular use with :-Cables that exhibit "Cold Flow" characteristics.
- See technical section of catalogue for installation rules and regulations.

### **Features**

- Provides armour clamping using one clamping arrangement for all armour/braid types.
- Provides a diaphragm seal on the cables inner sheath which will not damage cable that has "Cold Flow" characteristics.
- Provides an outer deluge seal to prevent moisture ingress to the cable armour/braid.
- Provides a cable retention and low smoke and fume, zero halogen seal onto the cables outer sheath.

### **Technical Data**

- Construction and test standards EN 50262.
- BS 6121 Part I type E1W, E1X and E1Z.IP66, IP67 and IP68 (30 metres for 7 days)
- ingress protection to IEC 60529 & EN 60529.
  DTS01 deluge protection certified by ITS.
- Operating temperature range -60°C to +80°C as standard.

**Cable Gland with Alternative** 

Clamping Ring (AR)





# Cable Gland Type 153/RAC

## Industrial

153/RAC Cable Gland

	CABLE GLAND SELECTION TABLE											
Entry	Thread			Cabl	e Acce	eptano	e De	tails				
Entry I hread Size		lı	nner Shea	ath 'A		Ou	ter	'c	-1		Dime	agon
		St	andard	rd Alternative			ath	Armou	- r/Braid	'G'	Dime	11310113
			Seal	Sea	l (S)	'	В'		.,		Across	Acros
rietric	Std./	Min.	Max.	Min.	Max.	Min.	Max.	Orientation	Orientation		Flats	Corne

Os	M20 <sup>2</sup>	1⁄2"	3.0	8.0	-	-	5.5	12.0	0.9/1.25	0/0.7	65.I	24.0	27.7
0	M20 <sup>2</sup>	<sup>1</sup> /2"	6.5	11.9	-	-	9.5	16.0	0.9/1.25	0/0.7	65.I	24.0	27.7
Α	M20	3/4"/1/2"	10.0	14.3	8.5	13.4	12.5	20.5	0.9/1.25	0/0.7	66. I	30.0	34.6
В	M25	"/3/4"	12.5	20.2	9.5	15.4	16.9	26.0	1.25/1.6	0/0.7	71.4	36.0	41.6
С	M32	11/4"/1"	19.0	26.5	14.5	21.2	22.0	33.0	1.6/2.0	0/0.7	75.2	46.0	53.I
C2	M40	1⁄2"/   1⁄4"	25.0	32.5	22.0	28.0	28.0	41.0	1.6/2.0	0/0.7	77.1	55.0	63.5
D	M50	2"/1½"	31.5	44.4/42.3 <sup>1</sup>	27.5	34.8	36.0	52.6	1.8/2.5	0/1.0	90.3	65.0	75.I
Е	M63	21⁄2"/2"	42.5	56.3/54.3 <sup>1</sup>	39.0	46.5	46.0	65.3	1.8/2.5	0/1.0	96.7	80.0	92.4
F	M75	3"/21/2"	54.5	68.2/65.3 <sup>1</sup>	48.5	58.3	57.0	78.0	1.8/2.5	0/1.0	96	95.0	109.6

Larger cable glands available in 501/453 design style. 31/2" 75.0 89.5 # G | M80 67.0 73.0 -

31/2" -Н M90 67.0 77.6 75.0 89.5

M100 4" 75.0 91.6 -88.0 04.5 # -

<sup>1</sup>Smaller value is applicable when selecting reduced NPT entry option.

<sup>2</sup>Sizes Os and O are available with an M16 thread size. For O size with M16 thread, the maximum cable inner sheath diameter is 10.9mm.

<sup>4</sup>Deluge protection option available.

# Dedicated armour clamping rings are fitted. Please specify armour type and size when ordering.

### **General Information**

Size

Ref.

Os - F size metric entry threads are 1.5mm pitch as standard.

For G size glands and above, a 2mm pitch is supplied as standard.

(1.5mm pitch with 15mm length of thread can be supplied) please specify when ordering. Thread length is 15mm for sizes Os to F and

20mm for sizes G to J.

All dimensions in millimetres (except\* where dimensions are in inches).

Assembly instruction data sheet No. A.I. 302 for sizes Os to F.

Assembly instruction data sheet No. A.I. 329 for sizes G to J.

Accessories including locknuts, sealing washers, serrated washers, earth tags, shrouds, adaptors and reducers available. See pages 53 - 57.

### **Materials & Finishes**

The I53/RAC cable gland is manufactured in brass (standard), nickel plated brass, 316 stainless steel or aluminium.

Brass NPT entries are nickel plated as standard.

### Cable Gland Ordering Examples Cable Gland Type/Size/Thread

e.g. 153/RAC/C/M32 153/RAC/C/11/4" NPT

### Cable Gland with Alternative Seal (S)

e.g. 153/RAC/C/M32/S 153/RAC/C/11/4" NPT/S

### Alternative Reversible Armour Clamping Rings (RAC)

#

	SELECTION	TABLE
Size	Steel Wire Arm	our/Braid/Tape
Ref.	Orientation I	Orientation 2
O/Os	0.8 - 1.0	0.4 - 0.8
A	0.8 - 1.0	0.4 - 0.8
В	0.9 - 1.25	0.5 - 0.9
С	1.2 - 1.6	0.6 - 1.2
C2	1.2 - 1.6	0.6 - 1.2
D	1.45 - 1.8	1.0 - 1.45
E	1.45 - 1.8	1.0 - 1.45
F	1.45 - 1.8	1.0 - 1.45

#

#

#

95.6 106.4 123.0

95.6 115.0 132.8

95.6 127.0 146.7

### Application

Across

Corners

- Outdoor or Indoor use.
- For use with single wire armoured 'W', wire braided 'X' and steel tape armoured 'Z', elastomer and plastic insulated cables.
- See technical section of catalogue for installation rules and regulations.

### **Features**

- Provides armour clamping using one clamping arrangement for all armour/ braid types.
- Provides a seal on the cables inner sheath.
- Provides a cable retention and low smoke and fume, zero halogen seal onto the cables outer sheath.

### **Technical Data**

- Construction and test standards EN 50262. BS 6121 Part I. Type EIW, EIX and EIZ.
- IP66, IP67 and IP68 (30 metres for 7 days) ingress protection to IEC 60529, EN 60529 and NEMA 4X.
- DTS01 deluge protection certified by ITS.
- Operating temperature range -60°C to +80°C as standard.

### **Cable Gland with Alternative** Clamping Ring (AR)

e.g. 153/RAC/C/M32/AR 153/RAC/C/11/4" NPT/AR

39



### Cable Gland Type 153/RAC/L For Lead Sheath Cables

Industrial

		CA	BLE	GL	AN	D SE	ELE	СТ	ONT	ABLE			
	Entry	Throad			Cat	ole Acc	eptano	e De	tails			Hoveron	
Size	S	lize	Inne	r Lead	Sheat	h 'A'	Ou	ter	'c	2'		Dime	ensions
Ref			Standa	ard (L)	Alternative (K)		Sheath		Armour/Braid		'G'		
	Motric	NP1*	Seal+	Bond	Seal+	Bond	<u>'</u>	B'				Across	Across
	Tieuric	Option	Min.	Max.	Min.	Max.	Min.	Max.	Orientation I	Orientation 2		Flats	Corners
0	M20 <sup>2</sup>	1/2"	7.5	8.5	-	-	9.5	16.0	0.9/1.25	0/0.7	65.I	24.0	27.7
Α	M20	3/4"/1/2"	-	-	8.5	10.8	12.5	20.5	0.9/1.25	0/0.7	66. I	30.0	34.6
В	M25	"/3/4"	13.0	16.7	11.0	15.4	16.9	26.0	1.25/1.6	0/0.7	71.4	36.0	41.6
С	M32	1⁄4"/   "	19.0	22.5	15.5	21.2	22.0	33.0	1.6/2.0	0/0.7	75.2	46.0	53.I
C2	M40	1⁄2"/   1⁄4"	25.0	28.5	22.0	28.0	28.0	41.0	1.6/2.0	0/0.7	77.I	55.0	63.5
D	M50	2"/1½"	31.5	40.3	27.5	34.8	36.0	52.6	1.8/2.5	0/1.0	90.3	65.0	75.I
E	M63	21/2"/2"	42.0	52.0	39.0	46.5	46.0	65.3	1.8/2.5	0/1.0	96.7	80.0	92.4
F	M75	3"/21/2"	54.5	63.8	51.0	58.3	57.0	78.0	1.8/2.5	0/1.0	96	95.0	109.6

Larger cable glands available in 153/L design style.

						1							
G	M80	31/2"	67.0	68.5	-	-	75.0	89.5	#	#	95.6	106.4	123.0
Н	M90	31⁄2"	67.0	73.I	-	-	75.0	89.5	#	#	95.6	115.0	132.8
J	M100	4"	75.0	87.I	-	-	88.0	104.5	#	#	95.6	127.0	146.7

 $^2\,\text{Size}$  O is available with an M16 thread size. For O size with M16 thread,

the maximum cable inner sheath diameter is 10.9mm.

<sup>4</sup>Deluge protection option available.

# Dedicated armour clamping rings are fitted. Please specify armour type and size when ordering.

### **General Information**

Os - F size metric entry threads are 1.5mm pitch as standard.

For G size glands and above, a 2mm pitch is supplied as standard.

(1.5mm pitch with 15mm length of thread can be supplied) please specify when ordering.

Thread length is 15mm for sizes Os to F and

20mm for sizes G to J.

All dimensions in millimetres (except\* where dimensions are in inches). Assembly instruction data sheet No. A.I. 302 +336 for sizes Os to F. Assembly instruction data sheet

No. A.I. 329 + 336 for sizes G to J.

Accessories including locknuts, sealing washers, serrated washers, earth tags, shrouds, adaptors and reducers available. See pages 53 - 57.

### **Materials & Finishes**

The 153/RAC/L cable gland is manufactured in brass (standard), nickel plated brass, 316 stainless steel or aluminium. Brass NPT entries are nickel plated as standard.

### Alternative Reversible Armour Clamping Rings (RAC)

SELECTION TABLE									
Size	Steel Wire Arm	our/Braid/Tape							
Ref.	Orientation I	Orientation 2							
O/Os	0.8 - 1.0	0.4 - 0.8							
Α	0.8 - 1.0	0.4 - 0.8							
В	0.9 - 1.25	0.5 - 0.9							
С	1.2 - 1.6	0.6 - 1.2							
C2	1.2 - 1.6	0.6 - 1.2							
D	1.45 - 1.8	1.0 - 1.45							
E	1.45 - 1.8	1.0 - 1.45							
F	1.45 - 1.8	1.0 - 1.45							

### Cable Gland Ordering Examples Cable Gland Type/Size/Thread/

Cable Gland Type/Size/Thread/ Standard Inner Seal + Bond

e.g. 153/RAC/C/M32/L 153/RAC/C/11/4" NPT/L

Cable Gland with Alternative Inner Seal + Bond

e.g. 153/RAC/C/M32/K 153/RAC/C/1<sup>1</sup>/4" NPT/K

Cable Gland with Alternative Clamping Ring (AR)

e.g. 153/RAC/C/M32/L/AR 153/RAC/C/1<sup>1</sup>/4" NPT/L/AR

### Application

- Outdoor or Indoor use.
  For use with single wire armoured 'W', wire braided 'X'
  - and steel tape armoured 'Z', elastomer and plastic insulated cables with a lead inner sheath.
- See technical section of catalogue for installation rules and regulations.

### **Features**

- Provides armour clamping using one clamping arrangement for all armour/braid types.
- Provides a seal and an electrical bond on the cables lead inner sheath.
- Provides a cable retention and low smoke and fume, zero halogen seal onto the cables outer sheath.

### **Technical Data**

- Construction and test standards EN 50262. BS 6121 Part 1. Type E2W, E2X and E2Z.
- IP66, IP67 and IP68 (30 metres for 7 days) ingress protection to IEC 60529, EN 60529 and NEMA 4X.
- Operating temperature range -60°C to +80°C as standard.



# Cable Gland Type I 50/RAC

Industrial

	CABLE GLAND SELECTION TABLE												
	Entry	Throad	(		Hexagon Dimensions		1						
Size	S	bize	Inner Sheath Outer Sheath 'C'				'G'						
Ref.		NPT*	A	'A' 'B' /		, Di uid		Across	Across	1			
	Metric	Std./ Option	Max.	Max.	Orientation I	Orientation 2		Flats	Corners				
0	M20 <sup>2</sup>	1/2"	11.9	16.0	0.9/1.25	0/0.7	47.5	24.0	27.7	1			
Α	M20	3/4"/1/2"	14.3	20.5	0.9/1.25	0/0.7	47.5	30.0	34.6	1			
В	M25	"/3/4"	20.2	26.0	1.25/1.6	0/0.7	50.8	36.0	41.6	1			
С	M32	11⁄4"/1"	26.5	33.0	1.6/2.0	0/0.7	54.9	46.0	53.I	1			
C2	M40	1⁄2"/   1⁄4"	32.5	41.0	1.6/2.0	0/0.7	64.4	55.0	63.5	1			
D	M50	2"/1½"	44.4/42.3 <sup>1</sup>	52.6	1.8/2.5	0/1.0	68.5	65.0	75.I	1			
E	M63	21/2"/2"	56.3/54.3 <sup>1</sup>	65.3	1.8/2.5	0/1.0	70.1	80.0	92.4	1			
F	M75	3"/21/2"	68.2/65.3 <sup>1</sup>	78.0	1.8/2.5	0/1.0	72.3	95.0	109.6				

Smaller value is applicable when selecting reduced NPT entry option.

<sup>2</sup> Size O is available with an M16 thread size. For O size with M16 thread, the maximum cable inner sheath diameter is 10.9mm.

### **General Information**

O - F size metric entry threads are 1.5mm pitch as standard.

(1.5mm pitch with 15mm length of thread can be supplied) please specify when ordering. Thread length is 15mm for sizes Os to F. All dimensions in millimetres (except\* where dimensions are in inches).

Assembly instruction data sheet No. A.I. 325.

Alternative Reversible Armour
Clamping Rings (RAC)

SELECTION TABLE										
Size	Steel Wire Armour/Braid/Tape									
Ref.	Orientation I	Orientation 2								
O/Os	0.8 - 1.0	0.4 - 0.8								
Α	0.8 - 1.0	0.4 - 0.8								
В	0.9 - 1.25	0.5 - 0.9								
С	1.2 - 1.6	0.6 - 1.2								
C2	1.2 - 1.6	0.6 - 1.2								
D	1.45 - 1.8	1.0 - 1.45								
E	1.45 - 1.8	1.0 - 1.45								
F	1.45 - 1.8	1.0 - 1.45								

Accessories including locknuts, sealing washers, serrated washers, earth tags, shrouds, adaptors and reducers available. See pages 53 - 57.

### **Materials & Finishes**

The 150/RAC cable gland is manufactured in brass (standard), nickel plated brass, 316 stainless steel or aluminium. Brass NPT entries are nickel plated as standard.

### Cable Gland Ordering Examples Cable Gland Type/Size/Thread

e.g. 150/RAC/C/M32 150/RAC/C/1<sup>1</sup>/4" NPT

### Cable Gland with Alternative Clamping Ring (AR)

e.g. 150/RAC/C/M32/AR 150/RAC/C/11/4" NPT/AR

### Application

- Outdoor or Indoor use.
- For use with single wire armoured 'W', wire braided 'X' and steel tape armoured 'Z', elastomer and plastic insulated cables.
- See technical section of catalogue for installation rules and regulations.

### Features

 Provides armour clamping using one clamping arrangement for all armour/braid types.

### **Technical Data**

 Construction and test standards BS 6121 Part 1. Type BW, BX and BZ.





# Cable Gland Type I 5 I/RAC

Industrial

		CA	ABLE GLA	ND S	SELEC	OITO	<b>NTAB</b>	LE			
	Entry	Thread	C	Cable Aco	ceptance	Details			Hos	(2000	
Size	S	Size	Inner Sheath	Outer	Sheath	'C Armou	: r/Braid	'G'	Dimensions		
Ref.	M	NPT*	~		D				Across	Across	
Metric		Std./ Option	Max.	Min.	Max.	Orientation I	Orientation 2		Flats	Corners	
Os	M20 <sup>2</sup>	1/2"	8.0	5.5	12.0	0.9/1.25	0/0.7	65.I	24.0	27.7	
0	M20 <sup>2</sup>	1⁄2"	11.9	9.5	16.0	0.9/1.25	0/0.7	65.I	24.0	27.7	
Α	M20	3/4"/1/2"	14.3	12.5	20.5	0.9/1.25	0/0.7	66. I	30.0	34.6	
В	M25	"/3/4"	20.2	16.9	26.0	1.25/1.6	0/0.7	71.4	36.0	41.6	
С	M32	1⁄4"/ "	26.5	22.0	33.0	1.6/2.0	0/0.7	75.2	46.0	53.I	
C2	M40	1⁄2"/   1⁄4"	32.5	28.0	41.0	1.6/2.0	0/0.7	77.I	55.0	63.5	
D	M50	2"/1½"	44.4/42.3 <sup>1</sup>	36.0	52.6	1.8/2.5	0/1.0	90.3	65.0	75.I	
E	M63	21⁄2"/2"	56.3/54.3 <sup>1</sup>	46.0	65.3	1.8/2.5	0/1.0	96.7	80.0	92.4	
F	M75	3"/21/2"	68.2/65.3 <sup>1</sup>	57.0	78.0	1.8/2.5	0/1.0	96.0	95.0	109.6	

Larger cable glands available in 151 design.

Laige													
G	M80	31⁄2"	72.0	75.0	89.5	#	#	95.6	106.4	123.0			
Н	M90	31/2"	80.0	75.0	89.5	#	#	95.6	115.0	132.8			
J	M100	4"	90.0	88.0	104.5	#	#	95.6	127.0	146.7			

 $^{\rm I}\,{\rm Smaller}$  value is applicable when selecting reduced NPT entry option.

<sup>2</sup> Sizes Os and O are available with an M16 thread size. For O size with M16 thread,

, the maximum cable inner sheath diameter is 10.9mm.

<sup>4</sup>Deluge protection option available.

# Dedicated armour clamping rings are fitted. Please specify armour type and size when ordering.

### **General Information**

Os - F size metric entry threads are 1.5mm pitch as standard.

For G size glands and above, a 2mm pitch is supplied as standard.

(1.5mm pitch with 15mm length of thread can be supplied) please specify when ordering.

Thread length is 15mm for sizes Os to F and 20mm for sizes G to J.

All dimensions in millimetres (except\* where dimensions are in inches).

Assembly instruction data sheet No. A.I. 308 for sizes Os to F.

Assembly instruction data sheet No. A.I. 314 for sizes G to J.

Accessories including locknuts, sealing washers, serrated washers, earth tags, shrouds, adaptors and reducers available. See pages 53 - 57.

### Materials & Finishes

The 151/RAC cable gland is manufactured in brass (standard), nickel plated brass, 316 stainless steel or aluminium. Brass NPT entries are nickel plated as standard.

### Cable Gland Ordering Examples

Cable Gland Type/Size/Thread

e.g. 151/RAC/C/M32 151/RAC/C/1<sup>1</sup>/4" NPT

Connection Solutions

www.ehawke.com

Cable Gland with Alternative Clamping Ring (AR)

e.g. 151/RAC/C/M32/AR 151/RAC/C/1'/4" NPT/AR

### Application

- Outdoor or Indoor use.
- For use with single wire armoured 'W', wire braided 'X' and steel tape armoured 'Z', elastomer and plastic insulated cables.
- See technical section of catalogue for installation rules and regulations.

### Features

- Provides armour clamping using one clamping arrangement for all armour/braid types.
- Provides a cable retention and low smoke and fume, zero halogen seal onto the cables outer sheath.

### **Technical Data**

- Construction and test standards EN 50262. BS 6121 Part 1. Type CW, CX and CZ.
- IP66 ingress protection to IEC 60529 and EN 60529.
- Operating temperature range -60°C to +80°C as standard.

Alternative Reversible Armour

Orientation I

0.8 - 1.0

0.8 - 1.0

0.9 - 1.25

1.2 - 1.6

1.45 - 1.8

1.45 - 1.8

1.45 - 1.8

SELECTION TABLE

Steel Wire Armour/Braid/Tape

Orientation 2

0.4 - 0.8

0.4 - 0.8

0.5 - 0.9

0.6 - 1.2

06 - 12

1.0 - 1.45

10-145

1.0 - 1.45

Clamping Rings (RAC)

Size

Ref.

O/Os

А

В

C C2

D

Е

F



I5I/RAC Cable Gland



# Cable Gland Type II4 (E Industrial

		CABL	E GI	LAN	D S	ELECT	101	NTA	BL			
	Male	Entry	Fomalo	Entry	Cab	le Acceptar	nce De	etails		Llas		
<u>.</u> .	Thre	ad Size	Threa	d Size	(	Outer Shea	ath 'B'			Dime	cagon	
Size	Ref.				St	andard	Alter	native	'G'	Dimensions		
Rei.	Maénia	NPT*	Motric	NPT		Seal	Sea	l (S)		Across	Across	
	Metric Std./ Option		Theuric	#	Min.	Max.	Min.	Max.		Flats	Corners	
А	M20	3/4"/1/2"	M20	-	11.0	14.3	8.5	13.4	63.9	30.0	34.6	
В	M25	"/3/4"	M25	-	13.0	20.2	9.5	15.4	52.8	36.0	41.6	
С	M32	1/4"/ "	M32	-	19.0	26.5	15.5	21.2	69.5	46.0	53.I	
C2	M40	1⁄2"/   1⁄4"	M40	-	25.0	32.5	22.0	28.0	72.3	55.0	63.5	
D	M50	2"/1½"	M50	-	31.5	44.4/42.3 <sup>1</sup>	27.5	34.8	92.8	65.0	75.I	
Е	M63	21⁄2"/2"	M63	-	42.5	56.3/54.3 <sup>1</sup>	39.0	46.5	93.2	80.0	92.4	
F	M75	3"/21/2"	M75	-	54.5	68.2/65.3 <sup>1</sup>	48.5	58.3	94.9	95.0	109.6	

<sup>1</sup>Smaller value is applicable when selecting reduced NPT entry option. # NPT female thread sizes equivalent to those shown in the table for the male thread size are available. Hexagon dimensions as shown may alter.

### **General Information**

A - F size metric entry threads are 1.5mm pitch as standard. (1.5mm pitch with 15mm length of thread can be supplied) please specify

when ordering.

Thread length is 15mm for sizes A to F.

All dimensions in millimetres (except\* where dimensions are in inches). Assembly instruction data sheet No. A.I. 310.

Accessories including locknuts, sealing washers, serrated washers, earth tags, shrouds, adaptors and reducers available. See pages 53 - 57.

### **Materials & Finishes**

The 114 cable gland is manufactured in brass (standard), nickel plated brass, 316 stainless steel or aluminium. Brass NPT entries are nickel plated as standard.

### **Cable Gland Ordering Examples**

Cable Gland Type/Size/MaleThread/Female Thread

e.g. 114/C/M32/M32 114/C/1<sup>1</sup>/4" NPT/M32

### Cable Gland with Alternative Seal (S)

e.g. 114/C/M32/M32/S 114/C/11/4" NPT/M32/S

### Application

- Outdoor or Indoor use.
- For use with non-armoured elastomer and plastic insulated cables installed in conduit.
- See technical section of the catalogue for installation rules and regulations.

### Features

- Provides a cable retention seal onto the cables outer sheath.
- Provides female running coupler for cable gland or conduit entry.

### **Technical Data**

- Construction and test standards EN 50262.
- IP66, IP67 and IP68 (30 metres for 7 days) ingress protection to IEC 60529 and EN 60529.
- Operating temperature range -60°C to +100°C as standard.



# North American Series Cable Glands/Connectors



Connection Solutions www.ehawke.com





Explosion Proof and General Purpose







### Unique Rear Sealing System

This arrangement offers IP66, IP67, IP68 (30 metres for 7 days), NEMA 4X and Deluge (DTS01) Ingress Protection. The seal is manufactured from a silicone material, has LSFZH properties, is ozone and oil resistant and is suitable for use at both high and low temperatures.

The Rear Sealing System covers the entire range of cable diameters without the need for special seals and the cable acceptance range is stamped on the backnut for ease of inspection. The backnut can be hand tightened, with only one further spanner turn required to ensure IP66, IP67, IP68 and NEMA 4X.

### • Armour Grounding Device

This device provides 360° armour grounding which is fully inspectable. The grounding device is unique in that it remains in contact with the metal cable jacket when the cable gland/connector is disassembled for inspection.

### • Inspectable Deluge Seal

Hawke's inspectable deluge seal offers IP66 and IP67 sealing and is certified as 'deluge proof' by ITS in accordance with DTS01. Indeed Hawke's deluge seal is so good that it exceeds the expectations of the offshore industry by not only preventing ingress into the equipment, but also into the cable gland/connector, which could potentially corrode the cable armour. The deluge seal is coloured red for hazardous location products and black for industrial general purpose products.

















# Cable Gland/Connector Type 710 CUS Explosion Proof

CA	BLE	GLAI	ND/C	ONN	IECT	OR S	ELE	СТІС		ABLE		
	Entry Th	aroad	C	able Acc	eptance l	Details			Hav	2000		
5:	Size		Inner Jacket/Cores			Outer			Dimensions			
Ref.	NIDT	-	'D'	'E'	Max.	Jac	Jacket					
	Std./	Metric	Max. Max. No. Over Inner Of		No. Of	1	3.		Across	Across		
	Option	*	Cores	Jacket	Cores	Min.	Max.		Flats	Corners		
Os	1/2"	M20 <sup>2</sup>	0.35"	0.39"	6	0.22"	0.47"	2.81"	0.94"	1.09"		
0	1/2"	M20 <sup>2</sup>	0.35"	0.39"	6	0.37"	0.63"	2.81"	0.94"	1.09"		
А	1/2"/3/4"	M20	0.43"	0.64"	10	0.49"	0.81"	2.84"	1.18"	1.36"		
В	3⁄4"/ "	M25	0.64"	0.93"	21	0.66"	I.02"	2.95"	1.42"	1.64"		
С	"/ '/4"	M32	0.86"	1.23"	42	0.87"	1.30"	3.11"	1.81"	2.09"		
C2	1/4"/   1/2"	M40	1.04"	1.59"	60	1.10"	1.61"	3.26"	2.17"	2.50"		
D	2"/1½"	M50	1.46"	1.96"	80	1.42"	2.07"	3.36"	2.56"	2.96"		
Е	21/2"/2"	M63	1.88"	2.55"	100	1.81"	2.57"	3.56"	3.15"	3.64"		
F	3"/21/2"	M75	2.32"	2.98"	120	2.24"	3.07"	3.76"	3.74"	4.31"		
'H' siz	H' size cable gland/connector available											

Contact Hawke International for further details.

Н	31⁄2"	M90	2.79"	3.12"	-	3.07"	3.52"	3.54"	4.18"	4.84"

<sup>2</sup>Sizes Os and O are available with an M16 thread size. For O size with M16 thread, the maximum cable inner sheath diameter is 0.43".

### **General Information**

Os - F size metric entry threads are 1.5mm pitch as standard. For H size glands and above, a 2mm pitch is supplied as standard. (1.5mm pitch with 15mm length of thread can be supplied) please specify when ordering.

Thread length is 15mm for sizes Os to F and 20mm for size H. All dimensions in inches (except\* where dimensions are in millimetres). Two part sealing compound and assembly instructions are supplied with the cable gland.

Assembly instruction data sheet No. A.l. 316 for sizes Os to F. Assembly instruction data sheet No. A.l. 337 for size H.  $\!$ 

Accessories including locknuts, sealing washers, serrated washers, earth tags, shrouds, adaptors and reducers available. See pages 53 - 57.

### **Materials & Finishes**

The 710 cable gland/connector is manufactured in brass (standard), nickel plated brass, 316 stainless steel or aluminium. Brass NPT entries are nickel plated as standard.

### Cable Gland/Connector Ordering Examples Cable Gland/Connector Type/Size/Thread

e.g. 710/C/1" NPT

### Application

- Outdoor or Indoor use.
- For use with non-armoured cable, as permitted by the NEC.
- See technical section of the catalogue for installation rules and regulations.

### **Features**

- Provides a barrier seal between the individual insulated conductors within the cable and prevents entry of the products of an explosion into the cable.
- Assembly of the cable gland/connector compresses and distributes the compound evenly to effect a barrier seal at the point of entry into the enclosure.
- Provides an outer deluge seal to prevent moisture ingress to the cable armour and enclosure.

Deluge seal is coloured red to indicate Hazardous Locations product.

 Provides a cable retention and low smoke and fume, zero halogen seal onto the cables outer jacket.

### **Technical Data**

- UL Listed for use in Class I, Division 2, Gas Groups A, B, C and D.
- UL Listed for use in Class I, Zone 2, Gas Groups IIA, IIB and IIC.
- UL listed AExd IIC and AExe II Class 1, Zone 2.
- Construction and test standards
   c (U)<sub>US</sub> UL Listed hazardous locations in USA and Canada. E84940.
- IP66, IP67 and IP68 (30 metres for 7 days) ingress protection to IEC 60529, EN60529 and NEMA 4X.
- DTS01 deluge tested by ITS.
- Operating temperature range -50°C to +60°C as standard.
- Alternative Certification Options Available.
- 🔸 🕍 Marine Approval.



Connection Solutions www.ehawke.com





# Cable Gland/Connector Type 711 Class 1 Division 1



### CABLE GLAND/CONNECTOR SELECTION TABLE

	Entry TI	Entry Thread		Cable	Accept	ance [	Details			Hexagon Dimensions		
C:	Size		Inn	ier Jack	et/Cor	es	Outer					
Size			'D'	Arm	Armour		Jacket		'G'	Bintensions		
Rei.	NPT	Metric	Max.	Jacke	et 'E'	No. Of	'B'			Across	Across	
	Option	*	Cores	Min.	Max.	Cores	Min.	Max.		Flats	Corners	
Α	1/2"/3/4"	M20	0.43"	0.41"	0.64"	10	0.49"	0.81"	2.74"	1.18"	1.36"	
В	<sup>3</sup> /4"/ "	M25	0.64"	0.49"	0.93"	21	0.66"	1.02"	2.95"	I.42"	1.64"	
С	"/ 1⁄4"	M32	0.86"	0.85"	1.23"	42	0.87"	1.30"	3.04"	1.81"	2.09"	
C2	1/4"/   1/2"	M40	1.04"	1.17"	1.59"	60	1.10"	1.61"	3.09"	2.17"	2.50"	
D	2"/1½"	M50	1.46"	1.37"	1.96"	80	1.42"	2.07"	3.37"	2.56"	2.96"	
E	21/2"/2"	M63	1.88"	1.76"	2.55"	100	1.81"	2.57"	3.65"	3.15"	3.64"	
F	3"/21/2"	M75	2.32"	2.29"	2.98"	120	2.24"	3.07"	3.73"	3.74"	4.31"	

'H' size cable gland/connector available.

Contact Hawke International for further details.

### **General Information**

A - F size metric entry threads are 1.5mm pitch as standard. For H size glands and above, a 2mm pitch is supplied as standard. (1.5mm pitch with 15mm length of thread can be supplied) please specify when ordering.

Thread length is 15mm for sizes A to F and 20mm for size H. All dimensions in inches (except\* where dimensions are in millimetres). Two part sealing compound and assembly instructions are supplied with the cable gland.

Assembly instruction data sheet No. A.I. 317 for sizes Os to F. Assembly instruction data sheet No. A.I. 338 for size H.  $\!$ 

Accessories including locknuts, sealing washers, serrated washers, earth tags, shrouds, adaptors and reducers available. See pages 53 - 57.

### **Materials & Finishes**

The 711 cable gland/connector is manufactured in brass (standard), nickel plated brass, 316 stainless steel or aluminium. Brass NPT entries are nickel plated as standard.

### Cable Gland/Connector Ordering Examples

Cable Gland/Connector Type/Size/Thread

e.g. 711/C/1" NPT

### Application

- Outdoor or Indoor use.
- For use with continuous corrugated aluminium, Metal Clad (MCHL) cable.
- See technical section of the catalogue for installation rules and regulations.

### Features

- Provides 360° armour grounding which is fully inspectable.
- Grounding Device remains in contact with cable when disassembled for inspection.
- Provides a barrier seal between the individual insulated cores within the cable and prevents entry of the products of an explosion into the cable.
- Assembly of the cable gland/connector compresses and distributes the compound evenly to create a barrier seal at the point of entry into the enclosure.
- Provides an outer deluge seal to prevent moisture ingress to the cable armour and enclosure. Deluge seal is coloured red to indicate Hazardous Location product.
- Provides a cable retention and low smoke and fume, zero halogen seal onto the cables outer jacket.

### **Technical Data**

- UL Listed for use in Class I, Division I, Gas Groups A, B, C and D.
- UL Listed for use in Class I, Zone I, Gas Groups IIA, IIB and IIC.
- UL Listed AExd IIC and AExe II Class I, Zone I.

• Construction and test standards CONSTRUCTION OF CONTROL OF CONT

- IP66, IP67 and IP68 (30 metres for 7 days) ingress protection to IEC 60529, EN60529 and NEMA 4X.
- DTS01 deluge tested by ITS.
- Operating temperature range -50°C to +60°C as standard.
- Alternative Certification Options available .
  - 👪 Marine Approval.
    - Marine Approval.

For Class I, Division 2 MC cable applications, the 713 cable gland/connector is available. Details and sizes are the same as the 711.





# **Cable Gland/Connector Type**



**153 Cable Gland/Connector** 

C	ABLE	GL	ANI	D/CON	NE	СТ	OR	SELECT	ION	ITAI	BLE	
	EnterryTh	wood		Cable	Acce	eptanc	e Deta	ils				
Size	Size	iread e		Inner Jacket/ Cores		Oı Jac	iter ket	'C'	'G'	Dimensions		
Ket.	NPT Std./ Option	Metric *	'D' Max. Over Cores	<b>'E'</b> Max. Inner Jacket	Max. No. Of Cores	'B' Min. Max.		Braid		Across Flats	Across Corners	
Os	1⁄2"	M20 <sup>2</sup>	0.35"	0.46"	6	0.22"	0.47"	0.008"/0.013"	2.80"	0.94"	1.09"	
0	1/2"	M20 <sup>2</sup>	0.35"	0.46"	6	0.37"	0.63"	0.008"/0.013"	2.80"	0.94"	1.09"	
Α	<sup>1</sup> /2"/3/4"	M20	0.43"	0.49"	10	0.49"	0.81"	0.008"/0.013"	2.83"	1.18"	1.36"	
В	3/4"/ "	M25	0.64"	0.72"	21	0.66"	1.02"	0.008"/0.013"	2.94"	1.42"	I.64"	
С	"/ 1⁄4"	M32	0.86"	0.97"	42	0.87"	1.30"	0.008"/0.013"	3.10"	1.81"	2.09"	
C2	1/4"/   1/2"	M40	1.04"	1.16"	60	1.10"	1.61"	0.008"/0.013"	3.26"	2.17"	2.50"	
D	2"/1½"	M50	1.46"	1.64"	80	I.42"	2.07"	0.008"/0.013"	3.35"	2.56"	2.96"	
E	21/2"/2"	M63	1.88"	2.11"	100	1.81"	2.57"	0.008"/0.013"	3.56"	3.15"	3.64"	•
F	3"/21/2"	M75	2.32"	2.61"/2.57" <sup> </sup>	120	2.24"	3.07"	0.008"/0.013"	3.76"	3.74"	4.31"	

'H' size cable gland/connector available.

Contact Hawke International for further details.

Н 31/2" M90 2.79" 3.05" -3.07" 3.52" 0.008"/0.013" 3.54" 4.18" 4.84"

<sup>1</sup>Smaller value is applicable when selecting reduced NPT entry option.

<sup>2</sup> Sizes Os and O are available with an M16 thread size. For O size with M16 thread, the maximum cable inner sheath diameter is 0.43".

### **General Information**

Os - F size metric entry threads are 1.5mm pitch as standard. For H size glands and above, a 2mm pitch is supplied as standard. (1.5mm pitch with 15mm length of thread can be supplied) please specify when ordering.

Thread length is 15mm for sizes Os to F and 20mm for size H. All dimensions in inches (except\* where dimensions are in millimetres). Two part sealing compound and assembly instructions are supplied with the cable gland.

Assembly instruction data sheet No. A.I. 318 for sizes Os to F. Assembly instruction data sheet No. A.I. 339 for size H.

Accessories including locknuts, sealing washers, serrated washers, earth tags, shrouds, adaptors and reducers available. See pages 53 - 57.

### **Materials & Finishes**

The 753 cable gland/connector is manufactured in brass (standard), nickel plated brass, 316 stainless steel or aluminium. Brass NPT entries are nickel plated as standard.

### Cable Gland/Connector Ordering Examples Cable Gland/Connector Type/Size/Thread

e.g. 753/C/1" NPT

### **Application**

- Dutdoor or Indoor use.
- or use with braid armoured marine hipboard jacketed or non-jacketed able.
- See technical section of the catalogue or installation rules and regulations.

### atures

- Provides a barrier seal between the individual insulated conductors within the cable and prevents entry of the products of an explosion into the cable.
- Assembly of the cable gland/connector compresses and distributes the compound evenly to effect a barrier seal at the point of entry into the enclosure.
- Provides an outer deluge seal to prevent moisture ingress to the cable armour and enclosure. Deluge seal is coloured red to indicate Hazardous Location product.
- Provides a cable retention and low smoke and fume, zero halogen seal onto the cables outer jacket.

### **Technical Data**

- UL Listed for use in Class I, Division I, Gas Groups A, B, C and D.
- UL Listed for use in Class I, Zone I and Zone 2, Gas Groups IIA, IIB and IIC.
- UL Listed AExd IIC and AExe II Class 1, Zone 1.
- Construction and test standards

C UL Listed hazardous locations in USA and Canada. E84941.

- IP66, IP67 and IP68 (30 metres for 7 days) ingress protection to IEC 60529, EN60529 and NEMA 4X.
- DTS01 deluge tested by ITS.
- Operating temperature range -50°C to +60°C as standard.
- Alternative Certification Options available .
  - 🚨 Marine Approval.





'G' Approx (Compressed Length) Nickel Plated Armou Hu

### **Explosion** Proof **CABLE GLAND/CONNECTOR SELECTION TABLE** Cable Acceptance Details Entry Thread Hexagon Inner Jacket/ Outer 'C' Size Dimensions Size Cores Jacket 'G' Ref. 'D 'F Max. NPT 'B' Steel Wire Metric No. Across Across Max. Max. Std./ Braid Таре Over Inner Of Armour Max. Flats Corners Min. Option lacket Cores Core Os 6 0.94" 1.09" 1/2" M20<sup>2</sup> 0.35 0.46' 0.22" 0.47' 0.036"/0.049" 0.008"/0.013" 0.008"/0.031" 2.80' 0 1/2" 6 0.37" 0.036"/0.049" 0.008"/0.013" 0.008"/0.031" 2.80' 0.94" 1.09" M20<sup>2</sup> 0.35' 0.46" 0.63" А 1/2"/3/4" M20 0.43' 0.49" 10 0.49" 0.81 0.036"/0.049" 0.008"/0.013" 0.008"/0.031" 2.83' 1.18" 1.36" 0.72" 1.02' 0.049"/0.062" 0.008"/0.013" 0.008"/0.039" 1.64" 3/4"/|" M25 0.64' 21 0.66" 2.94" 1.42" В 1"/11/4" 0.97" 0.062"/0.078" 0.008"/0.013" 2.09" С M32 0.86' 42 0.87" 1.30" 0.008"/0.055" 3.10" 1.81" C2 | 1/4"/ | 1/2" 1.04" 1.16" 1.10" 1.61 0.062"/0.078" 0.008"/0.013" 0.008"/0.070" 3.26' 2.17" 2.50" M40 60 0.078"/0.098" 0.008"/0.013" D 2"/11/2" M50 80 1.42" 0.008"/0.070" 2.56' 2.96" 1.46" 1.64" 2.07' 3.35" Е 21/2"/2" 1.88" 100 0.098" 0.008"/0.013" 0.008"/0.070" 3.15" M63 2.11" 1.81" 2.57" 3.56" 3.64"

0.098"

0.008"/0.013"

2.32" 2.61"/2.57" <sup>1</sup>Smaller value is applicable when selecting reduced NPT entry option.

<sup>2</sup>Sizes Os and O are available with an M16 thread size. For O size with M16 thread, the maximum cable inner sheath diameter is 0.43".

120 2.24" 3.07"

### **General Information**

M75

F

3"/21/2"

Os - F size metric entry threads are 1.5mm pitch as standard. Thread length is 15mm for sizes Os to F. All dimensions in inches (except\* where dimensions are in millimetres).

Two part sealing compound and assembly instructions are supplied with the cable gland.

Assembly instruction data sheet No. A.I. 319.

Accessories including locknuts, sealing washers, serrated washers, earth tags, shrouds, adaptors and reducers available. See pages 53 - 57.

### Materials & Finishes

The 753 cable gland/connector is manufactured in brass (standard), nickel plated brass, 316 stainless steel or aluminium. Brass NPT entries are nickel plated as standard.

### Cable Gland/Connector Ordering Examples Cable Gland/Connector Type/Size/Thread

e.g. 755/C/1" NPT

Alternative Certification Options available.

🎎 Marine Approval.

ABS Marine Approval.

### Application

Outdoor or Indoor use.

0.008"/0.070" 3.76"

For use with armoured jacketed cable, as permitted by the NEC.

**Cable Gland/Connector Type** 

See technical section of the catalogue for installation rules and regulations.

### Features

 Provides a barrier seal between the individual insulated conductors within the cable and prevents entry of the products of an explosion into the cable.

3.74"

4.31"

**755 Cable Gland/Connector** 

- Assembly of the cable gland/connector compresses and distributes the compound evenly to effect a barrier seal at the point of entry into the enclosure.
- Provides an outer deluge seal to prevent moisture ingress to the cable armour and enclosure. Deluge seal is coloured red to indicate Hazardous Location product.
- Provides a cable retention and low smoke and fume, zero halogen seal onto the cables outer jacket.

### **Technical Data**

- UL Listed for use in Class I. Division 2. Gas Groups A, B, C and D.
- UL Listed for use in Class I, Zone 2, Gas Groups IIA, IIB and IIC.
- UL Listed AExd IIC and AExe II Class 1, Zone 2.
- Construction and test standards Iocations in USA and Canada. E84940.
- IP66, IP67 and IP68 (30 metres for 7 days) ingress protection to IEC 60529, EN60529 and NEMA 4X.
- DTS01 deluge tested by ITS.
- Operating temperature range -50°C to +60°C as standard.



Cable Gland/Connector Type I 53/X



	CABLE GLAND/CONNECTOR SELECTION TABLE													
	Entry Th	rood			Cable	Acceptar	nce Deta	ails			Havagan			
<u>.</u>	Size	read		Inner Jack	(et'A'		'C'		Hexagon					
Size	0120		St	andard	Alternative		Outer Jacket			'G'	Dimensions			
Ref.	NPT	Metric		Seal	Sea	l (S)		D	Braid		Across	Across		
	Std./ Option	*	Min.	Max.	Min.	Max.	Min.	Max.	Draid		Flats	Corners		
Os	1/2"	M20 <sup>2</sup>	0.12"	0.31"	-	-	0.22"	0.47"	0.008"/0.013"	2.56"	0.94"	1.09"		
0	!⁄2"	M20 <sup>2</sup>	0.30"	0.46"	-	-	0.37"	0.63"	0.008"/0.013"	2.56"	0.94"	1.09"		
Α	1/2"/3/4"	M20	0.44"	0.56"	0.34"	0.52"	0.49"	0.81"	0.008"/0.013"	2.60"	1.18"	1.36"		
В	3/4"/ "	M25	0.52"	0.79"	0.38"	0.60"	0.66"	1.02"	0.008"/0.013"	2.81"	1.42"	1.64"		
С	1"/11⁄4"	M32	0.75"	1.04"	0.61"	0.83"	0.87"	1.30"	0.008"/0.013"	2.96"	1.81"	2.09"		
C2	1/4"/   1/2"	M40	0.99"	I.27"	0.87"	1.10"	1.10"	1.61"	0.008"/0.013"	3.04"	2.17"	2.50"		
D	2"/1½"	M50	1.24"	1.74"/1.67"	1.09"	I.37"	1.42"	2.07"	0.008"/0.013"	3.54"	2.56"	2.96"		
Е	21/2"/2"	M63	1.68"	2.21"/2.14"	1.54"	1.83"	1.81"	2.57"	0.008"/0.013"	3.81"	3.15"	3.64"		
F	3"/21/2"	M75	2.15"	2.68"/2.57"1	1.91"	2.29"	2.24"	3.07"	0.008"/0.013"	3.78"	3.74"	4.31"		

Contact Hawke International for further details.

H 3<sup>1</sup>/<sub>2</sub>" M90 2.64" 3.06" - - 2.96" 3.52" 0.008"/0.013" 4.8" 4.53" 5.23"

<sup>1</sup> Smaller value is applicable when selecting reduced NPT entry option.

<sup>2</sup> Sizes Os and O are available with an M16 thread size. For O size with M16 thread, the maximum cable inner sheath diameter is 0.43".

### **General Information**

Os - F size metric entry threads are 1.5mm pitch as standard. For H size glands and above, a 2mm pitch is supplied as standard. (1.5mm pitch with 15mm length of thread can be supplied) please specify when ordering.

Thread length is 15mm for sizes Os to F and 20mm for size H. All dimensions in inches (except\* where dimensions are in millimetres). Assembly instruction data sheet No. A.I. 341.

Accessories including locknuts, sealing washers, serrated washers, earth tags, shrouds, adaptors and reducers available. See pages 53 - 57.

### **Materials & Finishes**

The 153/X cable gland/connector is manufactured in brass (standard), nickel plated brass, 316 stainless steel or aluminium. Brass NPT entries are nickel plated as standard.

### Cable Gland/Connector Ordering Examples Cable Gland/Connector Type/Size/Thread

e.g. 153/CX/M32 153/CX/1" NPT

Cable Gland/Connector with Alternative Seal (S)

e.g. 153/CX/M32/S 153/CX/1" NPT/S

### Application

- Outdoor or Indoor use.
- For use with armoured marine shipboard jacketed or non-jacketed cable.
- See technical section of the catalogue for installation rules and regulations.

### Features

- Provides armour clamping for marine shipboard cable.
- Provide a seal on the cables inner jacket.
- Provides an outer deluge seal to prevent moisture ingress to the cable armour and enclosure.
- Provides a cable retention and low smoke and fume, zero halogen seal onto the cables outer jacket.

### **Technical Data**

- Construction and test standards
   CUUUS UL Listed wet locations. E218332.
- IP66, IP67 and IP68 (30 metres for 7 days) ingress protection to IEC 60529, EN60529 and NEMA 4X.
- DTS01 deluge tested by ITS.
- Operating temperature range -50°C to +60°C as standard.
- Alternative Certification Options available .
- 🎎 Marine Approval.
  - Marine Approval.

**General Purpose** 





# Cable Gland/Connector Type 70 I CUUS General Purpose

C	CABLE GLAND/CONNECTOR SELECTION TABLE													
	Entry Th	aread	Cat	ole Accep	tance De	tails		Нах	agon					
Size	Size	2	Armou	r Jacket	Outer	Jacket	'G'	Dimensions						
Ret.	NPT	Metric		2	E	5		Across	Across					
	Std./ Option	*	Min.	Max.	Min.	Max.		Flats	Corners					
А	1/2"/3/4"	M20	0.41"	0.64"	0.49"	0.81"	2.74"	1.18"	I.36"					
В	3⁄4"/ "	M25	0.49"	0.93"	0.66"	1.02"	2.95"	1.42"	I.64"					
С	"/ 1⁄4"	M32	0.85"	1.23"	0.87"	1.30"	3.04"	1.81"	2.09"					
C2	1⁄4"/   1⁄2"	M40	1.17"	1.59"	1.10"	1.61"	3.09"	2.17"	2.50"					
D	2"/1½"	M50	1.37"	1.96"	I.42"	2.07"	3.37"	2.56"	2.96"					
Е	21/2"/2"	M63	1.76"	2.55"	1.81"	2.57"	3.65"	3.15"	3.64"					
F	3"/21/2"	M75	2.29" 2.98"		2.24"	3.07"	3.73"	3.74"	4.31"					

'H' size cable gland/connector available.

Contact Hawke International for further details.

H 3 <sup>1</sup> / <sub>2</sub> " M90 2.93" 3.47" 3.07" 3.52" 4.33" 4.18"											
	H	ł	31/2"	M90	2.93"	3.47"	3.07"	3.52"	4.33"	4.18"	4.84"

### **General Information**

A - F size metric entry threads are 1.5mm pitch as standard. For H size glands and above, a 2mm pitch is supplied as standard. (1.5mm pitch with 15mm length of thread can be supplied) please specify when ordering.

Thread length is 15mm for sizes A to F and 20mm for size H. All dimensions in inches (except\* where dimensions are in millimetres). Assembly instruction data sheet No. A.I. 315 for sizes Os to F. Assembly instruction data sheet No. A.I. 342 for size H.

Accessories including locknuts, sealing washers, serrated washers, earth tags, shrouds, adaptors and reducers available. See pages 53 - 57.

### **Materials & Finishes**

The 701 cable gland/connector is manufactured in brass (standard), nickel plated brass, 316 stainless steel or aluminium. Brass NPT entries are nickel plated as standard.

### Cable Gland/Connector Ordering Examples Cable Gland/Connector Type/Size/Thread

e.g. 701/C/1" NPT

### Application

- Outdoor or Indoor use.
- For use with continuous corrugated aluminium and interlocked steel Metal Clad, MCHL and Teck type cables.
- See technical section of the catalogue for installation rules and regulations.

### **Features**

- Provides 360° armour grounding which is fully inspectable.
- Grounding Device remains in contact with cable when disassembled for inspection.
- Provides an outer deluge seal to prevent moisture ingress to the cable armour and enclosure.
- Provides a cable retention and low smoke and fume, zero halogen seal onto the cables outer jacket.

### **Technical Data**

- Construction and test standards
   C(U) US UL Listed wet locations. E165706.
- IP66 and IP67 ingress protection to IEC 60529, EN60529 and NEMA 4X.
- DTS01 deluge tested by ITS.
- Operating temperature range -50°C to +60°C as standard.
- Alternative Certification Options available .
  - 👪 Marine Approval.







# Accessories









### Nylon Sealing Washer



### **Red Fibre Washer**



SEA	LING WASHE	R
SELI	ECTION TABL	E
Metric	NPT *	
Cable	Cable	9.12
Gland	Gland	0
Size 'V'	Size 'V'	
M20	1/2"	1.5
M20	3/4"	1.5
M25	"	١.5
M32	11/4"	1.5
M40	1/2"	1.5
M50	2"	1.5
M63	21/2"	1.5
M75	3"	1.5
M80	31/2"	1.5
M90	31/2"	1.5
MI00	4"	1.5

SERRATED WASHER

**SELECTION TABLE** 

NPT \*

Cable

Gland

Size 'V'

1/2"

3/4"

1"

11/4"

11/2"

2"

21/2"

3"

'U'

1.5

1.5

1.5

1.5

1.5

1.5

1.5

1.5

Metric

Cable

Gland

Size 'V'

M20

M20

M25

M32

M40

M50

M63

M75

### **Application**

• For use on cable gland entry threads.

### Features

- To maintain ingress protection rating at the enclosure.
- Retaining 'Pips' make washer captive on metric cable gland entry thread.

### Ordering Examples Sealing Washer Type/Size/ Thread

e.g. Nylon Washer/M25 Fibre Washer/M25

### **General Information**

All dimensions in millimetres (except\* where dimensions are in inches). Hawke does not recommend the use of tapered entry threads in enclosures with plain clearance holes. Parallel threaded entries are recommended for this purpose.

Washers for M80, M90 and M100 sizes are only available in Red Fibre.

### **Serrated Washer**



### **General Information**

All dimensions in millimetres (except\* where dimensions are in inches). Hawke does not recommend the use of tapered entry threads in enclosures with plain clearance holes. Parallel threaded entries are recommended for this purpose.

### Application

• For use on cable gland entry threads.

### Features

 To dampen vibrations of the cable gland/ equipment assembly which may loosen the cable gland or locknut.

### **Materials & Finishes**

Hawke serrated washers are manufactured in stainless steel (standard).

### Ordering Examples Serrated Washer/Size/Thread

e.g. Serrated Washer/M25 Serrated Washer/I" NPT





### **Earth Tags**



EARTH TAC	S SEL	ECTIC	ON TA	BLE
Metric Cable Gland Size 'U'	'Y'	'W'	'X'	'Z'
M20	7.0	39.6	33.1	1.6
M25	10.5	45.5	36.5	1.6
M32	12.2	52.0	40.9	1.6
M40	13.6	59.6	44.2	1.6
M50	13.5	78.9	58.I	1.6
M63	13.5	87.6	66.8	1.6
M75	13.5	93.7	72.9	1.6
M80	14.0	128.0	104.0	3.0
M90	14.0	128.0	104.0	3.0
M100	14.0	128.0	104.0	3.0

### Features

Provides an earth bond attachment for a cable gland.

### **Materials & Finishes**

Hawke earth tags are manufactured in brass (standard). Stainless Steel locknuts are available, but dimensions may differ slightly to those stated in the selection table. Please contact Hawke for details.

### Ordering Example Earth Tag /Size/Thread

### e.g. Earth Tag/M25



Alternative Shape may be supplied dependant upon size.

### **Heavy Duty Locknuts**

General Information All dimensions in millimetres.

Hawke does not recommend the use of tapered entry threads in enclosures with plain

clearance holes. Parallel threaded entries are recommended for this purpose.

All dimensions in millimetres (except\* where dimensions are in inches).

Hawke does not recommend the use of tapered entry threads in enclosures with plain clearance holes. Parallel threaded entries are recommended for this purpose.



L	оскі	NUT SI	ELEC	TIONTA	BLE			
Metric	x I.5mr	n Pitch	NPT					
Metric Cable Gland	Across Flats 'X'	Across Across Flats Corners ' 'X' 'Y'		NPT * Cable Gland	Across Flats 'X'	Across Corners 'Y'	'Z'	
MI6	19.0	21.9	3.2	-	-	-	-	
M20	24.0	26.9	4.0	1/2"	30.0	33.6	4.7	
M20	24.0	26.9	4.0	3/4"	30.0	33.6	4.7	
M25	30.0	33.6	4.0	Ι"	36.0	40.3	6.4	
M32	46.0	53.I	4.0	l 1⁄4"	46.0	53.I	6.4	
M40	46.0	53.I	4.8	½"	55.0	61.6	6.4	
M50	65.0	72.8	4.7	2"	65.0	72.8	6.4	
M63	80.0	89.6	6.4	21/2"	80.0	89.6	6.4	
M75	95.0	107.0	6.4	3"	95.0	107.0	6.4	
M80	106.4	119.2	10.0	31/2"	127.0	143.0	9.0	
M90	106.4	119.2	10.0	31/2"	127.0	143.0	9.0	
M100	127.0	142.2	10.0	4"	139.7	158.0	9.0	

### Features

Secures a cable gland in position at the equipment.

### **Materials & Finishes**

Hawke heavy duty locknuts are manufactured in brass (standard). Stainless Steel locknuts are available, but dimensions may differ slightly to those stated in the selection table. Please contact Hawke for details.

### Ordering Example Locknut /Size/Thread

e.g. Locknut/M25

# Cable Gland Accessories

Connection Solutions www.ehawke.com

**General Information** 





## Flameproof, Increased Safety and Industrial

### **PVC Shrouds**



Ρ	С	Ρ	S	hı	ro	u	d	S



SHROUD SELECTION TABLE
Size Ref.#
O/Os
A
В
С
C2
D
E
F
G
Н
1

### Application

- Outdoor or Indoor use.
- For fitting over cable glands when additional environmental and corrosion protection is required.

### **Materials & Finishes**

Hawke shrouds are supplied in black (standard).

### **Ordering Examples** Shroud Type/Size

e.g. PVC Shroud/C PCP Shroud/C

# Cable Gland Accessories

### **Insulated Adaptor Type 478**



### **General Information**

All dimensions in millimetres.

### **Materials & Finishes**

Insulated portion manufactured from glass filled nylon. Female insert and entry component are manufactured in brass (standard).

### Press Stopping Plug



# **General Information**

All dimensions in millimetres.

	I	SULATED	ADAPTOR	SELECT	IONTA	BLE		
Size Ref	Size	Male Thread	Female Thread	'Z' Poro	Hexagon Dimensions			
	Ref.	Metric	Metric	Dore	Across Flats	Across Corners		
	Α	M20	M20	14.3	35.0	40.0		
	В	M25	M25	19.3	41.0	47.0		
	С	M32	M32	25.8	49.0	54.0		
	C2	M40	M40	33.0	55.0	63.5		
	D	M50	M50	43.0	70.0	80.5		
	Е	M63	M63	54.0	80.0	92.4		
	F	M75	M75	67.0	90.0	103.5		

### **Ordering Example**

Insulated Adaptor/Size/Male **Thread/Female Thread** e.g. 478/1/C/M32/M32

PUSH-IN PLUG APPLICATION DATA

Min/Max

Clearance Hole Ø

20mm-20.7mm

Gland Plate

Thickness

2mm-3mm

Hawke push-in stopping plugs are

supplied in Black Silicone (standard).

**Materials & Finishes** 

Clearance

Hole

M20

### **Application**

• Outdoor or Indoor use.

• Provides electrical insulation between a cable gland or a conduit fitting and an electrical enclosure. e.g. to provide a means of isolating armour/braid on signal/instrument cable.

### **Technical Data**

478 Certification and Approval

- Certificate No. SIRA 06 ATEX 1240U.
- Exd IIC.
- Suitable for use in Zone I and Zone 2.
- Suitable for use in Gas Groups IIA. IIB and IIC.

### **Technical Data**

- Increased Safety EExe. 🐼 II 2 GD EExe II.
- Press Plug Baseefa Certificate No. Baseefa 04 ATEX 0168U.
- Suitable for use in Zone 1, Zone 2, Zone 21 • & Zone 22.
- Construction and test standards EN 50014, EN 50019 and EN 50281-1-1. IEC 60079-0 and IEC 60079-7.
- Meets IP66 ingress protection for S Series and EZE Series Enclosures.
- DTS01 deluge protection witnessed by EECS. •
- Operating temperature range -40°C to +80°C.

### 55

ŀ	<b>4</b> Interr	<b>K</b>	Enal
	HWK6	9 June	e '07





### Type 475 and 477 Flameproof and Increased Safety



477 AND 475 STOPPING PLUGS								
Threa	ad Size	Hex. Key						
Metric		Across Flats						
x 1.5p	NPT *	Size 'V'						
M20	3/4"/1/2"	10.0						
M25	"/3/4"	10.0						
M32	1/4"/   "	10.0						
M40	1/2"/   1/4"	19.0						
M50	2"/1½"	19.0						
M63	21/2"/2"	19.0						
M75	3"/21/2"	19.0						

387 STOPPING PLUGS

Hex. Key

Across Flats

Size 'V'

10.0

10.0

10.0

10.0

19.0

19.0

19.0

Thread Size

Metric

x 1.5p

MI6

M20

M25

M32

M40

M50

M63

M75

### **General Information**

All dimensions in millimetres (except\* where dimensions are in inches). The 475 - EExde (removable from outside the enclosure). The 477 - EExde (removable from inside the enclosure).

### **Materials & Finishes**

475 and 477 Stopping plugs are manufactured in brass (standard).

### Type 387 Flameproof and Increased Safety



### **General Information**

### Ingress Protection

To meet with IP66 and IP67, the stopping plugs must be fitted perpendicular to the equipment face in a suitably sized threaded or plain hole and the equipment face must be smooth. Plain holes must be no larger than 0.7mm above the major diameter of the stopping plug thread and the plug must be held in place with a locknut. An serrated washer may also be fitted.

### Type 375 Increased Safety



375 STOPPING PLUGS								
Thread	Hex. Key							
Metric x 1.5p	Across Flats Size 'V'							
M20	10.1							
M25	10.1							

### **General Information**

### **Ingress Protection**

To meet with IP66 and IP67, the stopping plugs must be fitted perpendicular to the equipment face in a suitably sized threaded or plain hole and the equipment face must be smooth. Plain holes must be no larger than 0.7mm above the major diameter of the stopping plug thread and the plug must be held in place with a locknut. An optional serrated washer may also be fitted.

### Features

• To close unused cable gland entries and maintain the flameproof integrity of the equipment.

### **Technical Data**

- Flameproof EExde IIC 🖾 II 2 GD IP66.
- Certificate No. SIRA 06 ATEX 1240U.

### Stopping Plugs Ordering Example

Stopping Plug Type/Size/Thread

e.g. 477/M32

### **Features**

• To close unused cable gland entries and maintain the increased safety integrity of the equipment

### **Technical Data**

- Increased Safety EExde II 🐼 II 2 GD IP66.
- Certificate No. SIRA 06 ATEX 1240U.

### **Materials & Finishes**

387 Stopping plugs are manufactured in brass (standard).

### Stopping Plugs Ordering Example

Stopping Plug Type/Size/Thread

e.g. 387/M32

### **Features**

• To close unused cable gland entries and maintain the increased safety integrity of the equipment

### **Technical Data**

- Increased Safety EExe II 🐼 II 2 GD IP66.
- Baseefa Certificate No. BAS 01 ATEX 2104U.

### **Materials & Finishes**

375 Stopping plugs are manufactured in Black Nylon (standard).

### **Stopping Plugs Ordering Example**

Stopping Plug Type/Size/Thread

e.g. 375/M20





# Adaptors and Reducers Type 476

Flameproof and Increased Safety

	A	dapt	or	ADAPTOR AND REDUCER SELECTION TABLE																
	R	مطبية	or	Male Thread																
Reducer			.01				Met	ric								N	PT			
				M16 M20 M25 M32 M40 M50 M63 M75						1⁄2"	3⁄4"	Ι"	11/4"	½"	2"	21/2"	3"			
			MI6																	
			M20																	
			M25																	
		tric	M32																	
		Me	M40																	
			M50																	
	P		M63																	
	rea		M75																	
	L L																			
	nale		1⁄2"																	
	Fer		3⁄4"																	
			١"																	
		РТ	I 1⁄4"																	
		Z	½"																	
			2"																	
			21⁄2"																	
			3"																	

### **General Information**

All Metric entry threads are 1.5mm pitch as standard.

### **Materials & Finishes**

Hawke adaptors/reducers are manufactured in brass (standard), nickel plated brass, 316 stainless steel or aluminium. Brass NPT entries are nickel plated as standard.

### Adaptor Ordering Example 476/Male Thread Size/Female Thread Size.

e.g. 476//M25/M20.

### Reducer Ordering Example

476/1/Male Thread Size/Female Thread Size.

e.g. 476/1/M25/3/4" NPT.

### **Application/Features**

 Provides a means of connection between the equipment and cable glands with dissimilar thread sizes or types.

### **Technical Data**

- Flameproof and Increased Safety EExde IIC.
   ⟨ ⊆ 𝔅 𝔅 ↓ II 2 GD IP66.
- Certificate No. SIRA 06 ATEX 1240U.
- Suitable for use in Zone 1, Zone 2, Zone 21 and Zone 22.
- Suitable for use in Gas Groups IIA, IIB and IIC.
- Construction and test standards EN 50014, EN 50018, EN 50019 and EN 50281-1-1. IEC 60079-0, IEC 60079-1 and IEC 60079-7.



# Technical Data





The intent of this section of the catalogue is to identify important features that may be useful in the selection and installation of explosion protected electrical equipment.

There are numerous different regulations, codes, guidelines and standards for the design, installation and maintenance of electrical and non-electrical systems for use in potentially explosive atmospheres. The type of operational facility, geographic location, operator practice, local and national legislation, authority having jurisdiction etc. will determine many of the design and installation rules permitted. A fixed or floating petroleum facility located offshore, for example, would not be designed or classified in the same manner as an onshore petrochemical facility.

### 1.0 Potentially Explosive Atmospheres

An explosive atmosphere is defined as a mixture: -

- Of flammable substances in the form of gases, vapours, mists, dusts or fibres
- With air
- Under atmospheric conditions
- In which, after ignition has occurred, combustion spreads to the entire unburned mixture

### 2.0 Area Classification (Classification of Locations)

The purpose of area classification is to provide a basis for the correct selection, installation and location of electrical and non-electrical equipment in those areas. Areas must be classified depending on the properties of the flammable vapours, liquids, gases, mists, combustible dusts or fibres that may be present and the likelihood that a flammable or combustible concentration or quantity is present.

The aim of area classification is to avoid ignition of flammable releases that may occur in the operation of facilities. The intent is to reduce to an acceptable minimum level the probability of a flammable atmosphere and an ignition source occurring at the same time.

### 3.0 CENELEC and IEC

### 3.1 Area Classification

Area classification is the division of a facility into three-dimensional hazardous areas and non-hazardous areas and the sub-division of the hazardous area into 'Zones'.

Hazardous areas may be sub-divided into three Zones as follows: -

Flammable gases and vapours								
Zone 0	An area in which an explosive atmosphere is constantly present, or present for long periods.							
Zone I	An area in which an explosive atmosphere is likely to occur in normal operation. (Rough Guide: 10 hours or more / year but less than 1,000 hours / year)							
Zone 2	An area in which an explosive atmosphere is not likely to occur in normal operation and if it occurs, it will exist only for a short time. (Rough Guide: Less than 10 hours / year)							



Combustible Dusts				
Zone 20	An area in which combustible dust, as a cloud, is present continuously or frequently, during normal operation, in sufficient quantity to be capable of producing an explosive concentration of combustible dust in a mixture with air			
Zone 21	An area, in which combustible dust, as a cloud, is occasionally present during normal operation, in a sufficient quantity to be capable of producing an explosive concentration of combustible dust in a mixture with air.			
Zone 22	An area, in which combustible dust, as a cloud, may occur infrequently and persist for only a short period, or in which accumulations of layers of combustible dust may give rise to an explosive concentration of combustible dust in mixture with air.			

For further information on the classification of hazardous areas, see: -

IEC 60079-10	•	Electrical Apparatus for Explosive Gas Atmospheres, Classification of Hazardous Areas
IEC 61241-3	•	Electrical apparatus for use in the presence of combustible dust Part 3: Classification of areas where combustible dusts are, or may be, present
BS EN 50281-3	-	Classification of areas where dusts are, or may be, present
Institute of Petroleum	-	Model Code of Safe Practice in the Petroleum Industry, Part 15: Area Classification Code for installations handling flammable fluids, IP 15

### 3.2 Classification Society

A Classification Society may also enforce requirements for the design and installation of facilities. These requirements, which are in addition to statutory requirements, may influence the design and installation of the electrical systems. Classification Societies include ABS, DNV and Lloyds Register.

### 3.3 Design and Installation of Electrical Systems for Hazardous (Classified) Areas

There are numerous regulation codes, guidelines and standards for the design, selection and installation of electrical installation in potentially explosive atmospheres. These requirements are in addition to the requirements for installations in non-hazardous areas.

There are several types of protection, i.e. construction techniques, available for electrical apparatus in hazardous areas. The type of protection permitted will depend upon the applicable installation codes and rules to be adopted.

The selection of electrical apparatus should be in accordance with the following: -

- Classification of the hazardous area
- Temperature class or ignition temperature of the gas, liquid, vapours, mist, dust or fibre
- Where applicable, the gas, vapour or dust classification in relation to the group or sub-group of the electrical apparatus
- External influences and ambient temperature



### 3.4 Apparatus selection according to Zones

### Apparatus for use in Zone 0

• Intrinsic safety 'ia'

### Apparatus for use in Zone I

- Electrical apparatus permitted for use in Zone 0.
- Flameproof enclosure 'd'
- Pressurised apparatus 'p'
- Powder filling 'q'
- Oil immersion 'o'
- Increased safety 'e'
- Intrinsic safety 'ib'
- Encapsulation 'm'

### Apparatus for use in Zone 2

- Electrical apparatus permitted for use in Zone 0 or Zone 1 or
- Electrical apparatus designed specifically for Zone 2 (for example type of protection 'n' or
- Electrical apparatus complying with the requirements of a recognised standard for industrial electrical apparatus, which does not, in normal operation, have ignition capable hot surface and does not in normal operation produce arcs or sparks. This equipment must be in an enclosure with a degree of protection and mechanical strength suitable for the environment and be assessed by a person who is familiar with the requirements of any relevant standards and codes of practice.

### Apparatus for use in Zones 20, 21 and 22

 Refer to IEC 61241-14 Electrical apparatus protected by enclosures - Selection, installation and maintenance.

### 3.5 Apparatus selection according to the ignition temperature of the gas or vapour

The equipment must be selected so that its maximum surface temperature will not reach the ignition temperature of any gas or vapour that may be present.

Temperature class of electrical apparatus	Maximun surface temperature of electrical apparatus	lgnition temperature of gas or vapour
ΤI	450°C	>450°C
Т2	300°C	>300°C
Т3	200°C	>200°C
T4	135°C	>135°C
Т5	100°C	>100°C
Т6	85°C	>85°C

If the marking of the electrical apparatus does not include an ambient temperature range, the apparatus is only for use within an ambient temperature range from -20°C to +40°C.

For further information regarding data for flammable gases and vapours, see PD IEC 60079-20.



### 3.6 Apparatus selection according to apparatus grouping

The grouping of gases and vapours are classified into Group I and Group II categories. Group I is relevant to atmospheres containing firedamp (a mixture of gases, composed mostly of methane, found underground in mines).

Group II is intended for use in all other places with potentially explosive atmospheres. Group II electrical apparatus with types of protection 'd' and 'i' are further sub-divided into apparatus group IIA, IIB or IIC. Electrical apparatus with type of protection 'n' may also be sub-divided if it contains certain devices or components.

Gas / Vapour Sub-division	Apparatus sub-group permitted
IIA (typical gas propane)	IIA, IIB or IIC
IIB (typical gas ethylene)	IIB or IIC
IC (typical gases acetylene and hydrogen)	IIC

### 3.7 Apparatus Construction Standards

CENELEC		IEC		
BS EN 60079-0 -	General Requirements	IEC 60079-0	-	General Requirements
EN 50015 -	Oil Immersion 'o'	IEC 60079-6	-	Oil Immersion 'o'
BS EN 60079-2 -	Pressurisation 'p'	IEC 60079-2	-	Pressurisation 'p'
BS EN 60079-5 -	Powder Filling 'q'	IEC 60079-5	-	Powder Filling 'q'
BS EN 60079-1 -	Flameproof Enclosure 'd'	IEC 60079-1	-	Flameproof Enclosure 'd'
BS EN 60079-7 -	Increased Safety 'e'	IEC 60079-7	-	Increased Safety 'e'
BS EN 60079-11 -	Intrinsic Safety 'i'	IEC 60079-11	-	Intrinsic Safety 'i'
BS EN 60079-15 -	Electrical Apparatus type	IEC 60079-15	-	Electrical Apparatus type 'n
BS EN 60079-18 -	Encapsulation 'm'	IEC 60079-18	-	Encapsulation 'm'

### 3.8 Installation Standards and Codes

There are numerous different regulations, codes, guidelines and standards for the design, installation and maintenance of electrical and non-electrical systems for use in potentially explosive atmospheres. The type of operational facility, geographic location, operator practice, local and national legislation, authority having jurisdiction etc. will determine many of the design and installation rules permitted

For further information on the design, selection and installation of equipment for use in hazardous areas see: -

IEC 60079-14	<ul> <li>Electrical installations in hazardous areas (other than mines)</li> </ul>	
IEC 61892-7	<ul> <li>Mobile and fixed offshore units - Electrical installation, Part 7: Hazardous areas</li> </ul>	
IEC 61241-1-1 and IEC 61241-1-2	<ul> <li>Electrical apparatus in the presence of combustible dust.</li> </ul>	
EN 60079-14	- Electrical installations in hazardous areas (other than mines)	
IEC 61241-14	Electrical apparatus for use in the presence of combustible dus	t

### 3.9 Inspection Standards and Codes

For information regarding the installation and maintenance of equipment for use in hazardous see: -

IEC 60079-17	-	Inspection and maintenance of electrical installations in hazardous areas (other than mines)
IEC 61241-17	-	Electrical apparatus for use in the presence of combustible dust atmosphere - Part 17: Inspection and maintenance

### 4.0 ATEX 94/9/EC Directive

ATEX is the term used when referring to the European Unions (EU) Directive 94/9/EC

The ATEX Directive main objectives are to guarantee the free circulation of goods within the European Union by aligning the technical and legal requirements of the Member States.

"ATEX" is derived from the French "Atmosphères Explosibles".

The Directive is named: - "Approximation of the laws of the Member States concerning equipment and protective systems intended for use in potentially explosive atmospheres".

The Directive covers electrical and non-electrical equipment and protective systems intended for use in potentially explosive atmospheres in mining and surface industries.

The Directive covers: -

- equipment and products that have potential ignition sources
- protective systems products that control the effects of incipient explosions
- safety devices products that may be outside a potentially explosive atmosphere but that have an
  explosion safety function.
- components products that are intended to form parts of equipment or protective systems

To ensure compliance with the Directive, equipment must meet with the essential requirements specified in the Directive and be marked with the CE marking.

The process of ensuring that equipment complies with the Directive, conformity assessment procedure(s) must be complied with. These procedures may involve a Notified Body. A Notified body is a body that is independent of the product manufacturer and assesses conformity of the products and the manufacturer with the Directive. The Notified Body has to be approved and appointed by its government.

Conformity assessment procedures include, but are not limited by: -

- EC Type examination including testing and inspection of a product design, where appropriate
- Production Quality Assurance including the assessment, periodic auditing, testing and inspection of production samples, where appropriate, and of the manufacturers quality system.
- Product Verification the inspection and/or testing of each production item for conformity with the type that was subjected to EC Type Examination
- Internal Control of Production the verification by the manufacturer that the product design and each production item conform to either harmonised European Standards or the essential requirements or a combination of the two

The ATEX Directive came into force on a voluntary basis on 1st March 1996 and became mandatory from the 1st July 2003 and all products within its scope have to comply before being placed on the market or put into service.



The Directive classifies equipment into eight categories depending on the equipment's area of use: -

Category MI	<ul> <li>equipment intended for mining use and is required to remain functional in the presence of an explosive atmosphere.</li> </ul>
Category M2	<ul> <li>equipment intended for mining use but is intended to be de-energised in the event of an explosive atmosphere.</li> </ul>
Category IG	<ul> <li>non-mining equipment for use in Zone 0.</li> </ul>
Category 2G	<ul> <li>non-mining equipment for use in Zone 1.</li> </ul>
Category 3G	<ul> <li>non-mining equipment for use in Zone 2.</li> </ul>
Category ID	<ul> <li>non-mining equipment for use in Zone 20.</li> </ul>
Category 2D	<ul> <li>non-mining equipment for use in Zone 21.</li> </ul>
Category 2D	<ul> <li>non-mining equipment for use in Zone 22.</li> </ul>

### 4.1 ATEX 137 Directive 99/92/EC

The Directive covers the use of equipment in potentially explosive atmospheres and its aim is to establish minimum requirements for improving the safety and health of workers.

Article 137 of Directive 89/391/EC was published in the official journal of the EC on 28th January 2000 as Directive 99/92/EC, it is the 15th individual Directive of the framework Directive 89/391/EEC.

The article defines the: -

- Obligations of the employees re. the prevention and protection against explosions
- Assessment obligations re. the assessment of explosion risks.
- General obligations re. the safety and health of worker
- Requirements for explosion protection documents

In places where potentially explosive atmospheres may occur in such quantities as to endanger the health and safety of workers, the point of entry must be marked with the sign shown below in accordance with Section II, Article 7 of the Directive.





### 5.0 Wiring Systems

Cable systems and accessories should be installed in positions that prevent them from being subject to mechanical damage, corrosion, chemical attack, heat and other detrimental environmental conditions. Selection of the wiring system and cable type must consider these influences and where exposure to such conditions are unavoidable, protective measures such as minimising the risk of mechanical damage by the use of appropriate armoured cable types should be considered.

The connection of cables and conduits to the electrical apparatus must be in accordance with the requirements of the relevant type of protection and installation rules.

### 5.1 CENELEC and IEC Wiring Methods

With the introduction of cables incorporating new construction materials and especially cables with fire retardant or fire resistant properties such as cables complying with IEC 60331 and IEC 60332, cables may exhibit "cold flow" characteristics. "Cold flow" is a term used for thermoplastic materials that flow when subjected to pressure at ambient temperature. These "cold flow" characteristics ould have adverse effects on the protection of the apparatus. A suitable cable gland should be used that does not incorporate displacement / compression seals that act upon the part(s) of the cable having cold flow characteristics.

To overcome this problem, Hawke has developed cable glands that incorporate diaphragm seals that act upon the "cold flow" cable sheath without compressing or damaging the cable. A typical cable gland incorporating displacement/compression seals and a Hawke 501/453/Universal cable gland incorporating a diaphragm seal are shown below.



No cable damage due to Hawke 501/453 Universal diaphragm seal cable gland design.

Cable damage as found with cable gland designs incorporating compression / displacement seals.

The IEC and CENELEC installation standards, IEC 60079-14 and BS EN 60079-14 address "cold flow" in Clause 9.1.4.





**NOTE** - Internal sources of ignition include sparks or equipment temperatures occurring in normal operation which can cause ignition. An enclosure containing terminals only or an indirect entry enclosure (see 10.4.1) is considered not to constitute an internal source of ignition.



### **Hazardous Area Information**

### 10.4 Cable Entry Systems

### 10.4.1 General

It is essential that cable entry systems comply with all the requirements referred to in the appropriate apparatus standard, that the cable entry device is appropriate to the type of cable employed, maintains the respective method of protection and is in accordance with clause 9.

Where cables enter into flameproof apparatus via flameproof bushings through the wall of the enclosure which are part of the apparatus (indirect entry), the parts of the bushings outside the flameproof enclosure will be protected in accordance with one of the types of protection listed in IEC 60079-0. Normally the exposed part of the bushings will be within a terminal compartment which will either be another flameproof enclosure or will be protected by protection type 'e'. Where the terminal compartment is Ex'd', then the cable system shall comply with 10.4.2. Where the terminal compartment is Ex'e', then the cable system shall comply with 11.3.

Where cables enter into flameproof apparatus directly, the cable system shall comply with 10.4.2.

### 10.4.2 Selection

The cable entry system shall comply with one of the following:

a) cable entry device in compliance with IEC 60079-1 and the particular type of cable intended for use with that device;

b) thermoplastic, thermosetting or elastomeric cable which is substantially compact and circular, has extruded bedding and the fillers, if any, are non-hygroscopic, may utilize flameproof cable entry devices, incorporating a sealing ring selected in accordance with figure I;

c) mineral insulated cable with or without plastic outer covering with appropriate flameproof cable entry device;

d) flameproof sealing device (for example a stopper box or sealing chamber) specified in the apparatus documentation or having component approval and employing cable entry devices appropriate to the cables used. The sealing devices such as stopper boxes or sealing chambers shall incorporate compound or other appropriate seals which permit stopping around indivudual cores. Sealing devices shall be fitted at the point of entry of cables to the apparatus;

e) flameproof cable entry devices incorporating compound filled seals around the individual cores or other equivalent sealing arrangements;

f) other means which maintain the integrity of the flameproof enclosure.

NOTE - Where a factory-made termination of the encapsulated type is used, no attempt should be made to interfere with the connection to the apparatus or to replace the cable.





### Wiring Methods for Type of Protection 'e' - Increased Safety:

The cable entry device, e.g. cable gland, must comply with all the requirements referred to in the appropriate Standard, be appropriate to the cable type. and maintain the type 'e' integrity of the equipment.

A minimum ingress protection rating of IP54 is required for increased safety equipment. To meet with this requirement it may be necessary to provide a seal between the cable gland and the equipment, for example, by the use of a sealing washer or thread sealant. Where cable glands are fitted into non-metallic enclosures, metallic enclosures with a painted type finish or enclosures with non-threaded clearance holes, additional ingress and earthing / bonding considerations may be necessary. Please refer to the sealing washer, earthtag, serrated washer and locknut accessories shown in the catalogue.



### 6.0 Apparatus Marking - IEC and CENELEC (Group II) **ATEX Marking (Glands)** 6.1 The temperature class or maximum surface temperature in Manufacturer's name The symbol for each °C or both. (Cable glands need or registered type of protection Increased not be marked with the trademark technique used Safety temperature class) **Technical Data** T6 Tamb -60°C +80°C HAWKE 501/453/UNIV/B/M25 Ex Ex ExtD d Ш С 1 Manufacturer's type The group Enclosure The group of identification, e.g. sub-division, if suitable for dust electrical catalogue number applications apparatus applicable The symbol to indicate that When the equipment is designed for use the electrical apparatus in an ambient temperature range other corresponds with one or than -20°C to +40°C, the symbol Ta or more explosion protection Tamb together with the special range of tecuniques ambient temperatures must be marked. Marking to indicate special Year of conditions for certification safe use Baseefa 06 ATEX 0057 Х Marking to indicate an Ex component U which requires additional certification Name or mark of Certificate before being used in a hazardous area certificate testing Number station

### 6.2 **ATEX Marking (Enclosures)**

- The name and address of the manufacturer
- Type, serial number and the year in which the equipment was constructed
- The specific marking of explosion protection  $\langle \xi x \rangle$  followed by the symbol of the equipment group and the category.

'EN50 014\_EN50 019 EN50 281' (optional), (Ex) 'Exell' Temperature Classification,  $(\in 1180\langle E_X \rangle, Gas and Dust Groups, Maximum Surface Temperature of the enclosure (T),$ IP rating, Certification Name and Number, 'DO NOT OPEN WHEN ENERGIZED'. Maximum Dissipated Power (Watts), Volts and Amps.

Note: If the temperature range is outside the normal range of -20°C to +40°C, it must be marked on the label.





### 6.2 Additional CE Marking

The CE conformity marking must consist of the initials  $\mathfrak{E}$  and be followed by the identification number of the notified body responsible for production control.

Example: CE

**Technical Data** 

Connection Solutions www.ehawke.com


### 7.0 CE Marking (€

The CE Marking is intended to facilitate the free movement of products within the European Union. By affixing CE marking to products, the manufacturer is making a legal declaration that the product meets with the appropriate requirements of all relevant European Directives. CE marking only applies to products within the scope of the Directives. It should not be applied to products if they are outside the

#### 7.1 EMC, Electromagnetic Compatibility Directive

Most electrical and electronic products made or sold in the EU must: -

- Be constructed so they do not cause excessive electromagnetic interference and are not unduly affected by electromagnetic interference;
- In the case of certain radio-transmitting equipment, be subject to EC type examination by a notified body; and
- Carry CE marking

Cable glands are not considered to come within the scope of the Directive, however we have carried out independent third-party testing on the EMC shielding effectiveness of our armoured type cable glands fitted onto single wire armoured and braided-type cables. The electromagnetic ingress between the cable sample (perfect connection) and that of the cable sample fitted with the cable gland was of such a small magnitude that it could be regarded as within acceptable uncertainty of measurement. As such, it can be concluded that the shielding effectiveness of single wire armoured or braided cable is maintained when fitted with an appropriate Hawke armoured type cable gland.

#### 7.2 Low Voltage Directive

The Low voltage Directive 73/23/EEC embodies a number of principles: -

- Only electrical equipment that does not jeopardise the safety of people, domestic animals and property, is permitted on the market.
- Only electrical equipment, that satisfies the CE marking requirements of the LVD, is in compliance.
- Electrical equipment is not required to be tested or marked for approval by an independent third party
- Enforcement is the responsibility of each member state within its national jurisdiction.
- The regulations apply to all electrical equipment, except where extensions apply, that is designed for use between 50 and 1000 volts ac or 75 and 1500 volts dc.
- Only components, which are in themselves "electrical equipment", need satisfy the Low Voltage Directive.

Cable glands are not in themselves "electrical equipment" and therefore do not fall within the scope of the LVD.

### 8.0 Certification / Listing / Approvals

Electrical equipment for use in potentially explosive atmospheres is usually certified, listed or approved by a recognised Certification Body or Test House. In Europe, there are numerous Certification Bodies such as BASEEFA 2001 Limited and SIRA in the UK. In North America, there are many recognised Certification Bodies and testing laboratories such as UL, FM and the CSA. The definition of "Approved" by the NEC is "Acceptable to the authority having jurisdiction". The definition "Listed" by the NEC is "Equipment, materials or services included in a list published by an organisation that is acceptable to the authority having jurisdiction". Further information is given in the NEC.



### 9.0 CENELEC and IEC Degree of Protection, IP Code

The standards EN 60529 and IEC 60529 describe a system for classifying the degrees of protection provided by the enclosures of electrial equipment as follows :-

First Number			Se	cond Number		
0 🌠	Non-protected	Protection of persons against access to hazardous parts inside the enclosure and against solid foreign objects	0	ţ	Non-protected	Protection of the equipment inside the enclosure against harmful effects due to the ingress of water
50	Protected against objects of 50mm diameter and greater	An object probe, sphere of 50mm diameter, shall not fully penetrate	ī		Protected against vertically falling water drops	Vertically falling drops shall have no harmful effects
	Protected against solid foreign objects of 12.5mm diameter and greater	An object probe, sphere of 12.5mm diameter, shall not fully penetrate	2		Protected against vertically falling water drops when enclosure tilted up to 15°	Vertically falling drops shall have no harmful effects when the enclosure is tilted at any angle up to 15° on either side of the vertical
	Protected against solid foreign objects of 2.5mm diameter and greater	An object probe, sphere of 2.5mm diameter, shall not penetrate at all	3		Protected against spraying water	Water sprayed at an angle up to 60° on either side of the vertical shall have no harmful effects
	Protected against solid foreign objects of 1.0mm diameter and greater	An object probe, sphere of 1.0mm diameter, shall not penetrate at all	4	<b>F</b>	Protected against splashing water	Water splashed against the enclosure from any direction shall have no harmful effects
	Dust-protected	Ingress of dust is not totally prevented, but dust shall not penetrate in a quantity to interfere with satisfactory operation of apparatus or to impair safety	5		Protected against water jets	Water projected in jets against the enclosure from any direction shall have no harmful effects
	Dust-tight	No ingress of dust	6		Protected against powered water jets	Water projected in powerful jets against the enclosure from any direction shall have no harmful effects
Ту	/pical Desig	gnation : IP66	7 IM	• 15cm min.	Protected against the effects of temporary immersion in water for 30 mins	Ingress of water in quantities causing harmful effects shall not be possible when the enclosure is temporarily immersed in water under standardised conditions of pressure and time
			8		Protected against	Ingress of water in quantities

the effects of

immersion in water

continuous



causing harmful effects shall

not be possible when the

enclosure is continuously immersed in water under conditions which shall be agreed between manufacturer and user but which are more severe than for numeral 7

The protection of the enclosure and the equipment inside against external influences or conditions, such as: mechanical impacts, corrosion, corrosive solvents, solar radiation, icing moisture (e.g. produced by condensation), and explosive atmospheres, are matters that should be dealt with by the relevant product Standard.

There are additional and supplementary optional letters to the above coding; these designators are A, B, C & D and H, M, S & W, and further information can be found in the relevant Standard(s).

#### 9.1 Deluge Ingress Protection

On offshore facilities, equipment may be located in areas subject to emergency deluge systems. Equipment that has been evaluated as certified for use in hazardous areas may not be suitable for use in these locations. A testing method for electrical equipment to be installed in areas subject to deluge systems, DTS01, has been prepared by the Explosion and Fire Hazards Group of ERA Technology (now known as ITS) in collaboration with Shell UK Exploration and Production Ltd.

Testing includes: -

- Energising the equipment (where appropriate) for 60 minutes prior to the deluge test, then interrupting the electrical power at the start of the deluge test and resuming after 60 minutes until the completion of the deluge test.
- Carrying out insulation resistance testing before and after pre-conditioning and after the deluge test, where applicable.
- Carrying out pre-conditioning by exposure to vibration and thermal ageing at 90% relative humidity and at a temperature 20k above the equipments maximum service temperature and/or at least 80°C of any appropriate seals.
- Carrying out deluge test using a deluge chamber fitted with deluge nozzles that apply a salt water solution deluge pressure within the range of 3.5 bar to 4.5 bar at a water temperature in the range of 5°C to 10°C for 3-hours.

### 10.0 IECEx Scheme

The objective of the IECEx Scheme is to facilitate international trade in electrical equipment intended for use in potentially explosive atmospheres by eliminating the need for multiple national certification. The IECEx Scheme provides a means for manufacturers to obtain Certificates of Conformity that will be accepted at national level in all participating countries. A Certificate of Conformity may be obtained from any certification body accepted into the scheme. The objective of the IECEx Scheme is world-wide acceptance of one standard, one certificate, and one mark.

For the IEC scheme to achieve its objective, every applicable national standard will need to be identical to the corresponding IEC standard. A transition period will be necessary to allow time for participating IECEx Scheme countries to align their national standards with the IEC standards and work towards national acceptance of IECEx Certificates of Conformity and the IECEx mark.

### 11.0 North American Hazardous (Classified) Locations

#### II.I Area Classification

Area classification is the division of a facility into a two or three-dimensional hazardous location, a non-hazardous location and the sub-division of the hazardous location into 'Divisions' or 'Zones'.

Hazardous (classified) locations may be sub-divided as follows: -



In the United States of America, hazardous (classified) locations are sub-divided into three Zones or two Divisions, as follows: -

Class 1, Flammable Gases, Vapors or Liquids	Class 1, Flammable Gases, Vapors or Liquids
<b>Division 1:</b> Where ignitable concentrations of flammable gases, vapors or liquids can exist all of the time or some time under normal operating conditions.	<ul> <li>Zone 0: Where ignitable concentrations of flammable gases, vapors or liquids can exist all of the time or for long periods at time under normal operation conditions.</li> <li>Zone 1: Where ignitable concentrations of flammable gases, vapors or liquids can exist some of the time under normal operating conditions.</li> </ul>
<b>Division 2:</b> Where ignitable concentrations of flammable gases, vapors or liquids are not likely to exist under normal operating conditions	<b>Zone 2:</b> Where ignitable concentrations of flammable gases, vapors or liquids are not likely to exist under normal operating conditions.
Class 11, Combustible Dusts	There is no Zone classification for dusts, fibres or flyings at present in the NEC
<b>Division 1:</b> Where ignitable concentrations of flammable gases, vapors or liquids can exist all of the time or some time under normal operating	
<b>Division 2:</b> Where ignitable concentrations of combustible dusts are not likely to exist under normal operating conditions	
Class 111, Ignitable Fibres and Flyings	
<b>Division 1:</b> Where ignitable concentrations of ignitable fibres and flyings can exist all of the time or some of the time under normal operating conditions	
Division 2: Where ignitable concentrations of ignitable fibres and flyings are not likely to exist under normal operating conditions	

For further information on the classification of hazardous (classified) locations see: -

NEC, NFPA 70 NFPA 30	<ul> <li>National Electric Code, NFPA 70</li> <li>Flammable and Combustible Liquids Code</li> </ul>
NFPA 497	<ul> <li>Recommended Practice for the Classification of Flammable Liquids, Gases or Vapours and of Hazardous (Classified)</li> <li>Locations for Electrical Installations in Chamical Process</li> </ul>
Aroos	Eocations for Electrical Installations in Chemical Process
Aleas	
NFPA 499	- Recommended Practice for the Classification of Combustible
	Dusts and of Hazardous (Classified) Locations for Electrical
	Installations in Chemical Process Areas
ANSI/API RP500	- Recommended Practice for Classification of Locations for
	Electrical Installations at Petroleum Facilities Classified as
	Class I, Division 1 and Division 2
ANSI/API RP 505	- Classification of Locations for Electrical Installations at
	Petroleum Facilities Classified as Class I. Zone 0. Zone 1

#### 11.2 Apparatus selection according to Class I

#### Apparatus for use in Class I, Division I

- Explosion-proof
- Intrinsically safe
- Purged / pressurised (type X or Y)

#### Apparatus for use in Class 1, Division 2

- Any Class I, Division I method
- Non-incendive
- Non-sparking device
- Purged / pressurised (type Z)
- Hermetically sealed
- Oil immersion

#### Apparatus for use in Class I, Zone 0

- Intrinsic safety AEx ia
- Class I, Division I intrinsically safe

#### Apparatus for use in Class I, Zone I

- Any Class I, Zone 0 method
- Any Class I, Division I method
- Flameproof, AEx d
- Increased safety, AEx e
- Intrinsic safety, AEx ib
- Purged pressurised, AEx p
- Powder filling, AEx q
- Oil immersion, AEx o
- Encapsulation, AEx m

#### Apparatus for use in Class I, Zone 2

- Any Class I, Zone 0 or 1 method
- Any Class I, Division I or 2 method
- Type of protection AEx n

Intrinsically safe equipment listed for use in Class I, Division I, locations for the same gas or a permitted by Section 505-7(d) of the NEC, and with suitable temperature rating is permitted in Class I, Zone 0 locations.

Equipment approved for use in Class I, Division I or listed for use in Class I, Zone 0 locations for the same gas, or as permitted by Section 505-7(d) of the NEC, and with a suitable temperature rating is permitted in Class I, Zone I locations.

Equipment approved for use in Class I, Division I or Division 2 locations for the same gas, or as permitted by Section 505-7(d) of the NEC, and with a suitable temperature rating is permitted in Class I, Zone 2 locations.

Equipment listed as classified for use in Class I locations is not necessarily acceptable for Class II locations as it may not be dust-tight or operate at a safe temperature with a dust covering.

**Technical Data** 

#### 11.3 Apparatus selection according to the ignition temperature of the gas or vap

The equipment must be selected so that its maximum surface temperature will not reach the ignition temperature of any gas or vapor that may be present.

Temperature class of electrical apparatus	Maximun surface temperature of electrical apparatus	Ignition temperature of gas or vapour
TI	450°C	>450°C
T2	300°C	>300°C
T2A	280°C	>280°C
T2B	260°C	>260°C
T2C	230°C	>230°C
T2D	215°C	>215°C
Т3	200°C	>200°C
ТЗА	180°C	>180°C
ТЗВ	165°C	>165°C
T3C	160°C	>160°C
T4	135°C	>135°C
T4A	120°C	>120°C
Т5	100°C	>100°C
Т6	85°C	>85°C

Low ambient conditions require special consideration. Explosion proof of dust ignition proof equipment may not be suitable for use at temperatures lower than  $-25^{\circ}C$  ( $-13^{\circ}F$ ) unless they are identified for low temperature service. Unless the equipment is marked otherwise, it is for use only in an ambient temperature range of  $-25^{\circ}C$  ( $-13^{\circ}F$ ) to  $+40^{\circ}C$  ( $+104^{\circ}F$ ).

Equipment that is approved for Class I and Class II should be marked with the maximum safe operating temperature.

For information regarding data for flammable gases and vapors, see NFPA 497 and NFPA 325.

#### 11.4 Apparatus selection according to the ignition temperature of the dust

The equipment must be selected so that its maximum surface temperature will be less than the ignition temperature of the specific dust.

For information regarding data for dusts, see NFPA 499.

#### 11.5 Apparatus selection according to apparatus grouping

Equipment that is approved for Class I and Class II should be marked with the maximum safe operating temperature.







The grouping of Class II dusts are classified into categories E, F, and G.



### Apparatus Construction Standards

ANSI / UL 1203	-	Explosion-proof and Dust-ignition Proof Electrical Equipment for use in Hazardous (Classified) Locations
ANSI / ISA - \$12.12	-	Non-incendive Electrical Equipment for use in Class I and II, Division 2 and Class III, Divisions I and 2 Hazardous (Classified) Locations.
ANSI / NFPA 496	-	Standard for Purged and Pressurised Enclosures for Electrical Equipment.
ANSI / UL 913	-	Intrinsically Safe Apparatus and Associated Apparatus for use in Class I, II and III, Division 1, Hazardous Locations.
ANSI / UL 698	-	Industrial Control Equipment for use in Hazardous (Classified) Locations.
ANSI / UL 2225	-	Metal-Clad Cables and Cable-Sealing Fittings for use in Hazardous (Classified) Locations.
UL 1604 III	-	Electrical Equipment for use in Class I and II, Division 2 and Class Hazardous (Classified) Locations.
ANSI / UL 2279	-	Electrical Equipment for use in Class I, Zone 0, 1 and 2 Hazardous (Classified) Locations
ISA \$12.0.01	-	Electrical Apparatus for use in Class I, Zone 0, I Hazardous (Classified) Locations, General Requirements.
ISA \$12.22.01	-	Electrical Apparatus for use in Class I, Zone I and 2 Hazardous (Classified) Locations, Type of Protection - Flameproof 'd'
ISA \$12.16.01	-	Electrical Apparatus for use in Class I, Zone I and 2 Hazardous (Classified) Locations, Type of Protection - Increased Safety 'e'.

11.6



#### 11.7 Installation Standards and Codes

NEC, NFPA 70	- National Electrical Code (NEC)
USCG 45 CFR Parts 110 - 113	- Shipping, Sub-Chapter J, Electrical Engineering
ANSI / API RP 14F	- Recommended Practice for Design and Installatin of Electrical Systems for Fixed and Floating Offshore Petroleum Facilities for Unclassified and Class I, Division I and Division 2 Locations.
API RP 14FZ	<ul> <li>Rcommended Practice for Design and Installation of Electrical systems for fixed and floating offshore petroleum facilities for Unclassified and Class I, Zone 0, Zone 1 and Zone 2 Locations</li> </ul>

### 12.0 Wiring Systems

Cable systems and accessories should be installed in positions that prevent them from being subject to mechanical damage, corrosion, chemical attack, heat and other detrimental environmental conditions. Selection of the wiring system and cable type must consider these influences and where exposure to such conditions are avoidable, protective measures such as minimising the risk of mechanical damage by the use of appropriate armoured cable types should be considered.

The connection of cables and conduits to the electrical apparatus must be in accordance with the requirements of the relevant type of protection and installation rules.

#### 12.1 National Electrical Code (NEC) Wiring Methods

In Class I, Division I locations, the NEC permits the following wiring methods: -



Hawke Type 711 CableGland/

Connector

Type MC cable, listed for use, with a gas / vapor tight continuous corrugated aluminum sheath, an overall jacket of suitable polymeric material, separate grounding conductors, in accordance with Sections 250-122 and 501.10 of the NEC, and provided with termination fittings listed for he application, e.g. Hawke type 711 cable gland/connector.

- Type ITC cable, listed for use with a gas / vapor tight continuous aluminum sheath, an
  overall jacket of suitable polymeric material in accordance with Section 501.10 of the NEC
  and provided with termination fittings listed for the application, e.g. Hawke type 711 cable
  gland/connector.
- Threaded rigid metal conduit, threaded steel intermediate metal conduit, or type MI cable with termination fittings approved for the location and in accordance with Section 501.10

All boxes, fittings and joints must be explosion-proof.



In Class I, Division 2 locations, the NEC permits the following wiring methods: -

- Type MC, MV, ITC, PLTC, TC or MI cable with approved termination fittings in accordance with Section 501.10 of the NEC.
- Threaded rigid metal conduit, threaded steel intermediate metal conduit.
- Non-incendive field wiring using any of the methods suitable for wiring in ordinary locations in accordance with Section 501.10 of the NEC.

Boxes, fittings and joints need not be explosion-proof except as required by the NEC code.

#### 12.2 Cable Seals, Class I, Division I



Hawke Type 711 Cable Gland/ Connector Cables must be sealed at the termination. The sealing fitting, e.g. a barrier type cable gland, must provide a seal against the passage of gas or vapours through the fitting. Type MC cables with multi-conductors, a gas / vapour tight continuous corrugated aluminum sheath and an overall jacket with a suitable polymeric material must be sealed with an appropriate fitting, e.g. Hawke type 711, after removing the cables jacket and all other coverings so that the sealing compound surrounds each individual insulated conductor. Cables with twisted pairs and shielded cables require the removal of the shielded material or separation of the twisted pairs unless the fitting, e.g. cable gland, is an approved means which minimises the entrance of gases or vapours and prevents propagation of flame into the cable core. If the fitting complies with this requirement, there will be information provided in the fittings installation instructions detailing the means to achieve the seal. Additional testing may be required on the fitting and the style and type of cable to show compliance with the sealing requirements.

A NRTL approved cable sealing fitting e.g. barrier type cable gland, must be fitted onto cables that enter explosion-proof enclosures.

Further guidance is given in Section 501.5(d) of the NEC.

#### 12.3 Cable Seals, Class 1, Division 2

Cables must be sealed at the point of entrance into enclosures that require to be approved for Class I locations. A sealing fitting must comply with the above criteria given in "Cable Seals, Class I, Division I".

A NRTL approved cable sealing fitting e.g. barrier type cable gland, must be fitted onto cables where they enter explosion-proof enclosures.

#### 12.4 United State Coast Guard - Wiring Methods

Electrical installations in hazardous (classified) locations must comply with the general requirements of Section 43 of the IEEE standard 45 and either the NEC Articles 500 - 505 or IEC 60079 series publications.

In hazardous (classified) locations, the USCG 46 CFR Sub-Chapter J, permits the following wiring methods: -



Marine shipboard cables that are permitted for use, must meet all the requirements of either IEEE standard 45, IEC 60092-3 and the applicable flammability requirements. Cables constructed to IEC 60092-3 must meet with the flammability requirements of IEC 60332-3, Category A.

Hawke Type 753 Cable Gland/ Connector

Metal-clad (type MC) cables that are permitted for use, must have a continuous corrugated gas tight, vapor-tight, and water-tight sheath of aluminum or other suitable metal that is close fitting around the conductors and with fillers. The MC cable must have an overall jacket of an impervious PVC or thermoset material and be certified or listed to UL 1569.

For information on other wiring methods permitted and further information, refer to Subpart III-60 of the USCG 46 CFR.

Each cable entry into explosion-protected equipment must be made with an appropriate fitting or cable gland that maintains the integrity of the equipment.

12.4.1 Cables with multi-conductors that enter explosion-proof enclosures, must be sealed with an appropriate fitting, e.g. barrier type cable gland, after removing the cables jacket and all other coverings so that the sealing compound surrounds each individual insulated conductor. Cables with twisted pairs and shielded cables require the removal of the shielded material or separation of the twisted pairs unless the fitting, e.g. barrier type cable gland, is an approved means which minimises the entrance of gases or vapours and prevents propagation of flame into the cable core. If the fitting complies with this requirement, there will be information provided in the fittings installation instructions detailing the means to achieve the seal. Additional testing may be required on the fitting, and the style and type of cable to show compliance with the sealing requirements.

The equipment grounding path should be carefully considered when using Shipboard Cables or type TC cables, as these may not inherently provide a grounding means. The armor of Shipboard Cables should be grounded but can not be used as the grounding conductor. An appropriate sized grounding conductor should be included in each cable.

#### 12.5 American Petroleum Institute - Wiring Methods

#### Class I, Division I

The API RP 14F Recommended Practice for the design and installation of electrical systems for fixed and floating offshore petroleum facilities recommends the following wiring methods for hazardous (classified) locations.

- Type MC-HL metal clad cables as defined in UL 2225.
- Armored marine shipboard cable with an overall impervious sheath over the armor, constructed in accordance with UL 1309, and listed as "Shipboard Cable Marine" by a National Recognised Testing Laboratory (NRTL). This wiring method is a departure from the NEC.
- Type ITC cable that is NRTL listed for use in Class I, Division I locations with a gas / vapor tight continuous corrugated aluminum sheath and with an overall PVC or other suitable polymeric jacket.
- Threaded rigid copper-free aluminum conduit.
- Threaded rigid steel, hot dipped galvanized conduit, coated with PVC, or other suitable material, and with the interior protected by an additional means.

An NRTL approved cable sealing fitting, e.g. barrier type cable gland complying with UL 2225, must be fitted onto cables where they enter explosion-proof enclosures.

For further information and other wiring methods acceptable for Division I, refer to Clause 6.4.2.2 of the API RP14F.

For fitting requirements of cables with multi-conductors, twisted pairs or shielded conductors into explosion proof equipment. See clause 12.4.1.



#### Class I, Division 2



HawkeType 710

Connector

Wiring methods as recommended for use in Division 1.

Type MC cable with a gas / vapour tight continuous corrugated aluminum sheath, an overall PVC or other suitable polymeric jacket, and grounding conductors in accordance with NEC 250-122.

Non-armored marine shipboard cable, with an overall impervious jacket in accordance with Cable Gland/ UL 1309 and listed as "Shipboard Cable Marine" by a NRTL. This wiring method is a departure from the NEC.

> Additional wiring methods acceptable for Division 2 include type PLTC, ITC, TC and MV cables. It is recommended that an overall PVC or other suitable polymeric material jacket is included for these cable types.

For additional information, refer to Clause 6.4.2.3 of API RP14F.

In Division I locations, all electrical equipment (except intrinsically safe systems and equipment inside purged enclosures) should be explosion-proof.

In Division 2 locations, the equipment does not need to be explosion-proof, except where necessary to maintain the integrity of the installation.

Further information on the use of equipment is given in Clause 6.4.7 of API RP14F.

An NRTL approved cable sealing fitting, e.g. barrier type cable gland complying with UL 2225, must be fitted onto cables where they enter explosion-proof enclosures.

For fitting requirements of cables with multi-conductors, twisted pairs or shielded conductors into explosion proof equipment. See clause 12.4.1.

#### Class I, Zones 0, I and 2

The API RP 14 FZ, Recommended Practice for the design and installation of electrical systems for fixed and floating offshore petroleum facilities for unclassified and Class I, Zone 0, Zone I and Zone 2 locations, recommends the following wiring methods for hazardous (classified) locations.

#### Class I, Zone I

- Type MC-HL metal clad cables as defined in UL 2225. •
- Armored marine shipboard cable with an overall impervious sheath over the armor, constructed in accordance with UL 1309, and listed as "Shipboard Cable Marine" by a National Recognised Testing Laboratory (NRTL). This wiring method is a departure from the NEC.
- Type ITC cable that is NRTL listed for use in Class I, Division I locations with a gas / vapor tight continuous corrugated aluminum sheath and with an overall PVC or other suitable polymeric jacket.
- Threaded rigid copper-free aluminum conduit.
- Threaded rigid steel, hot dipped galvanized conduit, coated with PVC, or other suitable material, and with the interior protected by an additional means.

Non-armored marine shipboard cable, with an overall impervious jacket in accordance with UL 1309 and listed as "Shipboard Cable Marine" by a NRTL. This wiring method is a departure from the NEC.

For further information and other wiring methods acceptable for Zone I, refer to Clause 6.4.2.2 of the API RP14FZ.

For fitting requirements of cables with multi-conductors, twisted pairs or shielded conductors into explosion proof equipment. See clause 12.4.1.



#### Class I, Zone 2

- Wiring methods as recommended for use in Zone I.
- Type MC cable with a gas / vapor tight continuous corrugated aluminum sheath, an overall PVC or other suitable polymeric jacket, and grounding conductors in accordance with NEC 250-122.
- Non-armored marine shipboard cable, with an overall impervious jacket in accordance with UL 1309 and listed as "Shipboard Cable Marine" by a NRTL. This wiring method is a departure from the NEC.

Additional wiring methods acceptable for Zone 2 include type PLTC, ITC, TC and MV cables. It is recommended that an overall PVC or other suitable polymeric material jacket is included for these cable types.

For additional information, refer to Clause 6.4.2.3 of API RP14FZ.

Further information on the use of equipment is given in Clause 6.4.7 of API RP14FZ.

An NRTL approved cable sealing fitting, e.g. barrier type cable gland complying with UL 2225, must be fitted onto cables where they enter explosion-proof enclosures.

For fitting requirements of cables with multi-conductors, twisted pairs or shielded conductors into explosion proof equipment. See clause 12.4.1.

Where cables enter equipment which is permitted for use in Zone 2 or unclassified areas and that is not explosion-proof, a suitable cable fitting e.g. cable gland design, need not be explosion-proof, except when necessary to maintain the integrity of the enclosure and as required by the Recommended Practice.

In unclassified and Zone 2 locations, when the metallic sheath is approved as a grounding conductor, the continuous metal sheath of the MC cable or the combined metallic sheath and grounding conductors may be used as the grounding conductor when used with termination fittings that are NRTL listed to UL 514B.

#### 12.6 National Electrical Code (NEC) Zone Equipment Marking

Equipment that is listed for use in Class I, Zones as permitted by the NEC, should be marked as follows: -

- Class I, Zone 0 or Class I, Zone 1 or Class I, Zone 2.
- Applicable gas classification group(s)
- Temperature classification



#### 12.7 National Electrical Code (NEC) Division Equipment Marking

Equipment that is approved for use in Class I, Class II or Class III, Division I or 2 as permitted by the NEC, may be marked as follows: -

- Class I or Class II or Class III or a combination of where appropriate.
- Division I or Division 2 equipment not marked to indicate a Division or marked Division
  I is suitable for both Division I and 2 locations as defined in the NEC.
- Group classification.
- Operating temperature or temperature range or as permitted by the NEC.



#### 12.8 North American Ingress Protection

Non-Hazardo	us Locations
NEMA	
Enclosure	Application
Type Number	
I	For indoor use to provide a degree of protection (personnel against incidental contact with the enclosed equipment) against falling dirt.
2	For indoor use to provide a degree of protection (personnel against incidental contact with the enclosed equipment) against falling dirt, and to provide a degree of protection against dripping and light splashing of liquids.
3	For either indoor or outdoor use to provide a degree of protection (personnel against incidental contact with the enclosed equipment) against falling dirt, rain, sleet, snow, and windblown dust; and that will be undamaged by the external formation of ice on the enclosure.
3R	For either indoor or outdoor use to provide a degree of protection (personnel against incidental contact with the enclosed equipment) against falling dirt, rain, sleet, and snow; and that will be undamaged by the external formation of ice on the enclosure.
35	For either indoor or outdoor use to provide a degree of protection (personnel against incidental contact with the enclosed equipment) against falling dirt, rain, sleet, snow, and windblown dust; and in which the external mechanism(s) remain operable when ice laden.
4	For either indoor or outdoor use to provide a degree of protection (personnel against incidental contact with the enclosed equipment) against falling dirt, rain, sleet, snow, windblown dust, splashing water, and hose-directed water; and that will be undamaged by the external formation of ice on the enclosure.
4X	For either indoor or outdoor use to provide a degree of protection (personnel against incidental contact with the enclosed equipment) against falling dirt, rain, sleet, snow, windblown dust, splashing water, hose-directed water, and corrosion; and that will be undamaged by the external formation of ice on the enclosure.
5	For either indoor or outdoor use to provide a degree of protection (personnel against incidental contact with the enclosed equipment) against falling dirt; against settling airborne dust, lint, fibres, and flyings; and to provide a degree of protection against dripping and light splashing of liquids.
6	For either indoor or outdoor use to provide a degree of protection (personnel against incidental contact with the enclosed equipment) against falling dirt; against hose-directed water and the entry of water during occasional temporary submersion at a limited depth; and that will be undamaged by the external formation of ice on the
6P	For either indoor or outdoor use to provide a degree of protection (personnel against incidental contact with the enclosed equipment) against falling dirt; against hose-directed water and the entry of water during prolonged submersion at a limited depth; and that will be undamaged by the external formation of ice on the enclosure.
12	Enclosures constructed (without knockouts) for indoor use to provide a degree of protection (personnel against incidental contact with the enclosed equipment) against falling dirt; against circulating dust, lint, fibres, and flyings; and against dripping and light
12K	Enclosures constructed (without knockouts) for indoor use to provide a degree of protection (personnel against incidental contact with the enclosed equipment) against falling dirt; against circulating dust, lint, fibres, and flyings; and against dripping and light splashing of liquids.
13	For either indoor or outdoor use to provide a degree of protection (personnel against incidental contact with the enclosed equipment) against falling dirt; against circulating dust, lint fibres, and flyings; and against the spraying, splashing, and seepage of water, oil, and non-corrosive coolants.



### **Hazardous Locations**

Enclosure Type Number	Application
7	For indoor use in hazardous locations classified as Class I, Division I, Groups A, B, C, or D as defined in NFPA 70.
8	For indoor use in hazardous locations classified as Class II, Division I, Groups E, F, or G as defined in NFPA 70.
9	For indoor use in hazardous locations classified as Class II, Division I, Groups E, F, or G as defined in NFPA 70.

Further information can be found in NEMA Standard Publication 250 and UL 50 Standard Publication.

NEMA Enclosure Type Number	IEC and CENELEC 60529
I	IP10
2	IP1 I
3	IP54
3R	IP14
3S	IP54
4 and 4X	IP56
5	IP52
6 and 6P	IP67

The enclosures are designed to protect and to provide additional protection as stated below: -

The IEC and CENELEC 60529 Standards and NEMA degrees of protection can not be fully compared as equivalent ratings. The NEMA Standard includes tests for environmental conditions such as mechanical damage, corrosion, rusting, ice formation, etc.

### 13.0 Abbreviations, Acronyms and Definitions

ABS	American Bureau of Shipping. ABS is a ship classification society involved with establishing and administering of standards and rules for marine vessels and structures.
AEx	A marking prefix for apparatus complying with one or more types of explosion protection techniques for installation in accordance with Article 505
ANSI	American National Standards Institute
API	American Petroleum Institute
ATEX	EU Directive 94/9/EC Equipment and protective systems intended for use in potentially explosive atmospheres



#### Abbreviations, Acronyms and Definitions (cont'd)

BASEEFA	British Approvals Service for Electrical Equipment in Flammable Atmospheres. They provide a range of testing and certification services primarily related to equipment and systems intended for use in potentially explosive atmospheres. BASEEFA is a constituent of EECS - a branch of the Health & Safety Executive, UK.
BASEEFA (2001) Ltd	They provide a range of testing and certification services primarily related to equipment and systems intended for use in potentially explosive atmospheres.
CEC	Canadian Electric Code. The CEC, Part 1, CSA Standard C22.1, is a safety standard for the installation and maintenance of electrical equipment.
CEN	European Committee for Standardisation
CENELEC	European Committee for Electrotechnical Standardization. CENELEC is a European Standards Organisation that publishes harmonised standards for the European market.
	CENELEC comprises the National Committees of the following countries: Austria, Belgium, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and the United Kingdom.
CEPEL	Centro de Pesquisas de Energia Electrica (Brazil). In Brazil, all electrical or electronic equipment for use in potentially explosive atmospheres should be certified by a Brazilian certification body recognised by INMETRO. CEPEL is an accredited body that is able to issue relevant certification.
CFR	Code of Federal Regulations
Cold Flow	Certain types of cable employ materials that can exhibit "cold flow" characteristics that could have adverse effects on the protection of the apparatus. Where such cable is used, a suitable cable entry device should be employed, for example cable entry devices not employing compression seals that act upon the part(s) of the cable having "cold flow" characteristics. "Cold flow" can be more fully described as thermoplastic materials that flow when subjected to pressure at ambient temperature.
CSA	Canadian Standards Association. A service they offer includes testing and certification services to US and Canadian Standards, as well as international certification through agreements with other approval authorities.
DNV	Det Norske Veritas
EECS	Electrical Equipment Certification Service (UK). They provide a range of testing and certification services primarily related to equipment and systems intended for use in potentially explosive atmospheres. EECS has two divisions, the Mining Equipment Certification Services (MECS), and BASEEFA. The EECS is a branch of the Health & Safety Executive, UK.
Ex	A marking prefix for apparatus complying with one or more types of explosion protection techniques in accordance with CENELEC standards.



### Abbreviations, Acronyms and Definitions (cont'd)

Explosionproof	A term used to describe equipment that is capable of withstanding an explosion of a specified gas or vapour that may occur within it and preventing the ignition of a specified gas or vapour surrounding it.
Flameproof	A type of protection of electrical apparatus in which the enclosure will withstand an internal explosion of a flammable mixture which has penetrated into the interior, without suffering damage and without causing ignition, through any joints or structural openings in the enclosure, of an external explosive atmosphere consisting of one or more of gases or vapours for which it is designed.
FM	Factory Mutual Research Corporation (USA). Services they offer include the testing and approval of electrical equipment in accordance with US and international Standards.
Hazardous Areas	Locations where fire or explosion hazards may exist due to the presence of flammable gases, vapours, mists, ignitable fibres or dusts
IADC	International Association of Drilling Contractors
IEC	International Electrotechnical Commission. Founded in 1906, the IEC is the world organisation that prepares international standards for all electrical, electronic and related technologies. The membership consists of more than 50 participating countries.
IECEx	The aim of the IECEx Scheme is to facilitate international trade in electrical equipment intended for use in potentially explosive atmospheres by eliminating the need for multiple national certificates.
Increased Safety	A type of protection applied to electrical apparatus that does not produce arcs or sparks in normal service and under specified abnormal conditions, in which additional measures are applied so as to give increased security against the possibility of excessive temperatures and of the occurrence of arcs and sparks
INMETRO	Instituto Nacional de Metrologia, Normalização Qualidade Industrial (Brazil)
Intrinsically Safe System	An assembly of interconnected items of apparatus which may comprise intrinsically safe apparatus, associated apparatus and other apparatus, and interconnecting cables in which the circuits within those parts of the system that may be exposed to explosive gas atmospheres are intrinsically safe circuits
Impervious Sheathed Cable	Cable constructed with an impervious metallic or non-metallic overall covering that prevents the entrance of gases, moisture or vapours into the insulated conductor or cable
IP	A system of rating standard levels of Ingress Protection provided by the apparatus.
ISA	The International Society for Measurement and Control (formerly Instrument Society of America)
ISO	International Organisations for Standardisation. A worldwide federation of national standard bodies from 130 countries. ISO's mission is to promote the development of standardisation to facilitate international exchange of goods service.
ITS	Intertek Testing Services



#### Abbreviations, Acronyms and Definitions (cont'd)

Marine Shipboard Cable	Impervious sheathed armoured or non-armoured cable constructed in accordance with UL 1309/CSA C22.2 No. 245, except that an overall impervious sheath is required over the armoured construction, and listed as "Shipboard Cable, Marine" by a Nationally Recognised Testing Laboratory (NRTL)
Maximum Surface Temperature	The highest temperature of a surface accessible to a flammable mixture under conditions of operation and within the ratings of the equipment
MC Cable	Metal-clad cable as defined by NEC Article 334
MC-HL Cable	Metal-clad cable for hazardous locations as defined in UL 2225
NEC	National Electric Code ® (ANSI/NFPA 70)
NEMA	National Electrical Manufacturers Association
NFPA	National Fire Protection Association
OSHA	Occupational Safety and Health Administration, U.S. Department of Labor National Recognised Test Laboratories (NRTL's) recognised by OSHA include CSA, FMRC and UL. The NRTL determines that the specific products meet the relevant standards of safety as required by OSHA and that the products are safe for use in the U.S. workplace. For further information, refer to OSHA's web site at www.osha.gov
PLTC	Power-limited tray cable as defined by NEC article 725
Potentially Explosive Atmosphere	A mixture with air, under atmospheric conditions, of flammable substances in the form of a gas, vapour, mist or dust in which, after ignition, combustion spreads through the un-consumed mixture.
SCS	SIRA Certification Service (UK). They provide a range of testing and certification services and have agreements with other international approval authorities.
тс	Power and control cable as defined by NEC Article 340
UL	Underwriters Laboratories Inc ® (USA)
USCG	United States Coast Guard



# Hawke Cable Glands

Flameproof/Increased Safety and Industrial

## NOTES







Agent/Distributor





# Visit us at www.ehawke.com

To the best of our knowledge the information contained in this leaflet, is accurate at the time of going to print and the company reserves the right to improve or modify any product illustrated without notification The company is unable to accept liability for any inaccuracies, errors o omissions that may exist. It is the customer's responsibility to ensure that the product is suitable for their application.

All copyright reserved-Hubbell Ltd. This document and all copyright therein is the property of: Hawke International a division of of Hubbell Ltd (A member of the Hubbell Group of Companies). Copyright Condition.This document shall be used only for the purpose for which copyright Condition.This document shall be used only for the purpose for which copyright Condition.This document shall be used only for the purpose for which copyright Condition.This document shall be used only for the purpose for which copyright Condition.This document shall be used only for the purpose for which copyright condition.This document shall be used only for the purpose for which copyright condition.

### **Connection Solutions**

www.ehawke.com Hawke international is a division of Hawke international is a division of Hubbell Ltd. A member of the Hubbell Group of Companies.

# Hawke Cable Glands Limited

Oxford Street West, Ashton-under-Lyne, Lancashire OL7 0NA. UK. Sales: 0870 606 0105 Tel: +44 (0)161 830 6695 Fax: +44 (0)161 830 6648 E-mail: sales@ehawke.com www.ehawke.com

Hawke Cable Glands America L.C. 600 Kenrick, Suite C-10, Houston, TX. 77060, USA Tel: +1 (281) 445 7400 Wats: (800) 354 9189 Fax: +1 (281) 445 7404 E-mail: america@ehawke.com www.ehawke.com

Hawke Asia-Pacific Pte Ltd I 30 Joo Seng Road, #03-02 Olivine Building Singapore 368357 Tel: 00 65 6282 2242 Fax: 00 65 6284 4244 E-mail: asia@ehawke.com www.ehawke.com

